

Ministry Of Energy and Natural Resources

BHUTAN POWER SYSTEM OPERATOR

THIMPHU: BHUTAN



ANNUAL TRANSMISSION SYSTEM PERFORMANCE REPORT FOR THE YEAR 2022

JANUARY-2023



Sl. No.	Table of Contents	Page No.
1.0	INTRODUCTION	3
2.0	PERFORMANCE OF GENERATING STATIONS	3
2.1	POWER GENERATION	3
2.2	PLANT FACTOR	7
3.0	PEAK DEMAND, ENERGY AVAILABILITY AND REQUIREMENT FOR THE COUNTRY	10
3.1	NATIONAL LOAD	11
3.2	WESTERN GRID PEAK LOAD	13
3.3	EASTERN GRID PEAK LOAD	14
4.0	EXPORT AND IMPORT OF ELECTRICITY TO/FROM NEIGHBORING COUNTRIES	15
4.1	EXPORT OF ELECTRICITY TO NEIGHBORING COUNTRY	15
4.2	IMPORT OF ELECTRICITY FROM NEIGHBORING COUNTRY	15
5.0	FREQUENCY PROFILE: MAXIMUM AND MINIMUM FREQUENCY RECORDED AND THE FREQUENCY DURATION IN DIFFERENT FREQUENCY BANDS	16
6.0	VOLTAGE PROFILE OF SELECTED SUBSTATIONS	19
7.0	MAJOR GENERATING AND TRANSMISSION OUTAGE	23
8.0	TRANSMISSION CONSTRAINTS	23
9.0	INSTANCES OF PERSISTENT OR SIGNIFICANT NON-COMPLIANCE WITHIN THE GIRD CODE REGULATION	23



1.0 INTRODUCTION

In compliance to Grid Code Regulation 2008, Clause No. 6.14.2.1, this office prepared an annual report covering the performance of the Transmission System and details as required by the Ministry and the Authority annually for development of power system master plan and formulation of other policy decisions, thus this report contains the performance of Transmission System for the year 2022.

All the index and other calculations in this report have been executed based on the data received from substations and generating plants.

2.0 PERFORMANCE OF GENERATING STATIONS

2.1 POWER GENERATION


The maximum individual plant generation was recorded as 1122.00 MW by the Tala Hydropower Plant, followed by 785.70 MW by Mangdichu Hydropower Plant.




Table: 2.1.1 Monthly maximum and minimum generation summary

Sl. No	Hydropower Plant	Monthly Maximum and Minimum Generation (MW)												Max/Min of year (MW)		
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
1	BHP	Max	30.04	28.62	48.46	33.92	65.46	66.64	66.40	66.58	66.39	66.25	43.22	31.30	66.64	
		Min	5.69	4.99	7.58	7.28	5.89	12.92	0.00	0.00	0.00	43.80	14.01	22.90	0.00	
2	CHP	Max	256.79	185.33	251.31	368.16	324.25	369.94	369.99	353.00	353.39	353.14	247.58	211.65	369.99	
		Min	12.13	21.57	28.67	0.00	139.73	192.13	79.47	259.79	165.59	233.02	111.09	48.38	0.00	
3	THP	Max	0.00	0.00	480.00	820.00	670.00	988.00	1,122.00	1,122.00	1,122.00	1,122.00	560.00	400.00	1,122.00	
		Min	0.00	0.00	110.00	0.00	170.00	100.00	557.00	830.00	734.00	470.00	230.00	120.00	0.00	
4	KHP	Max	48.24	48.96	65.64	196.45	270.23	66.00	66.00	66.00	66.00	66.00	56.60	32.63	270.23	
		Min	8.86	10.03	10.06	0.00	31.61	29.63	0.00	0.00	0.00	33.00	20.95	20.03	0.00	
5	DHP	Max	32.99	47.50	40.25	45.98	53.38	126.92	95.10	100.70	100.79	100.70	52.27	40.03	126.92	
		Min	22.47	22.93	22.17	0.00	17.97	22.70	5.50	1.13	40.30	48.74	31.31	23.06	0.00	
6	MHP	Max	280.21	294.88	341.11	595.22	593.15	785.70	594.19	729.82	729.92	729.34	325.11	211.65	785.70	
		Min	12.22	19.30	20.87	0.00	105.79	271.01	193.19	395.37	232.07	279.19	75.37	48.38	0.00	


Graph: 2.1.1 Basochhu generation summary




Graph: 2.1 Chhukha generation summary




Graph: 2.1.3 Tala generation summary




Graph: 2.1.4 Kurichhu generation summary



Graph: 2.1.5 Dagachhu generation summary



Graph: 2.1.6 Mangdichu generation summary



2.2 PLANT FACTOR


The plant factor of each generating plant was calculated as below:

$$\begin{aligned}
 \text{Plant factor} &= (\text{Actual output of a plant over a period of time}) / (\text{Output when operated at name plate rated capacity for entire time}) \\
 &= (\text{Total energy plant has produced over a period}) / (\text{Total energy plant would produce when operated at full rated capacity})
 \end{aligned}$$


Table: 2.2.1 Monthly plant factor of the hydropower plants

Sl. No	Hydropower Plant	Monthly Plant Factor (%)												Max/Min of year (%)	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Max	Min
1	BHP	37.20	30.97	38.40	31.91	36.78	92.28	92.30	98.79	102.19	89.41	56.90	41.87	102.19	30.97
2	CHP	33.96	27.31	41.33	52.76	53.84	92.24	87.80	92.73	99.67	96.38	52.42	36.82	99.67	27.31
3	THP	0.00	0.00	14.70	34.78	34.96	56.63	92.25	106.34	101.93	78.29	35.11	23.84	106.34	0.00
4	KHP	35.24	29.24	55.65	82.25	95.34	104.95	106.03	109.72	103.37	104.25	61.95	43.05	109.72	29.24
5	DHP	21.43	19.23	21.43	17.54	19.21	58.65	66.56	74.36	68.47	58.97	32.35	23.22	74.36	17.54
6	MHP	30.31	28.92	23.73	23.04	34.96	44.51	27.44	28.01	91.14	28.95	5.56	0.00	91.14	0.00


Graph: 2.2.1 Plant factor of Basochhu Hydropower Plant




Graph: 2.2.2 Plant factor of Chhukha Hydropower Plant



Graph: 2.2.3 Plant factor of Tala Hydropower Plant




Graph: 2.2.4 Plant factor of Kurichhu Hydropower Plant



Graph: 2.2.4 Plant factor of Dagachhu Hydropower Plant

Graph: 2.2.4 Plant factor of Mangdichu Hydropower Plant



3.0 PEAK DEMAND, ENERGY AVAILABILITY AND REQUIREMENT FOR THE COUNTRY

Calculation of coincidental peak load for the eastern grid, western grid and national load, we use the following methods:

1. *National Demand = (Sum of all total generation of each plant) – (Sum of all Export/Import)*
2. *National Demand = (Sum of all feeders loading at hydropower plant) – (Sum of all Export/Import)*
3. *National Demand = (Sum of all substation loading)*



The national load calculated using method-1 is considered in the report.

3.1 NATIONAL LOAD

The national peak demand till now is recorded at **629.61MW** which was occurred on December 28, 2022 at 18:00 hours. This is calculated by summation of Generation minus Export/Import.

Table3.1. the National Peak Demand since 2007

Year	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022
Peak Load (MW)	157.36	187.05	237.17	256.95	276.24	282.44	313.94	333.41	336.52	335.87	362.09	399.35	387.66	374.53	435.35	629.61
% Growth over previous Year	-	18.87	26.79	8.34	7.51	2.24	11.15	6.20	0.93	-0.19	7.81	10.29	-2.93	-3.39	16.24	44.62



Table: 3.1.2 Monthly national peak load and corresponding generation using method- 1

Sl. No	Months	Date	Time	Total Grid (MW)		Western Grid (MW)		Eastern Grid (MW)	
				Load	Generation	Load	Generation	Load	Generation
1	Jan	4-Jan-21	19:00	577.89	618.90	390.60	282.68	36.91	336.22
2	Feb	4-Feb-21	19:00	461.32	527.33	382.78	204.72	35.55	322.61
3	Mar	4-Mar-21	19:00	430.01	514.90	325.89	211.00	26.84	303.90
4	Apr	27-Apr-22	18:00	424.55	917.11	221.84	367.68	90.13	549.43
5	May	6-May-22	18:00	417.81	926.85	178.00	444.37	87.68	482.48
6	Jun	16-Jun-22	8:00	438.47	1,545.87	369.14	954.89	128.17	590.98
7	Jul	13-Jul-22	20:00	467.95	1,399.11	491.76	1,256.08	144.03	143.03
8	Aug	18-Aug-22	15:00	540.67	1,690.17	396.15	1,492.08	54.55	198.09
9	Sep	10-Sep-22	8:00	527.18	1,800.93	436.50	1,604.50	64.90	196.43
10	Oct	25-Oct-22	18:00	530.45	1,601.27	433.09	1,381.44	81.67	219.83
11	Nov	3-Nov-22	13:00	620.02	963.42	387.37	705.04	87.76	258.38
12	Dec	6-Dec-22	13:00	629.61	900.70	367.29	478.94	69.12	421.76
National Peak Load of the year (MW)				629.61					


2 WESTERN GRID PEAK LOAD

Using method-1, the peak load for the western grid was 491.76 MW which occurred on July 13, 2022.

Table: 3.2.1 Monthly western peak load and corresponding generation

Sl. No	Months	Date	Time	Western Grid (MW)	
				Load	Generation
1	Jan	17-Jan-22	17:00	390.60	282.68
2	Feb	10-Feb-22	19:00	382.78	204.72
3	Mar	1-Mar-22	21:00	325.89	211.00
4	Apr	29-Apr-22	9:00	221.84	367.68
5	May	1-May-22	5:00	78.31	365.00
6	Jun	16-Jun-22	8:00	369.14	368.80
7	Jul	13-Jul-22	20:00	491.76	370.00
8	Aug	28-Aug-22	20:00	396.15	375.80
9	Sep	13-Sep-22	19:00	436.50	380.00
10	Oct	13-Oct-22	0:00	433.09	385.00
11	Nov	2-Nov-22	19:00	387.37	370.00
12	Dec	30-Dec-22	22:00	437.23	372.58
Western Peak Load of the year (MW)				491.76	

Graph: 3.2.1 Monthly western peak load and corresponding generation




3.3 EASTERN GRID PEAK LOAD

Using method-3, the peak load for the eastern grid was 144.03 MW which occurred on July 22, 2022.

Table: 3.3.1 Monthly eastern peak load and corresponding generation

Sl. No	Months	Date	Time	Eastern Grid (MW)	
				Load	Generation
1	Jan	31-Jan-21	14:00	87.73	118.31
2	Feb	5-Feb-21	19:00	75.47	105.39
3	Mar	9-Mar-21	8:00	88.62	115.66
4	Apr	28-Apr-22	6:00	57.06	452.99
5	May	24-May-22	12:00	65.04	174.58
6	Jun	21-Jun-22	3:00	68.00	659.18
7	Jul	22-Jul-22	7:00	144.03	654.88
8	Aug	19-Aug-22	7:00	54.55	794.47
9	Sep	22-Sep-22	7:00	64.90	445.73
10	Oct	23-Oct-22	6:00	69.10	373.43
11	Nov	3-Nov-22	10:00	68.60	308.97
12	Dec	23-Dec-22	10:00	70.32	142.98
Eastern Peak Load of the year (MW)				144.03	

Graph: 3.3.1 Monthly eastern peak load and corresponding generation





4.0 EXPORT AND IMPORT OF ELECTRICITY TO/FROM NEIGHBORING COUNTRIES

4.1 EXPORT OF ELECTRICITY TO NEIGHBORING COUNTRY

Maximum export of electricity for the year was 1,280.73MW to Binaguri substation in August, 2022, followed by 310.42 MW to Birpara substation. The minimum export was 0.00 MW to Binaguri and Birpara substation.

Table: 4.1.1 Monthly power export summary

Sl. No	Substation in India	Monthly Maximum and Minimum Export (MW)												Max/Min of year (MW)	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
1	Binaguri	Max	0.00	0.00	217.46	256.45	325.09	1,108.54	1,209.00	1,280.73	1,136.36	1,071.00	496.36	332.64	1,280.73
		Min	0.00	0.00	0.09	0.55	0.09	8.00	571.03	727.27	559.00	336.00	131.91	17.00	0.00
2	Birpara	Max	0.00	39.25	100.60	194.13	159.78	310.42	232.88	260.74	281.22	224.12	93.70	85.54	310.42
		Min	0.00	0.66	0.27	0.30	0.28	31.91	51.30	52.32	4.30	56.09	0.38	9.90	0.00
3	Salakoti & Rangia	Max	18.99	25.11	51.10	56.48	67.16	96.56	77.24	77.91	95.51	97.88	43.27	30.09	97.88
		Min	0.04	0.07	0.05	0.18	1.55	50.16	2.00	13.79	0.50	4.00	0.04	0.04	0.04

4.2 IMPORT OF ELECTRICITY FROM NEIGHBORING COUNTRY

Maximum import of power was 157.91 MW from Birpara substation which occurred in January, 2022 followed by 149 MW and 47.59 MW from Binaguri, Salakati & Rangia respectively.



Table: 4.2.1 Monthly power import summary

Sl. No	Substation in India		Monthly Maximum and Minimum Import (MW)												Max/Min of year (MW)		
			Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
1	Binaguri	Max	120.36	110.56	88.36	127.00	62.18	149.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	149.00	
		Min	36.73	4.36	0.09	0.40	0.09	106.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00
2	Birpara	Max	157.91	137.92	135.32	66.36	90.15	0.00	0.00	0.00	24.16	0.00	80.08	128.04	157.91		
		Min	1.44	0.46	0.05	0.02	0.01	0.00	0.00	0.00	24.16	0.00	0.02	1.75		0.00	
3	Salakoti & Rangia	Max	39.23	38.54	33.74	36.52	18.53	0.00	20.02	10.24	15.60	0.00	16.08	47.59	47.59		
		Min	0.05	0.29	0.05	0.37	11.52	0.00	1.29	10.24	0.06	0.00	0.01	0.06		0.00	

5.0 FREQUENCY PROFILE: MAXIMUM AND MINIMUM FREQUENCY RECORDED AND THE FREQUENCY DURATION IN DIFFERENT FREQUENCY BANDS

As per the Grid Code Regulation 2008, Clause 6.4.1 the transmission system frequency was classified into three different bands as follows:

1. *Normal state*
The transmission system frequency is within the limit of 49.5Hz to 50.5Hz
2. *Alert state*
The transmission system frequency is beyond the normal operating limit but within 49.0Hz to 51.0Hz
3. *Emergency state*
There is generation deficiency and frequency is below 49.0Hz.

We base our frequency at 220kV Bus frequency at 220/66/11kV Sementokha substation in the western grid and 132kV Bus frequency at 50Hz and Kurichhu Hydropower Plant in the eastern grid.



Table: 5.0.1 Frequency profile at Semtokha substation

220/66/11kV Semtokha Substation					
Sl. No	Months	220kV Bus Frequency Operation State (%)			
		Normal	Alert	Emergency	Blackout/ Other
1	Jan	100.00	0.00	0.00	0.00
2	Feb	90.19	0.00	0.00	9.81
3	Mar	99.87	0.00	0.00	0.13
4	Apr	96.51	0.13	0.00	3.36
5	May	100.00	0.00	0.00	0.00
6	Jun	96.64	0.00	0.00	3.36
7	Jul	100.00	0.00	0.00	0.00
8	Aug	99.23	0.13	0.00	0.00
9	Sep	96.51	0.00	0.00	3.49
10	Oct	100.00	0.00	0.00	0.00
11	Nov	96.77	0.00	0.00	3.23
12	Dec	0.00	0.00	0.00	0.00
Operation State for the year		89.64%	0.02%	0.00%	1.95%



Table: 5.0.2 Frequency profile at Kurichhu Hydropower plant

60MW Kurichhu Hydropower Plant					
Sl. No	Months	132kV Bus Frequency Operation State (%)			
		Normal	Alert	Emergency	Blackout/ Other
1	Jan	99.87	0.13	0.00	0.00
2	Feb	89.52	0.00	0.54	9.95
3	Mar	100.00	0.00	0.00	0.00
4	Apr	96.37	0.00	0.00	3.63
5	May	100.00	0.00	0.00	0.00
6	Jun	96.51	0.13	0.13	3.23
7	Jul	98.79	0.00	0.00	1.21
8	Aug	100.00	0.00	0.00	0.00
9	Sep	96.37	0.40	0.00	3.23
10	Oct	100.00	0.00	0.00	0.00
11	Nov	98.66	0.00	0.00	1.34
12	Dec	0.00	0.00	0.00	0.00
Operation State for the year		89.67%	0.06%	0.06%	1.88%



6.0 VOLTAGE PROFILE OF SELECTED SUBSTATIONS

As the Grid Code Regulation 2008, Clause 6.4.1, the voltage at all connection points was classified into three different bands as follows:

1. *Normal state*
The voltages at all connection point are within the limits of 0.95 times and 1.05 times of the normal values
2. *Alert state*
The voltage at all connection points are outside the normal limit but within the limits of 0.9 times and 1.1 times of the normal values
3. *Emergency state*
Transmission system voltages are outside the limits of 0.9 times and 1.1 times of nominal values.

The voltage profile of 400/220/66/11kV Malbase substation in western grid and 132/33/11kV Nangkhor substation in the eastern grid are considered in the report.



Table: 6.0.1 Voltage profile at Malbase substation

400/220/66/11kV Malbase Substation									
Sl. No	Months	400kV Bus Voltage Operation State (%)				220kV Bus Voltage Operation State (%)			
		Normal	Alert	Emergency	Blackout/ Other	Normal	Alert	Emergency	Blackout/ Other
1	Jan	58.06	58.06	58.06	58.06	58.06	58.06	58.06	58.06
2	Feb	60.22	29.84	58.06	9.68	90.32	0.00	0.00	9.68
3	Mar	91.80	8.20	58.06	0.00	100.00	0.00	0.00	0.00
4	Apr	96.77	0.00	58.06	3.63	92.07	4.44	0.00	3.49
5	May	99.87	0.00	58.06	0.00	99.87	0.13	0.00	0.00
6	Jun	96.77	0.00	58.06	3.23	96.77	0.00	0.00	3.23
7	Jul	99.73	0.00	58.06	0.00	99.73	0.00	0.27	0.00
8	Aug	0.00	0.00	58.06	0.13	99.87	0.00	0.00	0.13
9	Sep	96.77	0.00	58.06	3.23	96.64	0.00	0.13	3.23
10	Oct	100.00	0.00	58.06	0.00	100.00	0.00	0.00	0.00
11	Nov	77.69	19.09	58.06	3.23	96.77	0.00	0.00	3.23
12	Dec	95.70	0.04	0.00	0.00	100.00	0.00	0.00	0.00
Operation State for year		81.12%	9.60%	53.23%	6.77%	94.18%	5.22%	4.87%	6.75%





Table: 6.0.2 Voltage profile at Nangkhor substation

132/33/11kV Nangkhor Substation					
Sl. No	Months	132kV Bus Voltage Operation State (%)			
		Normal	Alert	Emergency	Blackout/ Other
1	Jan	99.87	0.13	0.00	0.00
2	Feb	90.19	0.13	0.00	9.68
3	Mar	100.00	0.00	0.00	0.00
4	Apr	94.89	4.97	0.00	0.13
5	May	97.18	2.82	0.00	0.00
6	Jun	96.77	0.00	0.00	3.23
7	Jul	99.73	0.13	0.00	0.13
8	Aug	0.00	0.00	0.00	0.00
9	Sep	96.77	0.00	0.00	3.23
10	Oct	100.00	0.00	0.00	0.00
11	Nov	96.77	0.00	0.00	3.23
12	Dec	0.00	0.00	0.00	0.00
Operation State for year		81.01%	0.68%	0.00%	1.64%



7.0 MAJOR GENERATING AND TRANSMISSION OUTAGE

The summary of the major transmission outages for the eastern grid and western grid are attached as Annexure- I and Annexure- II respectively.

The outages of transmission line or transformer or any power system equipment below 66kV, tripping/outage of less than 30minutes and planned shutdown which do not cause supply interruption to the customers are not reflected.

8.0 TRANSMISSION CONSTRAINTS

There are no instant of transmission constraints during normal condition in Bhutan Power System.

9.0 INSTANCES OF PERSISTENT OR SIGNIFICANT NON-COMPLIANCE WITHIN THE GRID CODE REGULATION

The instance of non-compliance with the Grid Code Regulation 2008 for the year 2019 was not recorded.

Annexure- I



Eastern Grid Outages January 2022

MONTHLY OUTAGE REPORT FOR THE MONTH OF JANUARY, 2022 UNDER SMD DEOTHANG, TD, BPC.

Division: SMD-DEOTHANG		Substation: 132/33/11kV Nangdur Substation		Month: Jan-22										
Sl No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Date	Time	Normalization Date	Time	Duration of Outage (Hrs)	MW before Outage (MW)	Protection Relay Operated	Tripping Details (As recorded by relay)	Type/Cause of Fault	Reason for Shutdown	Remarks
132kV Feeders														
1	SMVA Transformer-I, 132/22/11kV	132kV	Tripping	02-01-2022	10:47 hrs	02-01-2022	10:49 hrs	0	2	Non directional IDMT PROTON Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Tesbar feeder
2	SMVA Transformer-II, 132/22/11kV	132kV	Tripping	02-01-2022	10:47 hrs	02-01-2022	10:48 hrs	0	1	Non directional IDMT PROTON Relay operated	Non dir O/C relay-50A & tripping relay 86 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Tesbar feeder
3	SMVA Transformer-I, 132/22/11kV	132kV	Tripping	03-01-2022	03:12 hrs	03-01-2022	03:13 hrs	0	1	Non directional IDMT PROTON Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped due to fault on 33kV Tesbar feeder
4	SMVA Transformer-II, 132/22/11kV	132kV	Tripping	03-01-2022	03:12 hrs	03-01-2022	03:14 hrs	0	2	Non directional IDMT PROTON Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped due to fault on 33kV Tesbar feeder
5	Nangdur-Nganglum	132kV	Tripping	12-01-2022	08:14 hrs	12-01-2022	08:29 hrs	0	15.4	MCOMP4DB & P142	<i>Directional -O/C & R/F Relay:</i> Start O CN, tripped O N.O.C stat I-1, E.FI start IN1>12, trip IN1-2, VAB=127.3kV, VBC=99.91kV, VCA=94.07kV, VAN=73.38kV, VBN=72.45kV, VCN=38.08kV, VNI=0.01A=40.32A, IB=93.69A, IC=93.5A, ID=Ined=1.018A, IN measured=1.0138A & tripping relay 86 operated at our end. <i>Distance relay:</i> Start O CN, fault duration=203.4ms, relay trip time=0.005, fault location=44.14KM, IA=12.0A, IB=95.19A, IC=94.55A, VAN=73.54kV, VBN=72.07, VCN=38.31kV, fault resistance=5.824Q, fault core-Zone 3	Tripped on fault	-	Informed to BPSO, and charged as per their instruction.
6	SMVA Transformer-I, 132/22/11kV	132kV	Tripping	17-01-2022	09:00 hrs	17-01-2022	09:05 hrs	0	5	Non directional IDMT PROTON Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped due to fault on 33kV Wamung feeder
7	SMVA Transformer-II, 132/22/11kV	132kV	Tripping	17-01-2022	09:00 hrs	17-01-2022	09:05 hrs	0	5	Non directional IDMT PROTON Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped due to fault on 33kV Wamung feeder



Transmission System Performance Report 2022

Division: SMD DEOTHANG	
Substation: 132/33/11kV Deothang Substation	
Month: Jan-22	

Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage (Hrs)	Duration of Outage (Min)	MW before Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Protective Relay Operd	Fault Details (As recorded by relay)			

NO TRIPPING

Division: SMD DEOTHANG	
Substation: 132/33/11kV Nganglam Substation	
Month: Jan-22	

Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage (Hrs)	Duration of Outage (Min)	MW before Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Protective Relay Operd	Fault Details (As recorded by relay)			

1	Tagtla Nganglam	112kV	Tripping	12.01.2022	8:10	12.01.2022	8:25	0	15	-28.91	Micom relay P412	IA=122.44 IB=243.1A (C=1.2)23kA Ph-CN Tripped ABC	Over Current		Supply restored after confirmation from BPSO and coordination to Tagtla end
2	SMVA Tr-II	112kV	Tripping	27.01.2022	14:58	27.01.2022	15:03	#REF!	5	0.752	O-C & E/F Micom relay		Due to 33kV Discharging Feeder		Supply restored after isolating the 33kV Discharging Feeder and withstood.

Division: SMD DEOTHANG	
Substation: 132/33kV Motanga Substation	
Month: Jan-22	

Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage (Hrs)	Duration of Outage (Min)	MW before Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Protective Relay Operd	Fault Details (As recorded by relay)			

1	DML Factory Feeder	112kV	Tripping	07-01-2022	12:24:50 PM	07-01-2022	22:28:00 PM	0	4	0	86A & 86B OPTD				Changed the feeder with a charging code 1019 from BPSO
2	Deothang Feeder	112kV	Tripping	08-01-2022	12:05	08-01-2022	12:19	0	14	-24.62	86A & 86B OPTD				Changed the feeder with a charging code 1046 from BPSO
3	Ranga Feeder	112kV	Tripping	08-01-2022	12:05	09-01-2022	0:51	12	46	4.42			Y-Phase IA was punctured at Ranga end		Changed the feeder with a charging code 1048 from BPSO (Shantanu), 817 from NLDC (Indra) and 4588 from BLDCC (Indra)
4	DML Factory Feeder	112kV	Tripping	15-01-2022	12:43:00 PM	15-01-2022	22:45:00 PM	0	2	0	86A & 86B OPTD				Changed the feeder with a charging code 1095 from BPSO

Division: SMD DEOTHANG	
Substation: 132/33kV Motanga Substation	
Month: Jan-22	

Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage (Hrs)	Duration of Outage (Min)	MW before Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Protective Relay Operd	Fault Details (As recorded by relay)			

1	DML Factory Feeder	112kV	Tripping	07-01-2022	12:24:50 PM	07-01-2022	22:28:00 PM	0	4	0	86A & 86B OPTD				Changed the feeder with a charging code 1019 from BPSO
2	Deothang Feeder	112kV	Tripping	08-01-2022	12:05	08-01-2022	12:19	0	14	-24.62	86A & 86B OPTD				Changed the feeder with a charging code 1046 from BPSO
3	Ranga Feeder	112kV	Tripping	08-01-2022	12:05	09-01-2022	0:51	12	46	4.42			Y-Phase IA was punctured at Ranga end		Changed the feeder with a charging code 1048 from BPSO (Shantanu), 817 from NLDC (Indra) and 4588 from BLDCC (Indra)
4	DML Factory Feeder	112kV	Tripping	15-01-2022	12:43:00 PM	15-01-2022	22:45:00 PM	0	2	0	86A & 86B OPTD				Changed the feeder with a charging code 1095 from BPSO

Division: SMD DEOTHANG	
Substation: 132/33kV Corang Substation	
Month: Jan-22	

Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage (Hrs)	Duration of Outage (Min)	MW before Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Protective Relay Operd	Fault Details (As recorded by relay)			

NO TRIPPING

Division: SMD DEOTHANG	
Substation: 132/33kV Phantschohang Substation	
Month: Jan-22	

Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage (Hrs)	Duration of Outage (Min)	MW before Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Protective Relay Operd	Fault Details (As recorded by relay)			

1	132/33kV Transformer-II (10MVA)	112kV	Transient Fault	13-01-2022	16:03	13-01-2022	16:07		4	0.49	86A and 86B	(DPHLPDOCI) Trip value: L1: 3.6A, L2: 150.5 A, L3: 156.15 A, L4: 0.00 A.	rr current and Earth fs	Unknown	Charged
2	132/33kV Transformer-I (10MVA)	112kV	Transient Fault	26-01-2022	11:14	26-01-2022	11:17		3	0.23	86A and 86B	(DPHLPDOCI) Trip value: L1: 4.1A, L2: 225.4A, L3: 218.3 A, L4: 0.00 A.	rr current and Earth fs	Unknown	Charged
3	132/33kV Transformer-II (10MVA)	112kV	Tripping	28-01-2022	08:30	28-01-2022	08:32		2	0.92	86A and 86B	(DPHLPDOCI) Trip value: L1: 4.6A, L2: 2A, L3: 71.25A, L4: 0.00 A.	rr current and Earth fs	Unknown	Charged



Transmission System Performance Report 2022

1. 400/220/132/33kV Jigmeling Substation													
Sl. No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MW before Outage (MW)	Name of feeder	Name of the Substation/lines Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outages	Remarks
i) 66kV Above													
1	26.01.2022	18:39 hrs	26.01.2022	18:47 hrs	0	36.52	132kV Tingubi	Tingubi	Main 1, Relay General Trip, B phase trip Line loop B-G	SIPROTEC 7SA52	Distance: 42.8 km	Transient	
2. 220/66/33kV Dhajay Substation													
i) 66kV and above													
1	12.01.2022	05:38:20hrs	12.01.2022	05:51:32hrs		-16.96	Jigmeling feed	Dhajay St o/c		Main -I=IA=1.76kA, IB=1.59kA, IC=1.57kA. main-2, Ia=0157.01A, Tripped			feeder restored after as per DPSO instruction.

February 2022

Division:		SMD DITHANG													
Substation:		132/33/11kV Kikkhae Substation													
Month:		Feb-22													
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration of Outage		MW before Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)		Protection Relay Operd	Fault Details (As recorded by relay)			
132kV Feeders															
1	132KV/Cothing	132KV	Tripped	05-02-2022	12:43hrs	05-02-2022	12:50hrs	0	7	3.420	NI	NI	Tripped		Tripped from Kwikhu end
2	132KV Cothing	132KV	Tripped	05-02-2022	14:13hrs	07-02-2022	19:19 hrs	52	57	10.160	Distance protection relay	Start Phase CN, Trip Phase ABC, Distance 4.34KM towards Cothing SS, IA=3.236A, IB=0.00A, IC=563.2A, Zone 1.	Tripped		Tripped due to heavy snowfall, conductor snapped at Kwikhu Location KK 28 Y phase & KK 31 B phase.
2	132KV Cothing	132KV	Tripped	08-02-2022	14:29hrs	08-02-2022	18:12hrs	3	43	8.922	NA	NI	Shutdown	Maintenance of CVT	Shutdown Taken by Cothing Incharge to Maintenance work for CVT

Division:		SMD DITHANG													
Substation:		132/33/11kV Kraglung Substation													
Month:		Feb-22													
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration of Outage		MW before Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)		Protection Relay Operd	Fault Details (As recorded by relay)			
132kV															
1	5MVA Transformer - I	132kV	Tripped	09.02.2022	10:59	09.02.2022	11:08	0	9	1.992	NA	NA	Due to out going feeder(UDZORONG)	NA	Both 5MVA transformer got tripped as line fault with Udzoong feeder.
	5MVA Transformer - II	132kV	Tripped	09.02.2022	10:59	09.02.2022	11:08	0	9	1.992	NA	NA	Due to out going feeder(UDZORONG)	NA	Both 5MVA transformer got tripped as line fault with Udzoong feeder.
2	332KV Cothing	132kV	Tripped	21.02.2022	2:20	21.02.2022	2:44	0	24	-4.248	NA	NA	Guide fail from Kwikhu	NA	Guide fail from Kwikhu
	5MVA Transformer -I	132kV	Tripped	22.02.2022	7:45	22.02.2022	9:08	1	23	2.271	NA	NA	Due to out going feeder(UDZORONG)	NA	5MVA transformer I got tripped as line fault with Udzoong feeder. Tripping coil burned and replaced



Transmission System Performance Report 2022

Division: SMD DEOTHRANG		Substation: 132/33/11kV Nangkul Substation		Month: Feb-22													
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/ Tripping)	Shutdown/ Tripping		Normalization Time		Duration of Outage (Min)	MW before Outage (MW)	Protection Relay Operd	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks		
				Date	Time	Date	Time				(Hrs)	Fault Details (As recorded by relay)					
132kV Feeders																	
1	Nangkul-Deothang Line	132kV	Tripping	01-02-2022	15:25 hrs	01-02-2022	15:37 hrs	0	10	16.7	MCCOMP14DB & Distance relay	Directional -O/C & E/F Relay: Start O IN, tripped O N/O C start I-1, E/F1 start IN1=12, trip IN1=2 VAB=82.38kV, VBC=82.52kV, VCA=126.3kV, VAN=68.48kV, VBN=19.78kV, VCN=7.39kV, VN=0.0kV, IN measured=1.03kA, IC=1.070kA, IB=1.070kA, IC=1.007A, VAN=66.55kV, VBN=32.85kV, VCN=66.20kV, fault resistance=1.01kΩ, fault zone=Zone 3	Tripped on fault	-	Informed to BPSO and changed the feeder as per their instruction.		
2	5MVA Transformer-I, 132/22/11kV	132kV	Tripping	04-02-2022	19:09 hrs	04-02-2022	19:11 hrs	0	5	1.3	Non directional IDMT PROT N Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Wanrong feeder		
3	5MVA Transformer-I, 132/22/11kV	132kV	Tripping	05-02-2022	07:32 hrs	05-02-2022	07:36 hrs	0	4	0.78	Non directional IDMT PROT N Relay operated	Non dir O/C relay-50A & tripping relay 86 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Wanrong feeder		
4	5MVA Transformer-II, 132/22/11kV	132kV	Tripping	05-02-2022	07:32 hrs	05-02-2022	07:35 hrs	0	3	0.55	Non directional IDMT PROT N Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped due to fault on 33kV Wanrong feeder		
5	5MVA Transformer-I, 132/22/11kV	132kV	Tripping	05-02-2022	08:53 hrs	05-02-2022	08:56 hrs	0	5	0.47	Non directional IDMT PROT N Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped while test charging Wanrong feeder		
6	5MVA Transformer-II, 132/22/11kV	132kV	Tripping	05-02-2022	08:53 hrs	05-02-2022	08:55 hrs	0	2	0.51	Non directional IDMT PROT N Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped while test charging Wanrong feeder		
7	5MVA Transformer-I, 132/22/11kV	132kV	Tripping	05-02-2022	10:21 hrs	05-02-2022	10:23 hrs	0	2	0.99	Non directional IDMT PROT N Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped while due to fault on Tselbar feeder		
8	5MVA Transformer-II, 132/22/11kV	132kV	Tripping	05-02-2022	10:21 hrs	05-02-2022	10:22 hrs	0	1	1.25	Non directional IDMT PROT N Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped while due to fault on Tselbar feeder		
9	5MVA Transformer-II, 132/22/11kV	132kV	Tripping	05-02-2022	15:32 hrs	05-02-2022	15:35 hrs	0	1	1.09	Non directional IDMT PROT N Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped while test charging Wanrong feeder		
10	Nangkul-Nyanglung	132kV	Tripping	06-02-2022	06:46 hrs	06-02-2022	06:53 hrs	0	7	-12.45	MCCOMP14DB	Directional -O/C & E/F Relay: Tripped O N Start O AN O/C start I-1, E/F1 start IN1=12, trip IN1=1 VAB=104.9kV, VBC=133.48kV, VCA=107.8kV, VAN=17.18kV, VBN=75.89kV, VCN=7.478kV, VN=0.0kV, IA=606.3A, IB=49.91A, IC=17.28A, IN Devid=505.0A, IN measured=563.1A & tripping relay 86 operated at our end.	Tripped on fault	-	Informed to BPSO, and charged as per their instruction.		
11	5MVA Transformer-II, 132/22/11kV	132kV	Tripping	06-02-2022	16:05 hrs	06-02-2022	16:07 hrs	0	2	0.66	Non directional IDMT PROT N Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped while test charging Wanrong feeder		
12	5MVA Transformer-II, 132/22/11kV	132kV	Tripping	20-02-2022	17:37 hrs	20-02-2022	17:55 hrs	0	8	1.49	Non directional IDMT PROT N Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped due to fault on 33kV Wanrong, Yangang & Nangkul feeders		
14	Main Grid/Rangas Grid	132kV	Tripping	21-02-2022	02:22 hrs	21-02-2022	02:45 hrs	0	23	7.1			-	-	Supply failed from Rangas Substation		
15	Nangkul-Nyanglung Line	132kV	Tripping	25-02-2022	16:17 hrs	25-02-2022	16:30 hrs	0	13	-7.22	MCCOMP14DB & Distance Relay	Directional -O/C & E/F Relay: Tripped O N Start O BCN O/C start I-1, E/F1 start IN1=12, trip IN1=2 VAB=108.8kV, VBC=89.78kV, VCA=105.8kV, VAN=71.96kV, VBN=43.78kV, VCN=14.1kV, VN=0.0kV, IA=29.94A, IB=45.2A, IC=22.2A, IN Devid=592.4A, IN measured=582.1A & tripping relay 86 operated at our end. Distance relay indication: Start O BC, TOC start, Tripped. Fault No. Fault alarm No. fault duration: 1.97sec, relay trip time: 0.00, IA 31.25A, IB=667.2A, IC=851.7A, VAN=74.62kV, VBN=43.86kV, VCN=44.07kV, fault zone=zone	Tripped on fault	-	Informed to BPSO, and changed the feeder as per their instruction.		
Division: SMD DEOTHRANG		Substation: 132/33/11kV Nyanglung Substation		Month: Feb-22													
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/ Tripping)	Shutdown/ Tripping		Normalization Time		Duration of Outage (Min)	MW before Outage (MW)	Protection Relay Operd	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks		
				Date	Time	Date	Time				(Hrs)	Fault Details (As recorded by relay)					
132kV																	
2	Nyanglung-Tingthi	132kV	Tripping	05-02-2022	15:13	05-02-2022	15:19	0	36	-24.16	Silicon relay P412	IA=15.77A IB=1.314A IC=1.328A Tripped on Zone 1 Fault Location 28.20km	Over Current	-	Supply normalised with wide closing code# 1221 issued by Madam Eshodra Choden BPSO.		
3	Nyanglung-Tingthi	132kV	Tripping	06-02-2022	06:49	07-02-2022	19:09	16	20	-18.74	Micromer P442	IA=743.7A IB=90.30A IC=136.1A Ie=531.4A(Tripped on Zone 3) Fault Location: 207.10km	Earth Fault/Conductor Snapped	-	Feeder Test charged at 07:00hrs from our end as per BPSO instruction with wide closing code# 1227 issued by Madam Karma Yangdrol BPSO but Tingthi end observed one phase is missing at their end(R, P/I) and around we received a call saying that conductor is snapped at Palyang site and immediately the CB was hand tripped from our end and informed to BPSO. The supply was normalised after completing the re-staging of Conductor with wide closing code# 1234 issued by Madam Choden		
5	3MVA Transformer	132kV	Tripping	20-02-2022	19:32	20-02-2022	19:39	6	1.427			Tripped due to 33kV Phubang feeder fault	Earth Fault	-			
6	Nyanglung-Nyanglung	132kV	Grid Fail	21-02-2022	02:22	21-02-2022	02:45	0	23		NA	NA	Grid Fail	-	Grid fail from Nyanglung and since the station is feeder 6 on single source as Nyanglung-Tingthi feeder is under shutdown.		



Transmission System Performance Report 2022

Division		SMD DIOHANG													
Substation		132/33kV Motanga Substation													
Month		Feb-22													
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage		MW before Outage (MW)	Protection Relay Operd	Tripping Details	Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)						
1	Diohang Feeder	132kV	Tripping	02-02-2022	15:29:00 PM	02-02-2022	15:59:00 PM	0	10	-15.47	OC on B-phase, EF, 86 A & B operated	OC EF and 86A/B operated	transient fault	-	-
2	Rangji Feeder	132kV	Tripping	02-02-2022	15:29:00 PM	02-02-2022	15:59:00 PM	0	30	-12.09	OC EF and 86A/B operated	OC EF and 86A/B operated	transient fault	-	Charged the feeder with a charging code 1359 from BPSO (Bhutan), NLDC (India) 52 and NEERLDC under 28
3	DME Factory Feeder	132kV	Tripping	02-02-2022	15:29:00 PM	02-02-2022	19:50:00 PM	4	21	0	86A & 86B OPTD	86A & 86B OPTD	transient fault	-	Charged from BPSO instruction verbally
4	DME Factory Feeder	132kV	Tripping	03-02-2022	21:32:00 PM	03-02-2022	21:37:00 PM	0	5	0	-	-	transient fault	-	Charged from BPSO instruction verbally
5	15 MVA, TR-I (9KV)	132/33kV	Tripping	05-02-2022	09:22:00AM	05-02-2022	01:17:00AM	0	15	0	50.51 OC, SEF	50.51 OC, SEF	transient fault	-	-
6	15 MVA, TR-I (9KV)	132/33kV	Tripping	05-02-2022	09:22:00AM	05-02-2022	01:18:00AM	0	16	0	86A & 86B OPTD	86A & 86B OPTD	transient fault	-	-
7	33kV Amara Feeder	33kV	Tripping	05-02-2022	02:22:00AM	05-02-2022	04:13:00AM	1	19	0	-	-	transient fault	-	-
8	15 MVA, TR-I (9KV)	132/33kV	Tripping	05-02-2022	02:26:00AM	05-02-2022	03:54:00AM	0	8	0	-	OC & EF	transient fault	-	-
9	15 MVA, TR-I (9KV)	132/33kV	Tripping	05-02-2022	02:26:00AM	05-02-2022	03:56:00AM	0	10	0	86A & 86B OPTD	OC & EF	transient fault	-	-
10	33kV Amara Feeder	33kV	Tripping	05-02-2022	02:26:00AM	05-02-2022	03:56:00AM	1	30	0	-	OC & EF	transient fault	-	-
11	33kV Amara Feeder	33kV	Tripping	05-02-2022	02:58:00AM	05-02-2022	10:20:00AM	0	20	0	-	OC & EF	transient fault	-	-
12	15 MVA, TR-I (9KV)	132/33kV	Tripping	05-02-2022	10:58:00AM	05-02-2022	10:38:00AM	0	10	0	-	-	transient fault	-	-
13	15 MVA, TR-I (9KV)	132/33kV	Tripping	05-02-2022	10:28:00AM	05-02-2022	10:40:00AM	0	12	0	-	-	transient fault	-	-
14	33kV Amara Feeder	33kV	Tripping	05-02-2022	10:28:00AM	05-02-2022	11:05:00AM	0	37	0	-	-	transient fault	-	-
15	DME Factory Feeder	132kV	Tripping	08-02-2022	23:39	02-06-2022	20:02	8	23	0	86A & 86B OPTD	-	transient fault	-	Charged the feeder with a charging code 1228 from BPSO. Feeder kept shutdown as per BPSO instruction
16	Rangji Feeder	132kV	Tripping	21-02-2022	14:22	02-06-2022	14:44	0	22	-17.12	86A & 86B OPTD	OC & EF	transient fault	-	Charged the feeder with a charging code 1233(BPSO), 2154(NLDC), 1447(NEERLDC). Feeder kept shutdown.
17	15 MVA, TR-I (9KV)	132/33kV	Tripping	21-02-2022	14:22	02-06-2022	14:48	0	26	0.03	-	OC & EF	transient fault	-	-
18	Rangji Feeder	132kV	Tripping	25-02-2022	19:01	25-02-2022	19:23	0	22	-0.27	86A & 86B OPTD	OC & EF	transient fault	-	Charged the feeder with a charging code 1256(BPSO), 2644(NLDC), 1780(NEERLDC).

Division		SMD DIOHANG														
Substation		132/33kV Coching Substation														
Month		Feb-22														
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage		MW before Outage (MW)	Protection Relay Operd	Tripping Details	Type/Cause of Fault	Reason for Shutdown	Remarks	
				Date	Time	Date	Time	(Hrs)	(Min)							Protection Relay Operd
7	132kV Khikhar-Coching Feeder	132 kV	Tripping	05-02-2022	12:29 hrs	05-02-2022	12:58 hrs	0	29	-11.530	Distance Relay (P142)	Distance Relay (P142) operated on Zone 1 trip. Recorded fault values: Scaled phase-BC. Tripped phase-ABC. fault duration-49.97 ms, relay trip time-79.79ms, fault location-33.33 km, IA-39.085A, IB-487.4AJC, 556.3A, VAN-78.12 kV/VBN-39.16kV/VCN-37.25 kV	informed to BPSO, and charged as per their instruction	-	-	
8	132 kV Khikhar-Coching Feeder	133 kV	Tripping	05-02-2022	14:11 hrs	07-02-2022	19:07 hrs	28	56	-9.910	Distance Relay (P142) and Backup Relay (P14D)	Distance Relay (P142) operated on Zone 1 trip. Recorded fault values: Scaled phase-BN. Tripped phase-B. fault duration-49.97 ms, relay trip time-79.85ms, fault location-28.89 km, IA-25.45A, IB-605.6A, IC-43.16A, VAN-74.44 kV, VBN-14.95kV, VCN-77.39 kV. Backup Relay (P14D): Started phase-BN, OC started P-1, EF 1, ms [N]-1, I2-25.01A, IB-595.5 A, IO-44.80 A, VAB-84.78KV, VBC-82.07 KV, VCA-133.0 KV, IN-581.1 A, VAN-74.22kV, VBN-14.53 kV, VCN-77.48 kV, VN-58.54 kV.	Conductor snapped in between location KK-28 & KK-29 and its between Location no KK-30 & KK-31	Test charge was done from khikhar substation but line could not stand and line was kept shut down as per the instruction from BPSO.	-	-

Division		SMD DIOHANG													
Substation		132/33kV Phomchok Substation													
Month		Feb-22													
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage		MW before Outage (MW)	Protection Relay Operd	Tripping Details	Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)						
1	132/33kV Transformer-I (10MVA)	132kV	Transient fault	05-02-2022	01:56	05-02-2022	02:00	4	0	0.14	86A and 86B	(DPNLPDOCI) Trip value, L1: 6A, L2: 65.5A, L3: 65.4 A, L4: 0.00 A	Over current and Earth fault	Unknown	Charged
2	132/33kV Transformer-II (10MVA)	132kV	Transient fault	05-02-2022	19:27	05-02-2022	19:40	13	0	0.63	86A and 86B	(DPNLPDOCI) Trip value, L1: 311.8A, L2: 349.5A, L3: 367.6A, L4: 0.00 A	Over current	Unknown	Charged



Transmission System Performance Report 2022

1. 400/220/132/33kV Jigmeling Substation													
Sl. No.	Date of Tripping	Time of Outage/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MW before Outage (MW)	Name of feeder	Name of Substation/lines Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outages	Remarks
j) 66kV Above													
1	08.02.2022	14:35 hrs	08.02.2022	15:37 hrs	1	-26.09	400kV Alipexduar line 1	Alipexduar SS	DTT	7SA52 & 7SA611			
2	08.02.2022	16:59 hrs				-25.6	400kV Alipexduar line 1	Alipexduar SS	DTT	7SA52 & 7SA612			
3	16.02.2022	20:31 hrs	16.02.2022	21:08 hrs	0	73.45	400kV Alipexduar line 2	Alipexduar SS	DTT	7SA52 & 7SA613			
4	17.06.2022	13:00 hrs				59.47	400kV Alipexduar line 2	Alipexduar SS	DTT trip on L123	7SA52 & 7SA614			
NO TRIPPING													
4. 132/33kV Tintibi Substation													
j) 66kV & Above													
1	05-02-2022	15:18	05-02-2022	15:52	0	24.77	132kV Tingtibi-Nanglam fdr Line	132kV Tingtibi-nanglam Line	Temporary fault	Distance protection relay-Start phase-BCN,Trip Phase:ABC,Zone-1,Fault Location:31.62Km	31.62kM	Temporary	
2	06-02-2022	06:49	07-02-2022	19:08	0	19.08	132kV Tingtibi-Nanglam fdr Line	132kV Tingtibi-nanglam Line	Conductor snapped at TN-63&64	Distance protection relay-Start phase-AN,Trip Phase:ABC,Zone-1,Fault Location:11.45Km	11.45	Line fault	



Transmission System Performance Report 2022

March 2022

Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration of Outage		MW before Outage (MW)	Protection Relay Operd	Tripping Details	Type/Cause of Fault	Reason for Shutdown	Weather Condition during the Outage	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)			Fault Details (As recorded by relay)				
132kV Feeders																
1	Cothing	132	Tripped	24-03-2022	14:50 hrs	24-03-2022	14:51 hrs		8	12.156	88	Relay Trip 80.27ms Fault clearance: 55.15ms IA 23.89A IB 14.80A IC 28.156A VAN 75.43kV VBN 78.41kV VCN 78.47kV Fault record Broken conductor	Transient Fault	NA	Clear	Tripped on O/C and E/F (Transient Fault)
District:		SMD/DEOTHRANG														
Substation:		132/33/11kV Naaglar Substation														
Month:		Mar-22														
132kV Feeders																
1	SNVA Transformer-I 132/22/11kV	132kV	Tripping	14-03-2022	07:25 hrs	14-03-2022	07:30 hrs	0	5	0.61	Non directional IDMT PROTN Relay operated	Non dir O/C relay-50A & tripping relay 86 operated	Tripped on feeder fault	-	Clear	Tripped due to fault on 13kV Wanning feeder
2	SNVA Transformer-II 132/22/11kV	132kV	Tripping	14-03-2022	07:25 hrs	14-03-2022	07:27 hrs	0	2	0.43	Non directional IDMT PROTN Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped on feeder fault	-	Heavy Rainfall	Tripped due to fault on 13kV Wanning feeder
3	Naaglar-Deothang	132kV	Tripping	24-03-2022	12:40 hrs	24-03-2022	12:48 hrs	0	8	21.7	MCOMPT14DB	Distinction: O/C & E/F Relay: Tripped 0 N - Start 0 CN, O/C start I-1, E/F1 start IN1-12, wp IN1-2, VAB-112.2kV, VBC-128.3kV, VCA-109.4kV, VAN-74.4kV, VBN-76.25kV, VCN-63.66kV, IA-123.6A, IB-121.4A, IC-538.8A, ID-Derived-444.9A, IN measured-44.5A & tripping relay 86 operated at 100ms end	Tripped on fault	-	Cloudy & Windy	Informed to BPSO, Thangka & cleared the feeder as per their instruction.
District:		SMD/DEOTHRANG														
Substation:		132/33/11kV Deothang Substation														
Month:		Mar-22														
132kV Feeders																
1	Deothang-Naaglar line	132kV	Tripped	24.03.2022	12:40	24.03.2022	12:48	0	8	32.888	O/C and E/F at Naaglar end	NI	Grid fal	NA	Windy	At our end the breaker condition was in normal
2	Deothang-Montanga line	132kV	Tripped	24.03.2022	12:40	24.03.2022	12:45	0	6	50.88	O/C at Montanga end	NI	Grid fal	NA	Windy	At our end the breaker condition was in normal



Transmission System Performance Report 2022

Division:		SMD DEOIBANG														
Substation:		122.33kV Nganglam Substation														
Month:		Mar-22														
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration of Outage (Min)	MW before Outage (MW)	Protection Relay Outd	Tripping Details (As recorded by relay)	Type/Cause of Fault	Reason for Shutdown	Weather Condition	Remarks	
				Date	Time	Date	Time									(Hrs)
12kV																
1	Nganglam-Tagthi	15kV	Tripping	14-08-2022	5:04	14-08-2022	12:38	7	34	Micon relay P442	IA -27.51A, IB -722.3A, IC -521.77A Fault Location 129m Zone 3 VAN - 76.48V VBN - 42.23kV VCN 78.71kV Fault duration 190 Jans Relay Trip time 0s	Over Current Dis-Integrate Protection at Tagthi Substation		Sunny	Supply restored after coordination to Tagthi end as per clearing code 1107 issued by Malama Karma Chodon, BPSO.	
2	Nganglam-Nitanga	15kV		28-01-2022	15:49	-	-	-	-					Clear	Line Test chapter as per the BPSO Clearing code 1162 issued by Malama Karma Chodon.	
Division:		SMD DEOIBANG														
Substation:		132.33kV Moxang Substation														
Month:		Mar-22														
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration of Outage (Min)	MW before Outage (MW)	Protection Relay Outd	Tripping Details (As recorded by relay)	Type/Cause of Fault	Reason for Shutdown	Weather Condition	Remarks	
				Date	Time	Date	Time									(Hrs)
1	Drooping Feeder	15kV	Tripping	24-03-2022	12:40	24-03-2022	12:45	0	4			OC, 86 A & B operated		Sunny	the feeder was changed after obtaining the verbal instruction from BPSO	
2	Rangin Feeder	15kV	Tripping	24-03-2022	13:09:50 am	24-03-2022	14:11:00 pm	1	2			OC, 86 A & B operated		Normal	Changed the feeder with a clearing code 1146 from BPSO (Sharma, NLDCC/Ardu) 1783 and NRELDC (Jukka) 5581	
3	15 MVA, IB, (HV)	132.33kV	Tripping	25-03-2022	17:08:30 PM	25-03-2022	17:10:00 PM	0	2	86A & 86B OP1D	OC, 86 A & B operated, REF protection trip, 50% bypass REF 615 protection trip.	transient fault		Normal	Changed from BPSO instruction verbally.	
4	15 MVA, IB, (HV)	132.33kV	Tripping	26-03-2022	0:20	26-03-2022	0:31	0	2	OC, 86A & 86B OP1D	over current and earth fault relay operated.	transient fault		Rainy	Changed from BPSO instruction verbally.	
5	15 MVA, IB, (HV)	132.33kV	Tripping	29-03-2022	03:50AM	29-03-2022	04:10AM	0	6	86A & 86B OP1D	OC, 86B	transient fault		Rainy	Transformer changed after verbal clearance from BPSO.	
Division:		SMD DEOIBANG														
Substation:		132.33kV Corling Substation														
Month:		Mar-22														
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration of Outage (Min)	MW before Outage (MW)	Protection Relay Outd	Tripping Details (As recorded by relay)	Type/Cause of Fault	Reason for Shutdown	Weather Condition	Remarks	
				Date	Time	Date	Time									(Hrs)
5	132 kV, 10 MVA Transformer-1	132.33 kV	Tripping	07-08-2022	22:07 hrs	07-08-2022	22:19hrs	0	12	0.989	Differential Relay (86A3) and 86 A & 86B	Starred Phase BC, Trip 3 phase BC, DM protection Star, DM protection bus trip, Resulted EF seen REF-1V, Restricted EF Trip REF-2V, Fault type Internal, System frequency 50.06, Fault duration 75.00ms, CB operated Time 65.00 ms, Relay Trip time 5.00 ms, IA-1 magnitude 5.215A, IB-1 magnitude 230.9 A, IC-1 Magnitude 226.9 A, IA-2 magnitude 0.00 A, IB-2 magnitude 0.00 A, IC-2 magnitude 432.6 mA, IA-3 magnitude 20.75 A, IB-3 magnitude 15.29 A, IC-3 magnitude 7.642 A, IA HV magnitude 5.219 A, IB HV magnitude 230.8 A, IC HV magnitude 226.9 A, IA-LV magnitude 20.75 IB-LV magnitude 15.29, IC-LV magnitude 7.642 A, IA-LV magnitude 131.2 A, IB-LV magnitude 5.793 A, IN-LV record mag 256.0 A, VAN magnitude 0.00 V, VBN 0.00 V, VCN 0.00V, VV magnitude 130.5 kV, V1 magnitude 0.00V, V2 magnitude 0.00 V, V3V detected mag 0.00 V, V4B magnitude 0.00 V, V5C magnitude 0.00 V, V6A magnitude 0.00 V, IA diff 0.009PU, IB diff 5.219 PU, IC diff 5.265 PU, IA bias 0.118 PU, IB bias 2.863 PU, IC bias 2.632 PU, REF LV REL DTR 166.3 A.	Transient fault		Clear	Test Change was done start
Division:		SMD DEOIBANG														
Substation:		122.33kV Phuntsho Gang Substation														
Month:		Mar-22														
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration of Outage (Min)	MW before Outage (MW)	Protection Relay Outd	Tripping Details (As recorded by relay)	Type/Cause of Fault	Reason for Shutdown	Weather Condition	Remarks	
				Date	Time	Date	Time									(Hrs)
1	122.33kV Transformer-II (10MVA)	152kV	Transient fault	01-03-2022	07:59	01-03-2022	08:01	2	0.97	86A and 86B	(DPHLPDOCI) Trip value: L1-4.05A, L2-348.2A, L3-1441.15A, L4-0.00 A	over current and Earth fault	Unknown	Sunny	Changed	
6	122.33kV Transformer-II (10MVA)	152kV	Transient fault	01-03-2022	08:42	01-03-2022	08:44	2	0.71	86A and 86B	(DPHLPDOCI) Trip value: L1-232.2A, L2-112.65A, L3-119.55A, L4-0.00 A	Over current	Unknown	Sunny	Changed	
9	122.33kV Transformer-I (10MVA)	152kV	Transient fault	13-03-2022	09:50	13-03-2022	09:55	5	0.17	86A and 86B	(DPHLPDOCI) Trip value: L1-158.1A, L2-126.1A, L3-159.3A, L4-0.00 A	over current and Earth fault	Unknown	Clear	Changed	
24	122.33kV Transformer-II (10MVA)	152kV	Transient fault	24-03-2022	19:47	24-03-2022	19:50	3	1.20	86A and 86B	(DPHLPDOCI) Trip value: L1-171.15A, L2-179.7A, L3-351A, L4-0.00A	Over current	Unknown	Clear	Changed	
27	122.33kV Transformer-II (10MVA)	152kV	Transient fault	24-03-2022	19:57	24-03-2022	20:00	3	1.2	86A and 86B	(DPHLPDOCI) Trip value: L1-165.5A, L2-173.7A, L3-339.75A, L4-0.00A	Over current	Unknown	Clear	Changed	
34	122.33kV Transformer-I (10MVA)	152kV	Transient fault	25-03-2022	14:57	25-03-2022	14:59	2	0.26	86A and 86B	(DPHLPDOCI) Trip value: L1-59.4A, L2-135.15A, L3-104.1A, L4-0.00 A	over current and Earth fault	Unknown	Rainy	Changed	
17	122.33kV Transformer-I (10MVA)	152kV	Transient fault	25-03-2022	15:29	25-03-2022	15:32	3	0.22	86A and 86B	(DPHLPDOCI) Trip value: L1-128.85A, L2-127.65A, L3-131.35A, L4-0.00 A	over current and Earth fault	Unknown	Rainy	Changed	
40	122.33kV Transformer-II (10MVA)	152kV	Transient fault	25-03-2022	16:55	25-03-2022	16:58	4	0.26	86A and 86B	(DPHLPDOCI) Trip value: L1-171.15A, L2-179.7A, L3-351A, L4-0.00A	Over current	Unknown	Rainy	Changed	
43	122.33kV Transformer-II (10MVA)	152kV	Transient fault	25-03-2022	19:27	25-03-2022	19:30	3	0.69	86A and 86B	(DPHLPDOCI) Trip value: L1-166.75A, L2-175.35A, L3-344.4A, L4-0.00A	Over current	Unknown	Rainy	Changed	
46	122.33kV Transformer-II (10MVA)	152kV	Transient fault	26-03-2022	07:39	26-03-2022	07:42	3	0.57	86A and 86B	(DPHLPDOCI) Trip value: L1-146.75A, L2-175.35A, L3-344.4A, L4-0.00A	Earth Fault	Unknown	Sunny	Changed	



Transmission System Performance Report 2022

L. 400/220/132/33kV Jigmeing Substation													
Sl. No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MW before Outage (MW)	Name of feeder	Name of the Substation/lines Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outages	Remarks
j) 66kV & Above													
1	08.02.2022	14:35 hrs	08.02.2022	15:37 hrs	1	-26.09	400kV Alipurdhar line 1	Alipurdhar SS	DIT	7SA52 & 7SA611			
2	08.02.2022	16:59 hrs				-25.6	400kV Alipurdhar line 1	Alipurdhar SS	DIT	7SA52 & 7SA612			
3	16.02.2022	20:31 hrs	16.02.2022	21:08 hrs	0	73.45	400kV Alipurdhar line 2	Alipurdhar SS	DIT	7SA52 & 7SA613			
4	17.06.2022	13:00 hrs				59.47	400kV Alipurdhar line 2	Alipurdhar SS	DIT trip on L123	7SA52 & 7SA614			
4. 132/33kV Tintshi Substation													
j) 66kV & Above													
1	05-02-2022	15:18	05-02-2022	15:52	0	24.77	132kV Tingtshi-Nanglam line	132kV Tingtshi-Nanglam Line	Temporary fault	Distance protection relay:Start phase-BCN,Trip Phase-ABC,Zone-1,Fault Location:31.62Km	31.62KM	Temporary	
2	06-02-2022	06:49	07-02-2022	19:08	0	19.08	132kV Tingtshi-Nanglam line	132kV Tingtshi-Nanglam Line	Conductor snaped at TN-63&64	Distance protection relay:Start phase-AN,Trip Phase-ABC,Zone-1,Fault Location:11.45Km	11.45	Line fault	

April 2022

Division:		SMD DEOTHSANG												
Substation:		132/33/11kV Kikkhar Substation												
Month:		Apr 22												
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown Tripping Time		Normalization Time		Duration of Outage (Hrs)	MW before Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time			Protection Relay Oper	Fault Details (As recorded by relay)			
132kV Feeders														
1	132kV Kanchu 1C	132kV	Tripped	19-04-2022	21:08hrs	19-04-2022	22:24hrs	1	10.564			Tripped	Grid fall from Motaga end	Supply resumed and restored from Puntsholing end
2	132kV Kanchu 1C	132kV	Tripped	22-04-2022	22:29hrs	22-04-2022	22:36hrs		13.384			Tripped	Grid fall from Rangaj end	Grid fall from Rangaj end
3	132kV Kanchu 1C	132kV	Tripped	22-04-2022	00:13 hrs	22-04-2022	00:16hrs		13.32			Tripped	Tripped from Tingtshi-Nanglam	Tripped from Tingtshi-Nanglam end
4	132kV Cothing	132kV	Tripped	29-04-2022	13:37hrs	29-04-2022	13:57hrs		2.412			Tripped	Grid fall	Grid fall from Cothing, Rangaj end



Transmission System Performance Report 2022

Division:		SMD DEOTHANG													
Substation:		132/33/11kV Kanglung Substation													
Month:		Apr 22													
Sl No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Durations (Hrs)	MW before Outage (MW)	Protection Relay Oper	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Fault Details (As recorded by relay)				
132kV															
1	SMVA Transformer II	132kV	Tripping	15/04/2022	4:02	15/04/2022	4:15	0	0.465	tripping relay 85 operated	NA	Earth Fault	NA	transformer tripped due to heavy feeder fault on 11kV Khawing feeder	
2	Corling Incomer	132kV	Eastern Grid failed	19/04/2022	21:08	19/04/2022	22:24	1	4.984	NA	NA	NA	NA	Wield Eastern Power Grid failed and later restored by extending the power from Indian Grid via Rangja-Moranga	
3	Corling Incomer	132kV	Grid fail from Rangja	22/04/2022	22:20	22/04/2022	22:44	0	-8.604	Tripping relay 86 operated	NA	NA	NA	Grid fail from Rangja	
4	Corling Incomer	132kV	Tripping	22/04/2022	22:45	23/04/2022	0:36	1	-8.604	NA	NA	Breaker charging problem at Corling after the Grid fail from Rangja	NA	Supply fed from Phantshokhang as the supply due to breaker problem at Corling is after the grid fail from Rangja	
5	Kanglung - Phantshokhang	132kV	Tripping	22/04/2022	22:45	23/04/2022	0:19	1	7.218	NA	NA	Breaker charging problem at Corling after the Grid fail from Rangja	NA	Supply fed from Phantshokhang as the supply due to breaker problem at Corling is after the grid fail from Rangja	
6	Kanglung - Phantshokhang	132kV	Grid fail from Rangja	29/04/2022	11:58	29/04/2022	11:58	0	-5.562	NA	NA	NA	NA	Grid fail from Rangja	
7	Kanglung - Phantshokhang	132kV	Grid fail from Rangja	29/04/2022	12:02	29/04/2022	12:04	0	-5.76	NA	NA	NA	NA	Grid fail from Rangja	
8	Kanglung - Phantshokhang	132kV	Grid fail from Rangja	29/04/2022	14:49	29/04/2022	14:53	0	-10.656	NA	NA	NA	NA	Grid fail	
9	Kanglung - Phantshokhang	132kV	Grid fail from Rangja	29/04/2022	18:47	29/04/2022	19:29	0	12.358	NA	NA	NA	NA	Grid fail	

Division:		SMD DEOTHANG													
Substation:		132/33/11kV Nangkar Substation													
Month:		Apr 22													
Sl No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Durations (Hrs)	MW before Outage (MW)	Protection Relay Oper	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Fault Details (As recorded by relay)				
132kV Feeders															
1	SMVA Transformer-I 132/22/11kV	132kV	Tripping	03-04-2022	01:05 hrs	03-04-2022	01:10 hrs	0	0.33	Non directional IDMT PROTN Relay operated	Non dir O/C relay 50A & tripping relay 85 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Yarang feeder	
2	SMVA Transformer-II 132/22/11kV	132kV	Tripping	03-04-2022	01:05 hrs	03-04-2022	01:11 hrs	0	0.17	Non directional IDMT PROTN Relay operated	O/C relay 50A & tripping relay 85 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Yarang feeder	
3	Nangkar Deothang Line	132kV	Tripping	04-04-2022	16:26 hrs	04-04-2022	16:34 hrs	0	44.5	MCC05P14DB	Directional -O/C & E/F Relay: Tripped O/N Start O/C N/O/C start I-1, E/F1 start INI>12, trip INI>2 VAB=132.2kV, VBC=126.8kV, VCA=106.3kV, VAN=74.24kV, VBN=76.20kV, VCN=61.32kV, [A=183.8A, B=187A, C=681.9A, IN measured=525.6A, IN measured=525.1A & tripping relay 85 operated at our end	Tripped on fault	-	Informed to BPSO, Thimphu & charged the feeder as per their instruction.	
4	SMVA Transformer-I 132/22/11kV	132kV	Tripping	05-04-2022	15:28 hrs	05-04-2022	15:30 hrs	0	0.423	Non directional IDMT PROTN Relay operated	O/C relay 50A & tripping relay 85 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Yarang feeder	
5	SMVA Transformer-II 132/22/11kV	132kV	Tripping	05-04-2022	15:28 hrs	05-04-2022	15:31 hrs	0	0.26	Non directional IDMT PROTN Relay operated	O/C relay 50A & tripping relay 85 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Yarang feeder	
6	SMVA Transformer-I 132/22/11kV	132kV	Tripping	08-04-2022	19:54 hrs	08-04-2022	19:57 hrs	0	0.58	Non directional IDMT PROTN Relay operated	O/C relay 50A & tripping relay 85 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Tesbar feeder	
7	SMVA Transformer-II 132/22/11kV	132kV	Tripping	08-04-2022	19:54 hrs	08-04-2022	20:15 hrs	0	0.58	Non directional IDMT PROTN Relay operated	O/C relay 50A & tripping relay 85 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Tesbar feeder	
8	SMVA Transformer-I 132/22/11kV	132kV	Tripping	09-04-2022	21:40 hrs	09-04-2022	21:47 hrs	0	0.522	Non directional IDMT PROTN Relay operated	O/C relay 50A, 50C & tripping relay 86 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Yarang feeder	
10	Nangkar-Nyanglung Line	132kV	Tripping	09-04-2022	21:44 hrs	09-04-2022	21:50 hrs	0	-10.65	MCC05P14DB	Directional -O/C & E/F Relay: Start O ABC, O/C start I-1, VAB=132.2kV, VBC=138.8kV, VCA=47.05kV, VAN=29.98kV, VBN=14.34kV, VCN=28.37kV, [A=866.3A, B=1999A, C=1371A, IN measured=756.5A, IN measured=759.1A & tripping relay 86 operated at our end	Tripped on fault	-	Informed to BPSO, Thimphu & charged the feeder as per their instruction.	
9	SMVA Transformer-I 132/22/11kV	132kV	Tripping	09-04-2022	21:50 hrs	09-04-2022	21:59 hrs	0	0.522	Non directional IDMT PROTN Relay operated	O/C relay 50A & tripping relay 85 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Wawang feeder	
11	SMVA Transformer-I 132/22/11kV	132kV	Tripping	09-04-2022	22:13 hrs	09-04-2022	22:16 hrs	0	0.522	Non directional IDMT PROTN Relay operated	O/C relay 50A & tripping relay 85 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Tesbar feeder	
12	SMVA Transformer-I 132/22/11kV	132kV	Tripping	10-04-2022	09:29 hrs	10-04-2022	09:31 hrs	0	0.338	Non directional IDMT PROTN Relay operated	O/C relay 50A & tripping relay 85 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Tesbar feedes	
13	SMVA Transformer-I 132/22/11kV	132kV	Tripping	15-04-2022	09:28 hrs	15-04-2022	09:29 hrs	0	0.31	Non directional IDMT PROTN Relay operated	O/C relay 50A & tripping relay 85 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Nawang feeder	
14	SMVA Transformer-II 132/22/11kV	132kV	Tripping	15-04-2022	09:28 hrs	15-04-2022	09:34 hrs	0	0.14	Non directional IDMT PROTN Relay operated	O/C relay 50A & tripping relay 85 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Nawang feeder	
15	SMVA Transformer-I 132/22/11kV	132kV	Tripping	15-04-2022	01:05 hrs	15-04-2022	01:06 hrs	0	0.23	Non directional IDMT PROTN Relay operated	O/C relay 50A & tripping relay 85 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Nawang feeder	



Transmission System Performance Report 2022

16	5MVA Transformer-II 132/22/11kV	112kV	Tripping	15-04-2022	01:05 hrs	15-04-2022	01:13 hrs	0	0.09	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Namang feeder
17	5MVA Transformer-I 132/22/11kV	112kV	Tripping	15-04-2022	03:55 hrs	15-04-2022	03:56 hrs	0	0.248	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Tshar feeder
18	5MVA Transformer-II 132/22/11kV	112kV	Tripping	15-04-2022	03:55 hrs	15-04-2022	03:57 hrs	0	0.099	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Tshar feeder
19	Nanglun-Npanglun Line	112kV	Tripping	15-04-2022	03:55 hrs	15-04-2022	04:01 hrs	0	7.99	MCOMP14DB & MCOMP442	<i>Directional-O/C & E/F Relay</i> : Start @ CN, O/C start D-1, E/F1 start IN1-12, VAB=133.1kV, VBC=65.19kV, VCA=79.58kV, VAN=73.79kV, VBN=74.31kV, VCN=23.79kV, IA=90.25A, IB=132.6A, IC=1.501kA, IN Derived=1.235kA, IN measured=1.280kA & tripping relay 86 operated at our end <i>Distance Relay</i> : Start @ CN, trip @ ABC, start element distance, TOC start, 50TF TOR trip, AR lock out short, 49.91Hz, fault duration 70.12ms, relay trip time 82.6ms, fault location 16.62KM towards Npanglun, Zone -1, fault resistance 7.85Ω & trip relay 86 operated at our end, IA=90.15A, IB=130.5A, IC=1.513kA, VCN=73.70kV, VBN=74.29kV, VCN=25.79kV	Tripped on fault	-	Informed to BPSO, Thimphu & charged the feeder as per their instruction.
20	5MVA Transformer-I 132/22/11kV	112kV	Tripping	15-04-2022	03:59 hrs	15-04-2022	04:01 hrs	0	0.248	Non directional IDMT PROTIN Relay operated	O/C relay-50A,50C & tripping relay 86 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Wanang feeder
21	5MVA Transformer-II 132/22/11kV	112kV	Tripping	15-04-2022	03:59 hrs	15-04-2022	04:10 hrs	0	0.099	Non directional IDMT PROTIN Relay operated	O/C relay-50A,50C & tripping relay 86 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Wanang feeder
22	Nanglun-Dooftang Line	112kV	Tripping	16-04-2022	21:08 hrs	16-04-2022	21:11 hrs	0	8.4	MCOMP14DB & MCOMP442	<i>Directional-O/C & E/F Relay</i> : Start @ N, Trip @ N, E/F1 start IN1-12, trip IN1=2, VAB=12.41kV, VBC=73.33kV, VCA=75.99kV, VAN=13.29kV, VBN=11.69kV, VCN=6.317kV, IA=491.7A, IB=491.1A, IC=63.85A, IN Derived=668.9A, IN measured=669.2A & tripping relay 86 operated at our end <i>Distance Relay</i> : Start @ ABCN, start element distance, TOC start, trip starts on, fault alarm on, fault duration 200.7ms, relay trip time -0.000s, fault location 35.96KM towards Dooftang, Zone -3, fault resistance 3.225Ω & trip relay 86 operated at our end, IA=496.6A, IB=532.8A, IC=59.08A, VAN=13.29kV, VBN=20.11kV, VCN=55.31kV	Tripped on fault	-	At the same Grid failed from Rangpa, informed to BPSO, Thimphu & CB closed from our end as per the instruction from their end. Supply received at 22:24 hrs via Motonga Phuntshochang-Kanglung Line.
23	Main Grid	112kV	Tripping	22-04-2022	22:23 hrs	22-04-2022	22:29 hrs	0	1.54	-	-	Tripped on fault	-	Grid failed from Nganglun Substation and Motonga Substation
24	Nanglun-Npanglun Line	112kV	Tripping	23-04-2022	09:12 hrs	23-04-2022	09:19 hrs	0	-0.39	MCOMP14DB	<i>Directional-O/C & E/F Relay</i> : Start @ DCN, O/C start D-1, E/F1 start IN1=12, VAB=88.24kV, VBC=27.28kV, VCA=85.01kV, VAN=70.74kV, VBN=19.41kV, VCN=22.18kV, IA=45.91A, IB=1.614kA, IC=1.398kA, IN Derived=1.327kA, IN measured=1.326kA & tripping relay 86 operated at our end <i>Distance Relay</i> : Start @ ACN trip @ ABC start element distance, TOC start, Distance trip Z1, AR lockout short, fault duration=71.50ms, relay trip time -80.37ms, fault location 17.52KM towards Kanchi, fault resistance=93.35Ω & trip relay 86 operated at our end, IA=1.417kA, IB=120.5A, IC=3485kA, VAN=16.42kV, VBN=67.55kV, VCN=14.09kV	Tripped on fault	-	Informed to BPSO, Thimphu & at 09:16 hrs received supply via Motonga, Dooftang & charged Nanglun-Npanglun feeder from our end as per the instruction from BPSO
25	Kanchi-Nanglun line	112kV	Tripping	27-04-2022	18:55 hrs	27-04-2022	18:57 hrs	0	-24.33	MCOMP442	<i>Distance Relay</i> : Start @ ACN trip @ ABC start element distance, TOC start, Distance trip Z1, AR lockout short, fault duration=71.50ms, relay trip time -80.37ms, fault location 17.52KM towards Kanchi, fault resistance=93.35Ω & trip relay 86 operated at our end, IA=1.417kA, IB=120.5A, IC=3485kA, VAN=16.42kV, VBN=67.55kV, VCN=14.09kV	Tripped on fault	-	Informed to BPSO & charged the feeder as per the instruction from their end.
26	5MVA Transformer-I 132/22/11kV	112kV	Tripping	27-04-2022	19:20 hrs	27-04-2022	19:23 hrs	0	0.86	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped due to fault on 33kV Tshar feeder
27	5MVA Transformer-I 132/22/11kV	112kV	Tripping	27-04-2022	22:16 hrs	27-04-2022	22:21 hrs	0	0.387	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped while test charging 33kV Tshar feeder
28	5MVA Transformer-II 132/22/11kV	112kV	Tripping	27-04-2022	22:16 hrs	28-04-2022	18:23 hrs	20	0.150	Non directional IDMT PROTIN Relay operated	O/C relay-50C & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped while test charging 33kV Tshar feeder. While charging LV side, continuous spark was observed from Y @ main Isolator to CB, and there after kept under short down and charged after rectifying the problem.
29	Nanglun-Dooftang	112kV	Tripping	29-04-2022	11:37 hrs	29-04-2022	12:01 hrs	0	35.60	MCOMP14DB	<i>Directional-O/C & E/F Relay</i> : Start @ BCN, O/C start D-1, E/F1 start IN1=12, VAB=88.24kV, VBC=27.28kV, VCA=85.01kV, VAN=70.74kV, VBN=19.41kV, VCN=22.18kV, IA=45.91A, IB=1.614kA, IC=1.398kA, IN Derived=1.327kA, IN measured=1.326kA & tripping relay 86 operated at our end	Tripped on fault	-	CB operated at our end at the instant of Grid failure. Informed to BPSO.
30	Main Grid (Rangpa Grid)	112kV	Tripping	29-04-2022	12:04 hrs	29-04-2022	12:04 hrs	0	35.60	-	-	Tripped on fault	-	Supply failed from Motonga Substation.
31	Nanglun Dooftang line	112kV	Tripping	29-04-2022	17:55 hrs	29-04-2022	18:04 hrs	0	19.00	MCOMP442	<i>Distance Relay</i> : Start @ ACN trip @ ABC start element distance, TOC start, Distance trip Z1, AR lockout short, fault duration=55.02ms, relay trip time -80.02ms, fault location 17.66KM towards Dooftang, fault resistance=991.96Ω & trip relay 86 operated at our end, IA=1.299kA, IB=1.309kA, IC=1.322kA, VAN=10.3kV, VBN=9.699kV, VCN=9.417kV	Tripped on fault	-	Informed to BPSO, Thimphu and closed the CB as per the instruction from their end.
32	5MVA Transformer-I 132/22/11kV	112kV	Tripping	29-04-2022	18:14 hrs	29-04-2022	18:15 hrs	0	0.71	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Namang feeder
33	5MVA Transformer-II 132/22/11kV	112kV	Tripping	29-04-2022	18:14 hrs	29-04-2022	21:17 hrs	3	0.5	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Namang feeder. Charged after weather subsided to normal.
34	5MVA Transformer-II 132/22/11kV	112kV	Tripping	29-04-2022	18:59 hrs	29-04-2022	18:59 hrs	0	0.71	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Yarang feeder.



Transmission System Performance Report 2022

Division:		SMD DEOTHANG													
Substation:		132/33/11kV Deothang Substation													
Month:		Apr-22													
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Dzang (Hrs)	MW before Outage (MW)	Protection Relay Oper	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Fault Details (As recorded by relay)				
1	Deothang-Montaga line	132kV	Tripping	04/04/2022	16:26	04/04/2022	16:29	0	42.732	O/C at Montaga end	Nil		NA	NA	Grid fail and at our end Breaker was in normal condition
2	Deothang-Naughor line	132kV	Tripping	04/04/2022	16:26	04/04/2022	16:34	0	44.236	O/C and E/F at Naughor end	Nil		NA	NA	Grid fail and at our end Breaker was in normal condition
3	Deothang-Naughor line	132kV	Tripping	09/04/2022	21:43	09/04/2022	21:46	0	47.016	Decisional relay opt.	JA-794.2A, IB-1.116KA, IC-1.5KA & N-238.14		Unknown	NA	Feeder trip due to earth fault after getting information from BPSO, just charge were done and stand successfully.
Division:		SMD DEOTHANG													
Substation:		132/33/11kV Nganglam Substation													
Month:		Apr-22													
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Dzang (Hrs)	MW before Outage (MW)	Protection Relay Oper	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Fault Details (As recorded by relay)				
132kV															
1	Nganglam-Teaghi	132kV	Tripping	02/04/2022	23:19	02/04/2022	23:19	0	-12.75	Micon relay P442	IA- 117.1A IB- 1.232KA IC- 82.92A IN- 1.422KA Zone 1 Fault location 30.74km Fault resistance 5.620 Ohms Fault duration 85.17ms Relay Trip Time 80.21ms A.R lock out		Earth Fault/Transient Fault		Line restored after coordination to BPSO and Teaghi substation
2	Nganglam-Teaghi	132kV	Tripping	09/04/2022	21:44	09/04/2022	21:50	0	-11.89		Grid Fail		Grid Fail		
3	Naughor-Nganglam	132kV	Tripping	15/04/2022	03:55	15/04/2022	04:01	0	-9.52		Grid Fail		Grid Fail		
4	Nganglam-Teaghi	132kV	Tripping	22/04/2022	08:01	22/04/2022	15:08	7	-19.11				Shutdown	Shutdown evoked by Mr. Dawa Tshering, JE for changing Reserver breakers dis-ardators at location TN4 196 TNS 195 & TN5 204 with side SWITCH OFF code# 0540 issued by Madam Kritam, BPSO and issued PTW No# 1794 to Mr. Dawa Tshering, TLMU Line incharge Nganglam. Line successful after returning of PTW by Mr. Dawa Tshering to Control Room with side SWITCH ON code# 1051 issued by Madam Binin Rai, BPSO.	
5	Nganglam-Teaghi	132kV	Tripping	22/04/2022	22:03	22/04/2022	22:13	0	-26.53	Micon relay P442	IA- 150.6A IB- 1.859KA IC- 1.782KA IN- 1.604KA Zone 1 Fault location 26.79km		Shutdown		Normalized after coordination to BPSO and adjacent Substation
6	Nganglam-Teaghi	132kV	Tripping	22/04/2022	22:23	22/04/2022	22:25	0	-26.53	Micon relay P442	IA- 16.54A IB- 18.25A IC- 18.24A VAN- 83.22kV VBN- 83.26kV VCN- 82.08kV A.R lockout		Over Voltage		
7	Naughor-Nganglam	132kV	Tripping	22/04/2022	22:22	22/04/2022	22:29	0	9.82	Micon relay P442	IA- 23.36A IB- 24.71A IC- 23.41A VAN- 83.33kV VBN- 83.59kV VCN- 82.08kV A.R lockout		Over Voltage		
8	Nganglam-Montaga	132kV	Tripping	22/04/2022	22:22	22/04/2022	09:45	11	19.1	REL650 REF615 opted	Line-1 Pre Fault Mag- 0.1A pre Fault Angle- -93.24deg Fault Mag- 0.51A Fault Angle- -37.48deg Line 2 pre Fault Mag- 0.07A Pre Fault Angle- -24.03deg Fault Mag- 0.11A Fault- Mag- 41.37deg		Over Voltage		Line normalized after getting clear confirmation from BPSO with side closing code# 1058 issued by Madam Tshering Choden and coordination to Montaga end.
9	Nganglam-Teaghi	132kV	Tripping	21/04/2022	08:12	23/04/2022	08:19	0	-10.89		Grid Fail		Grid Fail		
10	Nganglam-Teaghi	132kV	Tripping	27/04/2022	17:11	27/04/2022	17:27	0	-21.45	Protection Relay Oper	IA- 1.6308KA IB- 283.2A, IC- 1.4869KA Fault location 4.881km Zone 1		Over Voltage		
11	Nganglam-Montaga	132kV	Tripping	27/04/2022	17:11	27/04/2022	17:15	0	23.94	REL650 REF615 opted	NA		Earth Fault/Over current		



Transmission System Performance Report 2022

Division: SMD DEOTHANG		Substation: 132/33kV Motanga Substation		Month: Apr 22											
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Durations (Hrs)	MW before Outage (MW)	Protection Relay Operd	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Fault Details (As recorded by relay)				
1	Deothang Feeder	132kV	Tripping	04-04-2022	16:26	04-04-2022	16:29	0	-43.05	OC, 86 A & B operated	OC, 86 A & B operated	transient fault	-	The feeder was charged after obtaining the verbal instruction from BPSO	
2	Rangis Feeder	132kV	Tripping	04-04-2022	16:26	04-04-2022	17:11	0	31.65	OC, 86 A & B operated	OC, 86 A & B operated	transient fault	-	Charged the feeder with a charging code 194 from BPSO (Bhutan), NLDC (India) 221 and NERLDC (India) 176	
3	15 MVA, TR-1 (HV)	132/33kV	Tripping	04-04-2022	16:30	04-04-2022	16:33	0	0.12	86A & 86B OPD	OC, 86 A & B operated SEF protection operated over current and earth fault relay operated.	transient fault	-	Charged from BPSO instruction verbally	
4	Deothang Feeder	132kV	Tripping	09-04-2022	14:28	09-04-2022	14:31	0	-39.7	OC, 86A & 86B OPD	OC, 86A & 86B OPD	transient fault	-	Charged from BPSO instruction verbally	
7	Rangis Feeder	132kV	Tripping	09-04-2022	14:28	09-04-2022	15:33	1	28.82	OC, 86A & 86B OPD	over current and earth fault relay operated.	-	-	Charged the feeder with a charging code 1434 from BPSO (Bhutan), NLDC (India) 644 and NERLDC (India) 419. Lost time taken for obtaining closing code from BPSO, hence more outage.	
8	15 MVA, TR (HV)	132/33kV	Tripping	15-04-2022	16:37	15-04-2022	17:03	0	0.29	OC, 86A OPD	SEF protection operated	transient fault	-	Charged the transformer with closing code, 1012 from BPSO	
9	Deothang Feeder	132kV	Tripping	19-04-2022	21:08	19-04-2022	21:14	0	-7.13	OC & Ef, 86 A&B	Zone-1 trip on R & Y phase, 39A&B operated	transient fault	-	Deothang feeder was charged with BPSO verbal instruction.	
11	Rangis Feeder	132kV	Tripping	19-04-2022	21:06	19-04-2022	22:15	1	-16	OC, 86A & 86B operated	OC, 86A & 86B operated	-	-	At 21:06 hrs whole system grid failed, tripped Rangis & Deothang feeder on same time. Deothang feeder charged at 21:18 hrs, at 21:40 hrs Rangis feeder charge but did not hold due to faulty E's indication at relay panel. Earth switch was rectified & CB spring charged. 21:58 hrs - test charged Rangis feeder but still did not hold. Hand tripped deothang & phantichhong feeder to try for sectional charging, and charged Rangis feeder at 22:15 hrs from one relay with instruction from BPSO	
12	15 MVA, TR (HV)	132/33kV	Tripping	19-04-2022	22:15	19-04-2022	22:17	0	0.16	OC and E/F	OC, E/F and 86A relay operated	transient fault	-	Charged with BPSO verbal instruction.	
13	15 MVA, TR (HV)	132/33kV	Tripping	20-04-2022	7:56	20-04-2022	8:01	0	0.22	OC and E/F, 86 A operated	OC and E/F, 86 A operated	transient fault	-	Charged the transformer with clearance received from BPSO verbally.	
14	15 MVA, TR (HV)	132/33kV	Tripping	20-04-2022	9:01	20-04-2022	9:05	0	0.08	OC and E/F, 86 A operated	OC and E/F, 86 A operated	transient fault	-	Charged the transformer with clearance received from BPSO verbally.	
15	15 MVA, TR (HV)	132/33kV	Tripping	20-04-2022	16:18	20-04-2022	16:26	0	0.12	OC and E/F, 86 A operated	OC and E/F, 86 A operated	transient fault	-	Charged the transformer with clearance received from BPSO verbally.	
16	Nganglam	132kV	Tripping	22-04-2022	22:03	22-04-2022	22:10	0	-18.87	86 A & B operated	86 A & B operated	transient fault	-	The feeder was charged after obtaining closing code, 1052, from BPSO	
17	Rangis Feeder	132kV	Tripping	22-04-2022	22:23	22-04-2022	22:54	0	17.61	OC, 86 A & B operated	OC, 86 A & B operated	transient fault	-	Charged the feeder with a charging code 1054 from BPSO (Bhutan), NLDC (India) 1181 and NERLDC (India) 1684	
18	Nganglam Feeder	132kV	Tripping	22-04-2022	22:23	23-04-2022	7:45	9	-18.87	OC, 86 A & B operated	OC, 86 A & B operated	transient fault	-	The breaker was kept open from few hrs as per instruction from BPSO. Later it was charged at 7:45 am on next day with closing code, 1056 by selecting choker, BPSO.	
19	Deothang Feeder	132kV	Tripping	27-04-2022	17:11	27-04-2022	17:13	0	-23.16	OC, E/F, 86 A & B operated	OC, E/F, 86 A & B operated	transient fault	-	charged by verbal instruction from BPSO	
20	Nganglam Feeder	132kV	Tripping	27-04-2022	17:11	27-04-2022	17:15	0	-23.13	OC, E/F, 86 A & B operated	OC, E/F, 86 A & B operated	transient fault	-	charged by verbal instruction from BPSO	
21	Deothang Feeder	132kV	Tripping	28-04-2022	11:56	28-04-2022	11:58	0	-54.19	OC, E/F, 86 A & B operated	OC, E/F, 86 A & B operated	transient fault	-	Verbal instruction obtained from Tshering Choden, BPSO & charged feeder.	
22	Rangis Feeder	132kV	Tripping	29-04-2022	11:36	29-04-2022	12:05	0	24.24	OC, E/F, 86 A & B operated	OC, E/F, 86 A & B operated	transient fault	-	At 11:36 hrs grid failed. Deothang, Rangis/Nganglam feeder tripped due to oc & E/F As 11:43 hrs Nganglam CB test charged but did not hold. At 11:49 hrs test charged Rangis feeder as per closing code, 1110 (BPSO), 2187 (NLDC) & 1506 (NERLDC) but did not hold. At 11:50 hrs Nganglam CB cleared from motanga and grid restored. At 11:58 hrs Deothang & Rangis charged, at 12:05 hrs Rangis charged & at 12:27 hrs Nganglam closed.	
23	Nganglam Feeder	132kV	Tripping	29-04-2022	11:36	29-04-2022	12:27	0	-12.35	OC, E/F, 86 A & B operated	OC, E/F, 86 A & B operated	transient fault	-	closing code from BPSO was 1112 given by kurma shun	
24	Phantichhong feeder	132kV	Tripping	29-04-2022	14:52	29-04-2022	15:02	0	-8.82	OC, E/F, 86 A & B operated	OC, E/F, 86 A & B operated	transient fault	-	closing code from BPSO was 1116 given by Pema Lhamo.	

Division: SMD DEOTHANG		Substation: 132/33kV Coching Substation		Month: Apr 22											
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Durations (Hrs)	MW before Outage (MW)	Protection Relay Operd	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Fault Details (As recorded by relay)				
1	132 kV Khikhar Feeder and Kanglung Feeder	132 kV	Grid fail	19-04-2022	21:06 hrs	19-04-2022	22:32 hrs	1	-8.250	NI	NI	Grid fail	-	At 21:06 hrs there was no incoming supply from khikhar substation due to grid and Coching substation was blocked but no breaker tripping loss occurred at Coching substation.	
2	132 kV Khikhar-Coching Line	132 kV	Tripping	22-04-2022	22:23 hrs	22-04-2022	22:37 hrs	0	-10.730	Distance Relay (P442)	Distance Relay (P442) operated on Over Voltage, Recorded fault values : Started phase-ABC, Tripped phase-ABC, Over Voltage start V > 1.2, Over Voltage Trip V>2, fault duration-2.496s, relay trip time-79.63 ms, IA-13.41A, IB-15.96A, IC-14.67A, VAN-83.13 kV, VBN-84.18 kV, VCN-82.47 kV. Fault in Zone-None	Over Voltage	-	132 kV Khikhar-Coching Line and 132 kV Coching-Kanglung Line tripped at 22:23 hrs on over Voltage. Both the line was charged as per the instruction from BPSO at 22:37 hrs and 22:43 hrs respectively.	
3	132 kV Coching-Kanglung Line	132 kV	Tripping	22-04-2022	22:23 hrs	22-04-2022	22:43 hrs	0	9.950	Distance Relay (P442)	Distance Relay (P442) operated on Over Voltage, Recorded fault values : Started phase-ABC, Tripped phase-ABC, Over Voltage start V > 1.2, Over Voltage Trip V>2, fault duration-2.496s, relay trip time-79.63 ms, IA-13.41A, IB-15.96A, IC-14.67A, VAN-83.13 kV, VBN-84.18 kV, VCN-82.47 kV. Fault in Zone-None	Over Voltage	-		
4	132 kV Khikhar-Coching Line	132 kV	Tripping	22-04-2022	22:47 hrs	23-04-2022	0:23 hrs	1	-10.730	Distance Relay (P442)	Distance Relay (P442) operated on Over Voltage, Recorded fault values : Started phase-ABC, Tripped phase-ABC, Over Voltage start V > 1.2, Over Voltage Trip V>2, VT fail Alarm, V>1 Alarm, Frequency 50.02, fault duration-133.2 ms, relay trip time-79.95 ms, IA-12.85A, IB-14.76A, IC-12.73A, VAN-79.48kV, VBN-127.4 kV, VCN-80.30 kV. Fault in Zone-None	Over Voltage	-	132 kV Khikhar-Coching Line tripped at 22:47 hrs on over Voltage The line was charged as per the instruction from BPSO at 00:23 hrs on 23/04/2022	
5	132 kV Khikhar Feeder and Kanglung Feeder	132 kV	Grid fail	29-04-2022	11:36 hrs	29-04-2022	11:57 hrs	0	-3.510	NI	NI	Grid fail	-	At 11:36 hrs there was no incoming supply from khikhar substation due to grid and Coching substation was blocked but no breaker tripping loss occurred at Coching substation.	
6	132 kV Khikhar Feeder and Kanglung Feeder	132 kV	Grid fail	29-04-2022	12:02 hrs	29-04-2022	12:06 hrs	0	-3.920	NI	NI	Grid fail	-	At 12:02 hrs there was no incoming supply from khikhar substation due to grid and Coching substation was blocked but no breaker tripping loss occurred at Coching substation.	
7	132 kV Khikhar Feeder and Kanglung Feeder	132 kV	Tripped from Khikhar SS	29-04-2022	14:49 hrs	29-04-2022	14:53 hrs	0	-11.590	NI	NI	Tripped at Khikhar Substation	-	At 14:49 hrs 132 kV Khikhar-Coching line was tripped at Khikhar Substation and Coching substation was blocked but no breaker tripping loss occurred at Coching substation.	



Transmission System Performance Report 2022

Division: SMD DEOTHANG		Substation: 132/33kV Phuntshokhang Substation		Month: Apr 22											
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Durations (Hrs)	MW before Outage (MW)	Protection Relay Oper	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Fault Details (As recorded by relay)				
1	132/33kV Transformer-II (10MVA)	112kV	Transient fault	02-04-2022	05:56	02-04-2022	05:59	0.27	86A and 86B	(DPHLPDOCI) Trip value: L1: 90.6A, L2: 39.6A, L3: 84A, Lx: 0A.	Over current and Earth fault	Unknown	Charged		
2	132/33kV Transformer-II (10MVA)	112kV	Transient fault	04-04-2022	18:00	04-04-2022	18:07	0.64	86A and 86B	(DPHLPDOCI) Trip value: L1: 151.05A, L2: 29.65A, L3: 144.9A, Lx: 0A.	Over current	Unknown	Charged		
3	132/33kV Transformer-II (10MVA)	112kV	Transient fault	06-04-2022	02:42	06-04-2022	02:46	0.21	86A and 86B	(DPHLPDOCI) Trip value: L1: 93.25A, L2: 119.7A, L3: 105.2A, Lx: 0A.	Over current and Earth fault	Unknown	Charged		
4	132/33kV Transformer-II (10MVA)	112kV	Transient fault	09-04-2022	16:46	09-04-2022	16:50	0.58	86A and 86B	(DPHLPDOCI) Trip value: L1: 40.35A, L2: 81.75A, L3: 55.95A, Lx: 0A.	Earth fault	Unknown	Charged		
5	132/33kV Transformer-II (10MVA)	112kV	Transient fault	10-04-2022	17:20	10-04-2022	17:24	0.46	86A and 86B	(DPHLPDOCI) Trip value: L1: 40.35A, L2: 81.75A, L3: 55.95A, Lx: 0A.	Earth fault	Unknown	Charged		
6	132/33kV Transformer-II (10MVA)	112kV	Trip on fault	12-04-2022	09:50	12-04-2022	09:53	0.44	86A and 86B	(DPHLPDOCI) Trip value: L1: 191.4A, L2: 4.2A, L3: 195A, Lx: 0A.	Over current and Earth fault	Unknown	Charged		
7	132/33kV Transformer-II (10MVA)	112kV	Trip on fault	13-04-2022	12:56	13-04-2022	12:58	0.53	86A and 86B	(DPHLPDOCI) Trip value: L1: 53.25A, L2: 10.2A, L3: 55.8A, Lx: 0A.	Over current	Unknown	Charged		
8	132/33kV Transformer-II (10MVA)	112kV	Trip on fault	13-04-2022	14:25	13-04-2022	14:28	0.20	86A and 86B	(DPHLPDOCI) Trip value: L1: 53.7A, L2: 33.6A, L3: 73.05A, Lx: 0A.	Earth fault	Unknown	Charged		
9	132/33kV Transformer-II (10MVA)	112kV	Trip on fault	14-04-2022	18:28	14-04-2022	18:30	0.62	86A and 86B	(DPHLPDOCI) Trip value: L1: 181.5A, L2: 184.5A, L3: 366.15A, Lx: 0A.	Earth fault	Unknown	Charged		
10	132/33kV Transformer-II (10MVA)	112kV	Trip on fault	15-04-2022	01:35	15-04-2022	01:38	0.36	86A and 86B	(DPHLPDOCI) Trip value: L1: 45.6A, L2: 86.4A, L3: 40.8A, Lx: 0A.	Over current	Unknown	Charged		
11	132/33kV Transformer-II (10MVA)	112kV	Trip on fault	15-04-2022	03:01	15-04-2022	03:09	0.06	86A and 86B	(DPHLPDOCI) Trip value: L1: 170.85A, L2: 171.3A, L3: 342.15A, Lx: 0A.	Over current	Unknown	Charged		
12	132/33kV Transformer-II (10MVA)	112kV	Trip on fault	15-04-2022	03:35	15-04-2022	03:39	0.06	86A and 86B	(DPHLPDOCI) Trip value: L1: 180.6A, L2: 181.2A, L3: 361.8A, Lx: 0A.	Over current	Unknown	Charged		
13	132/33kV Transformer-II (10MVA)	112kV	Transient fault	16-04-2022	01:59	16-04-2022	02:06	0.19	86A and 86B	(DPHLPDOCI) Trip value: L1: 132.45A, L2: 130.95A, L3: 1.35A, Lx: 0A.	Earth fault	Unknown	Charged		
14	132/33kV Transformer-II (10MVA)	112kV	Trip on fault	16-04-2022	18:25	16-04-2022	18:30	0.86	86A and 86B	(DPHLPDOCI) Trip value: L1: 161.25A, L2: 170.4A, L3: 331.8A, Lx: 0A.	Over current	Unknown	Charged		
15	132/33kV Transformer-II (10MVA)	112kV	Trip on fault	17-04-2022	21:40	17-04-2022	21:44	0.64	86A and 86B	(DPHLPDOCI) Trip value: L1: 164.7A, L2: 169.2A, L3: 334.05A, Lx: 0A.	Over current	Unknown	Charged		
16	132/33kV Transformer-II (10MVA)	112kV	Trip on fault	19-04-2022	14:53	19-04-2022	14:57	0.54	86A and 86B	(DPHLPDOCI) Trip value: L1: 45.6A, L2: 86.4A, L3: 40.8A, Lx: 0A.	Over current	Unknown	Charged		
17	132/33kV Transformer-II (10MVA)	112kV	Trip on fault	19-04-2022	15:27	19-04-2022	15:29	0.08	86A and 86B	(DPHLPDOCI) Trip value: L1: 47.85A, L2: 58.35A, L3: 18A, Lx: 0A.	Over current	Unknown	Charged		
18	112kV Motang	112kV	Grid Fail	22-04-2022	22:25	22-04-2022	23:33	1	7.43	Nil	Nil	Nil	Grid Fail	Grid Fail at 22:25, however at first breaker are all normal but at 22:30 breaker got open and after receiving information from BPSO, just changed the line, but line didn't withstand and spring got discharged and due to abnormal weather took time to reset. After resetting and receiving information from BPSO, line changed at 23:33.	
19	112kV Kamthang	112kV	Grid Fail	22-04-2022	22:25	22-04-2022	23:37	1	8.19	Nil	Nil	Nil	Grid Fail	Grid Fail at 22:25, however at first breaker are all normal but at 22:33 breaker got open and after receiving information from BPSO, line changed at 23:37.	
20	132/33kV Transformer-II (10MVA)	112kV	Trip on fault	24-04-2022	13:33	24-04-2022	13:36	0.56	86A and 86B	(DPHLPDOCI) Trip value: L1: 263.7A, L2: 127.8A, L3: 139.9A, Lx: 0A.	Over current	Unknown	Charged		
21	132/33kV Transformer-II (10MVA)	112kV	Trip on fault	24-04-2022	13:39	24-04-2022	13:42	0.56	86A and 86B	(DPHLPDOCI) Trip value: L1: 52.2A, L2: 57.45A, L3: 24.6A, Lx: 0A.	Over current	Unknown	Charged		
22	132/33kV Transformer-II (10MVA)	112kV	Transient fault	28-04-2022	15:01	28-04-2022	15:03	0.57	86A and 86B	(DPHLPDOCI) Trip value: L1: 52.2A, L2: 57.45A, L3: 24.6A, Lx: 0A.	Earth fault	Unknown	Charged		
23	112kV Kamthang	112kV	Trip on fault	29-04-2022	19:03	29-04-2022	19:22	7.56	89A and 89B	(DPHLPDOCI) Zone-1OPTD (R,Y,B Phase trip) Trip value: L1: 1733.01A, L2: 1766.32A, L3: 1628.6A, Lx: 0A.	Zone-1OPTD (R,Y,B Phase trip)	Unknown	Zone-1OPTD (R,Y,B Phase trip) at the distance of 14.45 Km and line charge at 19:22 with clearing code#1123 issued by main: Phun Lhamo (BPSO)		
24	132/33kV Transformer-II (10MVA)	112kV	Trip on fault	29-04-2022	19:12	29-04-2022	19:14	1.07	86A and 86B	(DPHLPDOCI) Trip value: L1: 74.25A, L2: 113.55A, L3: 60.15A, Lx: 0A.	Over current	Unknown	Charged		
25	132/33kV Transformer-II (10MVA)	112kV	Trip on fault	29-04-2022	19:22	29-04-2022	19:23	1.07	86A and 86B	(DPHLPDOCI) Trip value: L1: 154.2A, L2: 288.75A, L3: 154.55A, Lx: 0A.	Over current	Unknown	Charged		
26	132/33kV Transformer-I (10MVA)	112kV	Trip on fault	29-04-2022	19:16	29-04-2022	19:18	0.44	50 and 86OPTD	(DPHLPDOCI) Trip value: L1: 97.8A, L2: 101.7A, L3: 52.05A, Lx: 0A.	Over current	Unknown	Charged		



Transmission System Performance Report 2022

Sl. No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MW before Outage (MW)	Name of feeder	Name of the Substation/lines Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outages	Remarks
1. 400/220/132/33kV Jigmeling Substation													
0 66kV Above													
1	04.04.2022	05:33 hrs	04.04.2022	06:03 hrs	0	171.62 MW	400kV Interim circuit 2	Alipurdza Substation	L1 to Ground and Over current, IA=1.18KA	main 1 = Rph pick up		Transient Fault	
2	06.04.2022	05:20 hrs	06.04.2022	05:57 hrs	0	100.17 MW	400kV Interim circuit 2	Alipurdza Substation	L1- Ground Zone 1, Over current, IA=0.90KA	Main 2 and Main 1 pick up, Rphase to ground	Fault Distance Main 2(dist)=190.7km, Main 1(dist)=B190.5km	Transient Fault	
3	10.04.2022	00:30 hrs	10.04.2022	00:55 hrs	0	125.08 MW	400kV Interim circuit 2	Alipurdza Substation	Fault Loop(Rph to Ground)	Main 1 optd ,Fault Loop(Rph to Ground) Zone 1 optd, Main 2 optd ,Fault Loop(Rph to Ground) , Zone 1 optd.	Main 1 Fault dist(161.7 km), Main 2 Fault dist(161.5)		
4	14.04.2022	19:28 hrs				52.36	400kV Interim circuit 2	Alipurdza Substation	YBph wip	Main 1 & Main2 optd.(YBph trip), zone 1 and Zone2 optd. (YB ph trip)			
5	15.04.2022	02:15 hrs	15.04.2022	3:00	0	83.4	400kV Interim circuit 1	Alipurdza Substation	Rph-G	Main-1; Ground Pickup - Main-2; RYBph pick up and Fault loop R-G.	Main 2 Fault dist 136.2 km	as per following Charging code: NLDC Bhutan: 1005, NLI	
6	22.04.2022	23:15 hrs	22.04.2022	0:00	0	116.95	400kV MHEP Line-4	Jigmeling SS and Alipurdza SS	Bph-G Fault current main -1&2 Fault current 5.9kA	Main 1 optd ,Fault Loop(Bph to Ground) , Zone 1 optd, Main 2 optd ,Fault Loop(Bph to Ground) , Zone 1 optd.	Fault dist(16.1 km) Fault dist(13.2),		Line auto reclosed
7	27.04.2022	17:11hrs	28.04.2022	18:58 hrs	25	101.5MW	500MVA ICT	Jigmeling SS	R&B phase operated	Differential relay operated			
8	22.04.2022	21:14 hrs	22.04.2022	21:22 hrs	0	57.520	220kV Tairang	Dhajej SS	L3-G	Main 2; Fault Loop Bph to Ground, Z1 Trip, Ib=1.91kA	Fault dist 39.5km.	Transient	Line restored as per BPSO closing code: 1052, Tsherin Choden
9	22.04.2022	21:14 hrs	22.04.2022	21:26 hrs	0	-13.81	220kV Dagap	Dagapela S	L2, L3-G	Main 1 optd, Z1 Trip, Fault Loop(L2, L3 and ground).	Fault dist(36 km) Fault current Ia=0.20ka Ib=0.91ka Ic=2.50ka	Transient	
10	27.04.2022	17:11hrs	27.04.2022			-34.09	400/220kV ICT	Jigmeling SS					
2. 220/66/33kV Dhajej Substation													
0 66kV and above													
1	22.04.2022	21:14hrs	22.04.2022	21:22hrs		56.52	Tairang-Jigmeling	Dhajej Substation	Main 1- Ia=0.13kA, Ib=0.76kA, Ic=1.47kA with distance 15.5KM Main 2- Ia=160.28A, Ib=834.37A, Ic=1455.55A, Ib=1012.99A	Distance relay Main 1&2(21.1&21.2)	Line segment	Tripped	Feeder restored after confirmation.
2	22.04.2022	23:30hrs	22.04.2022	23:43hrs		54.1	Tairang-Jime	Dhajej S	Main 2- Ia=220.5	Distance relay Main 2(21.2)	Line segment	Tripped	Feeder restored after confirmation.



Transmission System Performance Report 2022

4. 132/33kV Tingbi Substation														
i) 66kV & Above														
Sl. No.	Date	Time	Start Date	End Date	Duration (hrs)	Severity	Location	Equipment	Fault Description	Distance (km)	Impact	Remarks	Category	Notes
1	02-04-2022	23:19	02-04-2022	23:29	0	13.130	132kV Tingbi	132kV Tr	Temporary Fault	Distance Relay:Start Phase:BN,Trip Phase:ABC,Fault zone-1 trip,Fault location:28.86KM	28.86km		Temporary	
2	09-04-2022	21:19	09-04-2022	21:55	0	12.600	132kV Tingbi	132kV Tr	Temporary Fault	Distance Relay:Start Phase:ABC,Trip Phase:ABC,Fault zone-1 trip,Fault location:54.28KM	54.28km		Temporary	
3	09-04-2022	22:38	09-04-2022	22:47	0	3.670	132kV Tingbi	132kV Tr	Temporary Fault	Distance Relay:Start Phase:AN,Trip Phase:ABC,Fault zone-1 trip,Fault location:30.75KM	30.75km		Temporary	
4	09-04-2022	23:00	09-04-2022	23:07	0	9.720	132kV Tingbi	132kV Tr	Temporary Fault	Distance Relay:Start Phase:ABCN,Trip Phase:ABC,Fault zone-1 trip,Fault location:12.80KM	12.80km		Temporary	
5	10-04-2022	17:11	11-04-2022	17:17	0	12.890	132kV Tingbi	132kV Tr	Temporary Fault	Distance Relay:Start Phase:AB,Trip Phase:ABC,Fault zone-1 trip,Fault location:31.53KM	31.53km		Temporary	
6	15-04-2022	05:54	15-04-2022	04:05	0	-1.220	132kV Tingbi	132kV Tr	Temporary Fault	Distance Relay:Start Phase:CN,Trip Phase:ABC,Fault zone-1 trip,Fault location:51.83KM	51.83km		Temporary	
7	16-04-2022	01:55	16-04-2022	02:10	0	4.900	132kV Tingbi	132kV Tr	Temporary Fault	Distance Relay:Start Phase:AB,Trip Phase:ABC,Fault zone-1 trip,Fault location:33.33KM	33.33km		Temporary	
8	16-04-2022	02:10	20-04-2022	19:55	87	4.900	132kV Tingbi	132kV Tr	Conductor Snapped	Distance Relay:Start Phase:CN,Trip Phase:ABC,Fault zone-1 trip,Fault location:28.68KM	28.68km		Temporary	Conductor Snapped/Broken
9	22-04-2022	22:03	22-04-2022	22:13	0	26.300	132kV Tingbi	132kV Tr	Temporary Fault	Distance Relay:Start Phase:BCN,Trip Phase:ABC,Fault zone-1 trip,Fault location:33.82KM	33.82km		Temporary	
10	22-04-2022	22:23	22-04-2022	22:25	0	26.340	132kV Tingbi	132kV Tr	Temporary Fault	Distance Relay:Start Phase:AN,Trip Phase:ABC,Fault zone-1 trip,Fault location:54.02KM	54.02km		Temporary	
11	23-04-2022	00:01	23-04-2022	00:20	0	0.474	132kV Tingbi	132kV Tr	Temporary Fault	Distance Relay:Start Phase:BCN,Trip Phase:ABC,Fault zone-1 trip,Fault location:46.8KM	46.8km		Temporary	
12	25-04-2022	08:21	25-04-2022	08:39	0	9.720	132kV Tingbi	132kV Tr	Temporary Fault	Distance Relay:Start element:ao,Trip elts:NO,Fault zone:None,Over voltage tripped	0		Temporary	
13	25-04-2022	08:21	25-04-2022	08:41	0	0.310	3MVA transformer	3MVA tr	Over current	Over current (251A)	0		Temporary	
14	25-04-2022	08:21	25-04-2022	08:42	0	0.240	3MVA transformer	3MVA tr	Over current	Over current (251C)	0		Temporary	
15	27-04-2022	17:11 Hrs	27-04-2022	17:29	0	38.800	132kV Tingbi	132kV Tr	Temporary Fault	Distance Relay:Start Phase:ACN,Trip Phase:ABC,Fault zone-1 trip,Fault location:40.37KM	40.37km		Temporary	
5. 132/33kV Yumoo Substation														
i) 66kV & Above														
1	22-04-2022	0.919444444	22-04-2022	0.92291667	0	-10.7	132kV Tingbi	132kV Yumoo Ss	Nil					Supply was failed from Tingbi ss
2	23-04-2022	0.009027778	23-04-2022	0.01388889	0	-11.8	132kV Tingbi	132kV Yumoo Ss	Nil					Supply was failed from Tingbi ss
3	25-04-2022	0.349305556	25-04-2022	0.35763889	0	-11.4	132kV Tingbi	132kV Yumoo Ss	Nil					Supply was failed from Tingbi ss
6. 220/33kV Dagapela Substation														
i) 66kV & Above														
1	15-03-2022	06:15hrs	15-03-2022	19:08hrs	13	8.17	220/33kV 10	Dagapela	Earth fault	1 Trip Relay optd buch trip, SEF optd	Dagapela Substation		Transient Fault	Cable termination got burned and f



Transmission System Performance Report 2022

May 2022

Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration of Outage (Hrs)	MW before Outage (MW)	Tripping Details		Type-Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time			Protection Relay Optd	Fault Details (As recorded by relay)			
132kV Feeders														
14	132KV Karchu	132KV	Tripped	18-05-2022	09:47hrs	18-05-2022	09:51hrs	0	21.852	Nil	Nil	Tripped	Grid Fal	Grid fal from Motenga, Rangra And Tangla
Division: SMD-DEOTHIANG Substation: 132/33/11kV Kanglung Substation Month: May-22														
138kV														
5	Cochang	132	Grid fal	18-05-2022	21:48	18-05-2022	21:50	0	17.964	NA	NA	Grid Fal	NA	Grid fal
Division: SMD-DEOTHIANG Substation: 132/33/11kV Nanglung Substation Month: May-22														
132kV Feeders														
1	Nanglung-Nanglung Line	132kV	Tripping	07-05-2022	16:25 hrs	07-05-2022	16:37 hrs	0	3.24	MCOMP14DB	<i>Directional-O/C & P/F Relay:</i> Tripped O.N. Start O.N. E/F1 start IN1>1, trip IN3>1, I4d=106.9kV, VBC=100.8kV, VCA=170.27kV, VAN=45.57kV, VBN=73.38kV, VCN=46.38kV, IA=423.3A, IB=14.10A, IC=147.9A, INdev=4326.9A, IN max=4325.9A, & tripping relay 85 operated at our end.	Tripped on fault	-	Informed to BPSO, Thimphu & changed the feeder as per their instruction.
5	Main Grid	132kV	Tripping	18-05-2022	21:48 hrs	18-05-2022	21:51 hrs	0	-	-	-	Grid fal	-	Supply failed from Nanglung SS & Motenga SS.
Division: SMD-DEOTHIANG Substation: 132/33/11kV Deochang Substation Month: May-22														
33kV														
1	Gondur line	33kV	Tripping	30-04-2022	18:15	01-05-2022	11:25	17	0.156	O/C	IA=808.2A, IB=801.6A, IC=2.304A, IN=284.0A	Conductor snapped at Virapang	NA	Line charged as per line maintenance team & line got stand
14	Motenga Line	132kV	Tripping	18-05-2022	21:48	18-05-2022	21:45	0	32.256	E/F and O/C at Motenga end	Nil	E/F and O/C	NA	Grid fal and at our end breaker was in normal



Transmission System Performance Report 2022

Division: SMD DEOTHANG															
Substation: 132/33kV Nganglam Substation															
Month: May 22															
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration (Hrs)	MW before Outage (MW)	Protection Relay Optd	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Fault Details (As recorded by relay)				
132kV															
1	Nganglam-Tangthi	132kV	Tripping	07.05.2022	16:25	07.05.2022	16:34	0	-27.48	Micom relay#P442	[A-1.113kA, IB-138.9A, IC-1.113kA, VAN-27.97kV, VIN-76.97kV, VCN-28.14kV] Fault location: 104.8km Relay Trip Time: 941.6ms Fault resistance: 1.737Ohms Trip Phase: ABC A/R		Overcurrent		Supply restored after coordination to BPSO & Tangthi end.
2	Nganglam-Motanga	132kV	Tripping	07.05.2022	16:25	07.05.2022	16:45	0	20.08	Micom relay REF659 REL615	L1 Fault Mag: 104.48A / 0.45deg L2 Fault Mag: 105.58A/125.02deg L3 Fault Mag: 95.44A / 121.61deg IN Fault Mag: 228.0A / 173.31deg		Earth Fault		Supply restored after coordination to BPSO & Motanga end.
4	Nganglam- Naangthor	132kV	Tripping	15.05.2022	20:08	15.05.2022	20:22	0	-7.13	Micom relay REF659 REL615	[A=86.51A, IB=1.273kA, IC=134.1A, IN=1.063kA, VAN=90.55kV, VBN=85.78kV, VCN=127.5kV] S6operated, Trip Phase: ABC, fault distance: Zone 2 Trip, fault location: 38.59km, fault Resistance: 5.056 ohms.		Overcurrent		Supply restored after coordination to BPSO & Naangthor end.
5	Nganglam-Motanga	132kV	Tripping	15.05.2022	20:08	15.05.2022	20:23	0	18.7	Micom relay REF659 REL615	L1-Fault mag = 9.16A / -95.05deg, L2 - Fault mag = 8.76A / -36.03deg, L3 - Fault mag = 7.67A / -158.52deg, IN - Fault mag = 45A / 153.91deg		Earth Fault		Supply restored after coordination to BPSO & Motanga end.
6	BMVA TR-II	132kV	Tripping	16.05.2022	07:52	16.05.2022	16:37	0	0.936	O/C & E/F Relay	Tripped due to 33kV DCCL feeder fault		O/C & E/F		33kV DCCL feeder CB not Operated and made hand tripped.
7	BMVA TR-II	132kV	Tripping	17.05.2022	21:19	17.05.2022	21:27	0	0.837	Micom relay#P442	B5A operated. No fault recorded.		NA		
8	Nganglam-Motanga	132kV	Tripping	18.05.2022	21:49	18.05.2022	22:34	0	29.23	Micom relay REF659 REL615	B5A operated. mag = 19A / 168.73deg, L2 - Fault mag = 13A / 41.33deg, L3 - Fault mag = 05A / 74.48deg, IN - Fault mag = 139A / 132.77deg		Earth Fault		Supply restored after coordination to BPSO & Motanga end.
9	Nganglam-DCCL	132kV	Tripping	24.05.2022	13:00	24.05.2022	13:01	0	6.97	No relay is Operated	No fault is recorded.		Under Voltage		Feeder tripped at their end due to under voltage, the supply was normalized by opening Motanga-Range line.
132kV															
Division: SMD DEOTHANG															
Substation: 132/33kV Motanga Substation															
Month: May 22															
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration (Hrs)	MW before Outage (MW)	Protection Relay Optd	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Fault Details (As recorded by relay)				
1	Range Feeder	132kV	Tripping	06-05-2022	23:25	07-05-2022	0:14	0	34.02	OC, S6 A & B operated.	OC, S6 A & B operated.		transient fault	-	Charged the feeder with a charging code 1155 from BPSO(Bhutan), NLDC(India) 489 and NERLDC(India) 1862
3	Nganglam Feeder	132kV	Tripping	07-05-2022	16:25	07-05-2022	16:42	0	20.01	OC, S6 A & B operated.	OC, S6 A & B operated.		transient fault	-	The feeder was charged after obtaining the verbal instruction from BPSO.
4	Range Feeder	132kV	Tripping	13-05-2022	12:20	13-05-2022	12:45	0	28.33	S6A & S6B OPID	OC, S6 A & B operated.		transient fault	-	Charged the feeder with a charging code 9619 from BPSO(Bhutan), NLDC(India) 601 and NERLDC(India) 1980
5	Nganglam Feeder	132kV	Tripping	15-05-2022	20:10	15-05-2022	20:24	0	-18.11	over current trip	OC, S6 A & B operated.		transient fault	-	Charged after getting verbal instruction from BPSO.
7	Deothang Feeder	132kV	Tripping	18-05-2022	21:48	18-05-2022	21:55	0	32.99	over current trip	OC, S6 A & B operated.		transient fault	-	Charged after getting verbal instruction from BPSO.
8	Range Feeder	132kV	Tripping	18-05-2022	21:48	18-05-2022	22:20	0	50.15	OC, S6A & S6B OPTD	over current and earth fault relay operated.		transient fault	-	Charged the feeder with a charging code 9619 from BPSO(Bhutan), NLDC(India) 601 and NERLDC(India) 1980
9	Nganglam Feeder	132kV	Tripping	18-05-2022	21:48	18-05-2022	22:13	0	30.13	OC, S6A & S6B OPTD	over current and earth fault relay operated.		transient fault	-	Charged after getting verbal instruction from BPSO.
132kV															
Division: SMD DEOTHANG															
Substation: 132/33kV Cothing Substation															
Month: May 22															
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration (Hrs)	MW before Outage (MW)	Protection Relay Optd	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Fault Details (As recorded by relay)				
34	132 kV Khikhar Feeder and 132 kV Rangrang feeder	132 kV	Grid fail	18.05.2022	21:48 hrs	18.05.2022	21:55 hrs	0	-19.050	NI	NI		Breaker tripped at Khikhar End		There was no 132 kV incoming supply from Khikhar due to grid fail but no breaker tripping has occurred at cothing end.



Transmission System Performance Report 2022

Division:		SMD DEOBIANG												
Substation:		132/33kV Phuntshochang Substation												
Month:		May 22												
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/ Tripping)	Shutdown/Tripping Time		Normalization Time		MW before Outage (MW)	Protective Relay Oper	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time			(Hrs)	Fault Details (As recorded by relay)			
8	132/33kV Transformer-I (10MVA)	132kV	Transient	07-05-2022	06:16	07-05-2022	06:20	0.34	50 and 56OPD	(DPHLPDOCI) Trip value; L1: 170.25A, L2: 177.45A, L3: 347.4A, Ln: 0A.	Over current	Unknown	Charged	
13	132/33kV Transformer-II (10MVA)	132kV	Transient fault	08-05-2022	02:28	08-05-2022	02:31	0.44	85A and 86B	(DPHLPDOCI) Trip value; L1: 43.05A, L2: 5.51A, L3: 99.75A, Ln: 0A.	Earth fault	Unknown	Charged	
16	132/33kV Transformer-II (10MVA)	132kV	Transient fault	08-05-2022	06:00	08-05-2022	06:11	0.07	85A and 86B	(DPHLPDOCI) Trip value; L1: 83.1A, L2: 93.75A, L3: 82.8A, Ln: 0A.	Over current	Unknown	Charged	
20	132/33kV Transformer-II (10MVA)	132kV	Tripping on fault	08-05-2022	18:44	08-05-2022	18:50	0.07	85A and 86B	(DPHLPDOCI) Trip value; L1: 103.35 A, L2: 91.65A, L3: 101.7, Ln: 0A.	Over current	Unknown	Charged	
25	132/33kV Transformer-II (10MVA)	132kV	Tripping on fault	09-05-2022	20:07	09-05-2022	20:10	0.54	85A and 86B	(DPHLPDOCI) Trip value; L1: 126.9 A, L2: 203.4A, L3: 123.4A, Ln: 0A.	Over current	Unknown	Charged	
31	132/33kV Transformer-I (10MVA)	132kV	Transient fault	11-05-22	05:23	11-05-2022	05:26	0.27	85A and 86B	(DPHLPDOCI) Trip value; L1: 309 A, L2: 360.3A, L3: 362.55A, Ln: 0A.	Over current	Unknown	Charged	
36	132/33kV Transformer-II (10MVA)	132kV	Tripping on fault	11-05-2022	12:44	11-05-2022	12:47	0.26	85A and 86B	(DPHLPDOCI) Trip value; L1: 130.65 A, L2: 258.45A, L3: 127.67A, Ln: 0A.	Over current	Unknown	Charged	
41	132/33kV Transformer-II (10MVA)	132kV	Transient fault	12-05-2022	05:59	12-05-2022	06:02	0.31	85A and 86B	Fault Value did not reflect on Relay (REF615)	Earth fault	Unknown	Charged. DR did not triggered on Relay	
45	132/33kV Transformer-II (10MVA)	132kV	Transient fault	12-05-2022	12:10	12-05-2022	12:14	0.20	85A and 86B	(DPHLPDOCI) Trip value; L1: 87.75A, L2: 1.8A, L3: 89.25A, Ln: 0A.	earth fault and Overcurrent	Unknown	Charged	
51	132/33kV Transformer-II (10MVA)	132kV	Transient fault	14-05-2022	15:20	14-05-2022	15:22	0.47	85A and 86B	(DPHLPDOCI) Trip value; L1: 54.6A, L2: 51.15A, L3: 24.75A, Ln: 0A.	Earth fault	Unknown	Charged	
54	132/33kV Transformer-II (10MVA)	132kV	Transient fault	15-05-2022	01:57	15-05-2022	02:01	0.45	85A and 86B	(DPHLPDOCI) Fault value; L1: 130.5A, L2: 3A, L3: 133.2A, Ln: 0A.	earth fault and Overcurrent	Unknown	Charged	
59	132/33kV Transformer-II (10MVA)	132kV	Transient fault	16-05-2022	04:26	16-05-2022	04:29	0.50	85A and 86B	Fault Value did not reflect on Relay (REF615)	Earth fault	Unknown	Charged	
63	132/33kV Transformer-II (10MVA)	132kV	Transient fault	17-05-2022	08:55	17-05-2022	08:58	0.62	85A and 86B	(DPHLPDOCI) Fault value; L1: 41.1A, L2: 95.15A, L3: 85.2A, Ln: 0A.	earth fault and Overcurrent	Unknown	Charged	
71	132/33kV Transformer-II (10MVA)	132kV	Transient fault	18-05-2022	16:32	18-05-2022	16:37	0.45	85A and 86B	(DPHLPDOCI) Fault value; L1: 100.65A, L2: 122.1A, L3: 63.5A, Ln: 0A.	Earth fault	Unknown	Charged	
76	Kandung (1K7LA)	132kV	Transient fault	18-05-2022	21:47	18-05-2022	22:08	15.66	85A and 86B	(OV2PFOV) Fault value; L1: 5.85A, L2: 7A, L3: 6.94A, Ln: 9.52A.	Over voltage & Under Voltage	Unknown	Coordination with BPSO and line charged after Voltage get Normalized.	
81	132/33kV Transformer-II (10MVA)	132kV	Transient fault	21-05-2022	09:03	21-05-2022	09:06	0.48	85A and 86B	(DPHLPDOCI) Fault value; L1: 125.15A, L2: 129.75A, L3: 121.05A, Ln: 0A.	Over current	Unknown	Charged	
92	132/33kV Transformer-II (10MVA)	132kV	Transient fault	23-05-2022	06:31	23-05-2022	06:33	1.03	85A and 86B	(DPHLPDOCI) Fault value; L1: 56.25A, L2: 35A, L3: 33A, Ln: 0A.	Earth fault	Unknown	Charged	
101	132/33kV Transformer-II (10MVA)	132kV	Transient fault	24-05-2022	18:50	24-05-2022	18:53	0.56	85A and 86B	Fault Value did not reflect on Relay (REF615)	Earth fault	Unknown	Charged	
122	132/33kV Transformer-II (10MVA)	132kV	Transient fault	29-05-2022	12:09	29-05-2022	12:10	0.43	85A and 86B	Fault Value did not reflect on Relay (REF615)	Earth fault	Unknown	Charged	
125	132/33kV Transformer-II (10MVA)	132kV	Transient fault	29-05-2022	19:31	29-05-2022	19:32	0.71	85A and 86B	(DPHLPDOCI) Trip value; L1: 4.2A, L2: 64.2A, L3: 60.45A, Ln: 0A.	earth fault & overcurrent	Unknown	Charged	



Transmission System Performance Report 2022

1. 400/220/132/33kV Jigmeing Substation													
Sl. No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MW before Outage (MW)	Name of feeder	Name of the Substation/lines Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outages	Remarks
i) 66kV Above													
1	20.05.2022	22:48 hrs	20.05.2022	23:03 hrs	0	82.17	400/220kV ICT	Jigmeing Substation		Directional O/C & E/F Protection Relay optd (HV)			
2	21.05.2022	19:47 hrs	21.05.2022	19:54 hrs	0	82.7	400/220kV ICT	Jigmeing Substation	Operated PRV both on HV and LV	Directional O/C & E/F trip.			
3	28-May-22	10:27 hrs	28-May-22	11:41 hrs	1	-117.81	400kV MHPA Line-4	Jigmeing and Algardur SS	DTT trip for RYB phase	Distance Relay: SIPROTECT 7SA52 & 7SA611			
4	28-May-22	11:43 hrs	28-May-22	14:26 hrs	2		400kV MHPA Line-4	Jigmeing and Algardur SS	DTT trip for RYB phase	Distance Relay: SIPROTECT 7SA52 & 7SA611			
5	29-May-22	17:24 hrs	29-May-22	18:28 hrs	1	-113.21	400kV MHPA Line-4	Jigmeing and Algardur SS	DTT trip for RYB phase	Distance Relay: SIPROTECT 7SA52 & 7SA611			
1	11.05.2022	20:33hrs	11.05.2022	20:39hrs	0	44.23	220kV Tsikang feeder	Tsikang SS	Ground fault	Main-1 Y&B TRIP, Z1/Z1B tripped, Main-2 Y&B TRIP, Z1/Z1B tripped	Fault Current Rph=0.15kA, Yph=4.99kA, Bph=4.85kA Main 1 fault dist=11.8km, Main 2 Fault Dist=11.82km		lightning & Raining
4. 132/33kV Tintibi Substation													
i) 66kV & Above													
1	07-05-2022	16:25	07-05-2022	16:34	0	28.370	132kV Tingtibi	132kV Tinti	Temporary Fault	Distance Relay:Start Phase:ACN,Trip Phase:ABC,Fault zone-1 trip,Fault location:9.99kM	9.99kM	Temporary	Closing Code:1159(BPSC)
2	15-05-2022	20:09	15-05-2022	20:15	0	28.870	132kV Tingtibi	132kV Tinti	Temporary Fault	Distance Relay:Start Phase:ABC,Trip Phase:ABC,Fault zone-1 trip,Fault location:59kM	59kM	Temporary	
3	18-05-2022	21:47	18-05-2022	21:50	0	27.720	132kV Tingtibi	132kV Tinti	Temporary Fault	Distance Relay:Start Phase:AN,Trip Phase:ABC,Fault zone-1 trip,Fault location:54.56kM	54.56kM	Temporary	
5. 132/33kV Yurmoo Substation													
i) 66kV & Above													
1	22.04.2022	0.919444444	22.04.2022	0.92291667	0	-10.7	132kV Tingtibi	132kV Yurmoo Ss		Nil	Tingtibi ss		Supply was failed from Tingtibi ss
2	23.04.2022	0.009027778	23.04.2022	0.01388889	0	-11.8	132kV Tingtibi	132kV Yurmoo Ss		Nil	Tingtibi ss		Supply was failed from Tingtibi ss
3	25.04.2022	0.349305556	25.04.2022	0.35763889	0	-11.4	132kV Tingtibi	132kV Yurmoo Ss		Nil	Tingtibi ss		Supply was failed from Tingtibi ss



Transmission System Performance Report 2022

June 2022

SMD DEOTHANG															
Substation: 132/33/11kV Kibikar Substation															
Month: Jun 22															
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration of Outage (Hrs)	MW before Outage (MW)	Protection Relay Operd	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Protection Relay Operd	Fault Details (As recorded by relay)			
132kV Feeders															
1	Yommet Karchu	132kV	Shutdown	04-06-2022	09:19 hrs	04-06-2022	12:21 hrs	3	-20.556	Nil	Nil	To connected bus transfer PT terminal	Shutdown	To connected bus transfer PT terminal	
2	Yommet Karchu	132kV	Tripped	06-06-2022	05:02 hrs	06-06-2022	05:20 hrs		-20.624	Nil	Nil	Grid fail from Rangla	Tripped	Grid fail from Rangla and Tughr end	
SMD DEOTHANG															
Substation: 132/33/11kV Kanglung Substation															
Month: Jun 22															
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration of Outage (Hrs)	MW before Outage (MW)	Protection Relay Operd	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Protection Relay Operd	Fault Details (As recorded by relay)			
132kV															
1	132KV Coching	132kV	Tripped	09-06-2022	09:01	09-06-2022	09:11	9	-17.824	3A	3A	Grid Fail	NA	Grid Fail	
1	Coching	132	Stand stopped	11-06-2022	15:01	11-06-2022	15:14	9	-47.28	NA	NA	Insulation did not get trip when fault occur	NA	Will attend/Would dash on 23.05.2022 To CT.	
SMD DEOTHANG															
Substation: 132/33/11kV Nanglung Substation															
Month: Jun 22															
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration of Outage (Hrs)	MW before Outage (MW)	Protection Relay Operd	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Protection Relay Operd	Fault Details (As recorded by relay)			
132kV Feeders															
1	132/33kV, 5MVA Tsf-II	132kV	Shut down	01-06-2022	09:34 hrs	01-06-2022	17:11 hrs	7	0.603	-	-	-	To carry out Purging of Transformer	Shut down taken by this Substation. No supply interrupted.	
2	Nanglung-Nanglung Line	132kV	Tripping	03-06-2022	09:21 hrs	03-06-2022	09:27 hrs	0	9.43	MCOMPD4DB	Directional-OC & EE Relay: Tripped @ N: Start @ ABCN, EFI start IN1>12, wp IN1>2, VAB=95.82kV, VBC=32.93kV, VCA=33.28kV, VAN=21.18kV, VBN=20.59kV, VCN=17.12kV, IA=771.5A, IB=830.6A, IC=856.1A, IN=measured=96.06A & tripping relay S6 operated at our end. Distance Relay: Start @ ABCN, start element distance, TOC start, tripped alerts No. Fault alarm: No Fault, duration: 275.7ms, Relay trip time: 0.00s, Fault location: 55.65KM towards Nanglung, fault resistance: 1.55MΩ, IA=815.8A, IB=838.7A, IC=830.6A, VAN=21.92kV, VBN=21.25A, VCN=18.08kV.	Transient fault	-	Charged after informing BPSO, Thimphu	
3	Nanglung-Nanglung Line	132kV	Shut down	07-06-2022	06:36 hrs	07-06-2022	15:07 hrs	6	9.79	-	-	-	Shut down to carry out annual maintenance at their end	Approved shut down taken by SMD, Group to carry out annual maintenance at Nanglung Substation.	
4	Main Grid	132kV	Tripping	09-06-2022	05:01 hrs	09-06-2022	05:22 hrs	0	-	-	Directional-OC & EE Relay: Tripped @ N: Start @ AN, EFI start IN1>12, wp IN1>2, VAB=87.34kV, VBC=138.8kV, VCA=91.56kV, VAN=28.19kV, VBN=75.03kV, VCN=73.96kV, IA=1.269A, IB=125.6A, IC=133.3A, IN=measured=1.007kA & tripping relay S6 operated at our end.	Tripped on fault	-	Supply failed from Tughr & Motenga SS	
5	Nanglung-Deothang Line	132kV	Tripping	09-06-2022	05:34 hrs	09-06-2022	05:35 hrs	0	28	MCOMPD4DB	Directional-OC & EE Relay: Tripped @ N: Start @ AN, EFI start IN1>12, wp IN1>2, VAB=87.34kV, VBC=138.8kV, VCA=91.56kV, VAN=28.19kV, VBN=75.03kV, VCN=73.96kV, IA=1.269A, IB=125.6A, IC=133.3A, IN=measured=1.007kA & tripping relay S6 operated at our end.	Transient fault	-	Informed to BPSO & charged the feeder	
6	132/33kV, 5MVA Tsf-I	132kV	Tripping	18-06-2022	01:22 hrs	18-06-2022	01:24 hrs	0	0.18	-	Non directional IDMT relay opct	O/C relay-50A & trip relay S6 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Nanglung feeder
7	132/33kV, 5MVA Tsf-II	132kV	Tripping	18-06-2022	01:22 hrs	18-06-2022	01:52 hrs	0	0.11	-	Non directional IDMT relay opct	O/C relay-50A & trip relay S6 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Nanglung feeder
8	132/33kV, 5MVA Tsf-I	132kV	Tripping	18-06-2022	06:31 hrs	18-06-2022	06:33 hrs	0	0.291	-	Non directional IDMT relay opct	O/C relay-50A & trip relay S6 operated	Tripped on feeder fault	-	Tripped while test charging 33kV Wamang feeder
9	132/33kV, 5MVA Tsf-II	132kV	Tripping	18-06-2022	06:31 hrs	18-06-2022	06:34 hrs	0	0.129	-	Non directional IDMT relay opct	O/C relay-50A & trip relay S6 operated	Tripped on feeder fault	-	Tripped while test charging 33kV Wamang feeder
10	132/33kV, 5MVA Tsf-I	132kV	Tripping	27-06-2022	07:23 hrs	27-06-2022	07:25 hrs	0	0.606	-	Non directional IDMT relay opct	O/C relay-50A & trip relay S6 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Tughr feeder
11	132/33kV, 5MVA Tsf-II	132kV	Tripping	27-06-2022	07:23 hrs	27-06-2022	07:40 hrs	0	0.408	-	Non directional IDMT relay opct	O/C relay-50A & trip relay S6 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Tughr feeder
12	132/33kV, 5MVA Tsf-I	132kV	Tripping	28-06-2022	13:21 hrs	28-06-2022	13:24 hrs	0	0.456	-	Non directional IDMT relay opct	O/C relay-50A & trip relay S6 operated	Tripped on feeder fault	-	Tripped while test charging 33kV Nanglung feeder
13	132/33kV, 5MVA Tsf-II	132kV	Tripping	28-06-2022	13:21 hrs	28-06-2022	13:25 hrs	0	0.264	-	Non directional IDMT relay opct	O/C relay-50A & trip relay S6 operated	Tripped on feeder fault	-	Tripped while test charging 33kV Nanglung feeder



Transmission System Performance Report 2022

Division		SMD DEOTHANG										
Substation		132/33/11kV Deothang Substation										
Month		Jun-22										
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time (Date, Time)	Normalization Time (Date, Time)	DURATION (Hrs)	MW before Outage (MW)	Protection Relay Operd	Tripping Details (As recorded by relay)	Type/Cause of Fault	Reason for Shutdown	Remarks
12	Nganglam Deothang line	132kV	Tripping	09.06.2022 1:08	09.06.2022 1:28	0	-11.076	NA	NA	Grid fault	NA	Grid fault from Rangja. One end both the feeder is normal
13	Nganglam Deothang line	132kV	Tripping	09.06.2022 1:54	09.06.2022 1:55	0	-14.055	NA	NA	Grid fault	NA	Supply fed from Rangja at one end is normal
15	15MVA Transformer II (LV side)	132/33kV	Shutdown	09.06.2022 8:35	09.06.2022 12:45	4	9.678	NA	NA	NA	shutdown for charging tap coil and other maintenance	Charged after the completion of work
40	15MVA Transformer II	132/33kV	Tripping	19.06.2022 1:45	19.06.2022 0:23	0	0.51	NA	NA	Due to Rangja line	NA	Test charge done and found normal

Division		SMD DEOTHANG										
Substation		132/33/11kV Nganglam Substation										
Month		Jun-22										
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time (Date, Time)	Normalization Time (Date, Time)	DURATION (Hrs)	MW before Outage (MW)	Protection Relay Operd	Tripping Details (As recorded by relay)	Type/Cause of Fault	Reason for Shutdown	Remarks
1	Nganglam-Tezha feeder	132kV	Tripping	01.06.2022 09:28	01.06.2022 09:32	0	25.06	Micro relay F4C2	13-1 130kV B-1 180kV C-12 130kV VAN-10 130V 130V-10 130V 130V-14 017 Fault location 22.0km Relay Trip Time 273.3ms Fault resistance 195.00 Ohm Trip Phase ABC A-B In-Phase Zone 1	Overcurrent		Supply resumed after coordination to BPSO & Rangja end.
2	Nganglam-Motanga feeder	132kV	Tripping	01.06.2022 09:38	01.06.2022 09:35	0	25.9	Micro relay R27F10 R21.611	L1 Fault Mag 111.82kV 18.49deg L2 Fault Mag 116.20kV 113.7deg L3 Fault Mag 110.98kV 129.25deg 29 Fault Mag 134.87kV 9.7deg	Earth Fault		Supply resumed after coordination to BPSO & Motanga end.
3	Nganglam-Tezha feeder	132kV	Tripping	08.06.2022 12:46	08.06.2022 12:17	0	28.04	Micro relay F4C2	13-1 130kV B-1 180kV C-12 130kV VAN-10 130V 130V-10 130V 130V-14 017 Fault location 22.0km Relay Trip Time 273.3ms Fault resistance 195.00 Ohm Trip Phase ABC A-B In-Phase Zone 1	Overcurrent		Supply resumed after coordination with Rangja Substation, and NLDC/BPSO (closing Code 144) by Rangja Substation NLDC.
4	Nganglam-Tezha feeder	132kV	Tripping	08.06.2022 03:34	08.06.2022 03:55	0	-28.48	Micro relay F4C2	13-1 130kV B-1 180kV C-12 130kV VAN-10 130V 130V-10 130V 130V-14 017 Fault location 22.0km Relay Trip Time 273.3ms Fault resistance 195.00 Ohm Trip Phase ABC A-B In-Phase Zone 1	Overcurrent		Supply resumed after coordination with Rangja Substation, and NLDC/BPSO (closing Code 144) by Rangja Substation NLDC.
6	Nganglam-Motanga feeder	132kV	Tripping	08.06.2022 06:39	08.06.2022 09:20	0	-28.13	Micro relay F4C2	L1 Fault Mag 121.84kV 9.52deg L2 Fault Mag 127.34kV 113.7deg L3 Fault Mag 120.01kV 119.25deg 29 Fault Mag 134.87kV 9.7deg	Earth Fault		Supply resumed after coordination with Rangja Substation, and NLDC/BPSO (closing Code 144) by Rangja Substation NLDC.
9	15MVA Tr-I	132kV	Tripping	11.06.2022 07:08	15.06.2022 07:30	0	0.997	Micro relay F4C2	NA	Earth Fault Tripped due to 13kV Disk OTP under test		15MVA Tr LV side CB closed at 07:15hrs. At 07:15hrs 15MVA Tr LV side CB closed and open LV side CB of 15MVA Tr and kept in Idle Charged
10	15MVA Tr-I	132kV	Tripping	12.06.2022 08:51	12.06.2022 11:13	3	0.796	REL650R2F101 0942	Constant shutdown to release by 3 maintenance team to attend for LV side CT upgrading and lightning of 2nd & 3rd Detaching feeder	Tripped due to 15kV Detaching feeder		15MVA Transformer was put in service at 09:50hrs (Both the Transformer are now in parallel in service)
13	Nganglam-Motanga feeder	132kV	Tripping	18.06.2022 10:41	18.06.2022 10:18	0	17.3	Micro relay R27F10 R21.611	Fault Details: Zone 1 Fault Loop L1 L2 Ground Imp R Y B Fault Amp/Chk: 22.957 Fault Pd/Dir: 0.009 Recording Time 2.101s TP/80C CB-A/B Trip L1: 179.14kV L2: 177.50kV L3: 174.62kV 1.35A	Over Current (L1 L2)		As per end the CB is closed at 10:15hrs but from 10:15hrs and they could not open CB at 10:15hrs at one end as per the BPSO's instruction to close CB first from Motanga end. The CB is closed at 10:30hrs from Rangja end and after the time was long in idle.
14	Nganglam-Motanga feeder	132kV	Tripping	18.06.2022 20:41	18.06.2022 16:15	20	17.3	Micro relay R27F10 R21.611	Fault Details: Zone 1 Fault Loop L1 L2 Ground Imp R Y B Fault Amp/Chk: 22.957 Fault Pd/Dir: 0.009 Recording Time 2.101s TP/80C CB-A/B Trip L1: 179.14kV L2: 177.50kV L3: 174.62kV 1.35A	Over Current (L1 L2)		After clearing the fault at location 739kV & 739kV to 732kV and close BPSO switch. On October 19th the CB is closed at the end and without but from Motanga side they could not open CB at one end as per the BPSO's instruction to close CB first from Rangja end and after the time was long in idle.

Division		SMD DEOTHANG										
Substation		132/33kV Motanga Substation										
Month		Jun-22										
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time (Date, Time)	Normalization Time (Date, Time)	DURATION (Hrs)	MW before Outage (MW)	Protection Relay Operd	Tripping Details (As recorded by relay)	Type/Cause of Fault	Reason for Shutdown	Remarks
1	Nganglam Feeder	132kV	Tripping	##### 15:21	##### 15:38	0	-25.91	OC, 86 A & B operated.	OC, 86 A & B operated.	transient fault	-	The feeder was charged after obtaining the verbal instruction from BPSO.
2	15 MVA Transformer	132/33kV	Tripping	##### 14:37:00 pm	##### 14:40	0	2.43	OC, e/f and 86 A operated.	OC, earthfault and 86 A operated.	transient fault	-	-
4	15 MVA Transformer	132/33kV	Tripping	##### 14:27:00 pm	##### 14:32	0	1.92	o/c, ef, 86A and SEF protection operated.	o/c, ef, 86A and SEF protection operated.	transient fault	-	-
7	15 MVA Transformer	132/33kV	Tripping	##### 5:51	##### 6:20	0	0.17	OC, e/f and 86 A operated.	OC & earth fault relay operated.	-	-	-
8	15 MVA Transformer(LV)	33kV	Tripping	##### 5:51	##### 6:21	0	0.17	OC, e/f relay operated.	over current and earth fault relay operated.	transient fault	-	-
10	Rangja Feeder	132kV	Tripping	##### 5:57	##### 6:32	0	52.13	over current, earth fault & 86A operated.	over current, earth fault & 86A operated.	transient fault	-	Rangja feeder was charged with a closing code of NLDC(1402), NLDC, India(548) and NERLDC(3258).
11	Nganglam Feeder	132kV	Tripping	##### 3:34	##### 3:40	0	-30.1	over current, earth fault & 86A/B operated.	overcurrent, earthfault and 86A/B operated.	transient fault	-	charged the feeder with BPSO verbal instruction.
12	Rangja Feeder	132kV	Tripping	##### 5:01	##### 5:46	0	50.3	over current, earth fault & 86A/B operated.	overcurrent, earthfault and 86A/B operated.	-	-	Substation was blackout at 5:01hrs. Rangja and Nganglam feeder tripped. Rangja test charged at 5:17hrs, did not hold, Nganglam test charged at 5:18hrs but did not hold. As per BPSO instruction, hand tripped Deothang fdr at 5:19hrs, Silicon fdr at 5:20hrs & P/Thang fdr at 5:21hrs. Rangja charged at 5:46hrs with codes, 1412, NLDC, 636(NLDC,India), NERLDC(3312). And charged other fdr too simultaneously. Nganglam feeder was charged only at 6:31hrs thereby station supply normalised.
13	Nganglam Feeder	132kV	Tripping	##### 5:01	##### 6:31	1	-20.40	over current, earth fault & 86A/B operated.	overcurrent, earthfault and 86A/B operated.	-	-	Nganglam fdr test charged at 5:59hrs as per BPSO instruction but did not hold. Again test charged at 6:01hrs as per BPSO instruction but did not hold. Nganglam fdr charged at 6:31hrs.
14	Nganglam Feeder	132kV	Tripping	##### 19:03	##### 16:10	21	-18.58	over current, earth fault & 86A/B operated.	Zone -1 trip, R,Y & B Phase trip	-	-	The feeder was test charged at 19:11hrs but did not hold. Again test charged at 19:17hrs, 19:38hrs and 19:52 hrs but did not hold. Fault distance was shown by distance relay at 12.29km beyond Motanga substation. Upon line patrolling by TMO team next day, a tree was found fallen and hanging on the conductor. Tree was cleared and the line was charged.



Transmission System Performance Report 2022

Division: SMD-DIOTIANG		Substation: 132.33kV Phantsichang Substation		Month: Jun 22											
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/ Tripping)	Shutdown/Tripping Time		Normalization Time		Duration (Hrs)	MW before Outage (MW)	Protection Relay Oper.	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time				Fault Details (As recorded by relay)				
2	132.33kV Transformer-II (10MVA)	132kV	Transient fault	01-06-2022	11:52	01-06-2022	11:55		0.75	86A and 86B	(DPHLPDOCI) Trip value: L1: 87.15A, L2: 314.9A, L3: 97.5A, Ln: 0A	Earth fault	Unknown	Charged	
15	132.33kV Transformer-II (10MVA)	132kV	Transient fault	03-06-2022	09:57	03-06-2022	09:59		0.52	86A and 86B	Fault Value did not reflect on Relay (REF615)	Earth fault	Unknown	Charged	
23	132.33kV Transformer-II (10MVA)	132kV	Trip on Fault	03-06-2022	23:47	03-06-2022	23:48		0.50	86A and 86B	(DPHLPDOCI) Fault value: L1: 121.05A, L2: 59.55A, L3: 68.55A, Ln: 0A	Overcurrent	Unknown	Charged	
28	132.33kV Transformer-II (10MVA)	132kV	Transient fault	05-06-2022	17:40	05-06-2022	17:42		0.63	86A and 86B	Fault Value did not reflect on Relay (REF615)	Earth fault	Unknown	Charged	
36	132.33kV Transformer-II (10MVA)	132kV	Transient fault	07-06-2022	17:43	07-06-2022	17:46		0.58	86A and 86B	Fault Value did not reflect on Relay (REF615)	Earth fault	Unknown	Charged	
44	132.33kV Transformer-II (10MVA)	132kV	Transient fault	11-06-2022	03:58	11-06-2022	04:06		0.47	86A and 86B	(DPHLPDOCI) Fault Value L1: 1173.4A, L2: 341.7A, L3: 168.3A, Ln: 0	Over current	Unknown	Charged	
47	132.33kV Transformer-II (10MVA)	132kV	Trip on Fault	11-06-2022	16:58	11-06-2022	17:14		0.10	86A and 86B	(DPHLPDOCI) Fault Value L1: 33.75A, L2: 51.6A, L3: 73.2A, Ln: 0	Earth fault	Unknown	Charged	
51	132.33kV Transformer-II (10MVA)	132kV	Transient fault	11-06-2022	22:56	11-06-2022	22:59		0.26	86A and 86B	(DPHLPDOCI) Fault Value L1: 338.7A, L2: 347.7A, L3: 302.55A, Ln: 0	Over current	Unknown	Charged	
55	132.33kV Transformer-II (10MVA)	132kV	Transient fault	12-06-2022	01:52	12-06-2022	01:54		0.47	86A and 86B	(DPHLPDOCI) Fault Value L1: 198.15A, L2: 259.1A, L3: 53.85A, Ln: 0	Earth fault	Unknown	Charged	
58	132.33kV Transformer-II (10MVA)	132kV	Trip on Fault	12-06-2022	09:40	12-06-2022	09:43		0.64	86A and 86B	(DPHLPDOCI) Fault Value L1: 211.4A, L2: 277.25A, L3: 81.3A, Ln: 0	Over current	Unknown	Charged	
69	132.33kV Transformer-II (10MVA)	132kV	Trip on Fault	15-06-2022	09:46	15-06-2022	09:50		0.58	86A and 86B	(DPHLPDOCI) Fault value: L1: 45A, L2: 60.45A, L3: 23.1A, Ln: 0A Test charge fault value: L1: 45A, L2: 59.7A, L3: 21.5A, Ln: 0A	Earth fault	Unknown	Charged after isolating faulty feeder	
72	132.33kV Transformer-II (10MVA)	132kV	Trip on Fault	16-06-2022	09:57	16-06-2022	09:59		0.33	86A and 86B	(DPHLPDOCI) Fault value: L1: 174.6A, L2: 346.5A, L3: 171.9A, Ln: 0A	Overcurrent	Unknown	Charged	
75	132.33kV Transformer-II (10MVA)	132kV	Trip on Fault	17-06-2022	11:21	17-06-2022	11:25		0.27	86A and 86B	(DPHLPDOCI) Fault value: L1: 163.2A, L2: 320.4A, L3: 156.75A, Ln: 0A Test charge fault value: L1: 218.5A, L2: 326.65A, L3: 348.8, Ln: 0A	Over current	Unknown	Charged	
78	132.33kV Transformer-II (10MVA)	132kV	Trip on Fault	18-06-2022	03:11	18-06-2022	03:17		0.23	86A and 86B	(DPHLPDOCI) Fault value: L1: 402.3A, L2: 379.8A, L3: 385.35A, Ln: 0A	Overcurrent	Unknown	Charged	
83	132.33kV Transformer-II (10MVA)	132kV	Trip on Fault	19-06-2022	08:46	19-06-2022	08:49		0.46	86A and 86B	(DPHLPDOCI) Fault value: L1: 192.15A, L2: 373.45A, L3: 181.65A, Ln: 0A Test charge fault value: L1: 201.15A, L2: 388.35A, L3: 167.35A, Ln: 0A	Overcurrent	Unknown	Charged after isolating faulty feeder	
87	132.33kV Transformer-II (10MVA)	132kV	Trip on Fault	21-06-2022	13:19	21-06-2022	13:27		0.09	86A and 86B	(DPHLPDOCI) Fault value: L1: 85.95A, L2: 0.90A, L3: 86.25A, Ln: 0A	Earth fault not Overcurrent	Unknown	Charged	
92	132.33kV Transformer-II (10MVA)	132kV	Trip on Fault	27-06-2022	20:15	27-06-2022	20:22		0.14	86A and 86B	(DPHLPDOCI) Fault value: L1: 34.05A, L2: 79.85A, L3: 32.35A, Ln: 0A	Overcurrent	Unknown	Charged	



Transmission System Performance Report 2022

1. 400/220/132/33kV Jigmeling Substation

Sl. No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MW before Outage (MW)	Name of feeder	Name of the Substati on/lines Affected by the Fault	Reasons of Fault	Relay Operations	Type of outages	Remarks
i) 66kV Above												
1	02.06.2022	14:47 hrs	02.06.2022	15:06 hrs	0	171.62	400kV MHEP Line- 4	Alipurdu ar Substatio n	Rph-G Fault	Z1 pickup. (AR comd. ON)	Transient	
2	02.06.2022	15:28 hrs	02.06.2022	15:39 hrs	0	331.6	400kV MHEP Line- 3	Alipurdu ar Substatio n	L3-E Loop	R & B Phase Trip. Z1 pick up. (AR Comd. ON)	Transient	
3	23.06.2022	15:03 hrs	23.06.2022	15:03 hrs	0	-289.43	400kV MHEP Line- 3	Alipurdu ar Substatio n	L3-E Loop	Main-1; Bph pick up. Main-2; Bph pick up. Ground pickup and Z1 optd.	Transient	Line auto reclosed
4	01.06.2022	12:57 hrs	01.06.2022	13:03 hrs	0	6.320	220kV Tsirang	Tsirang Substatio n	Bph to Ground	Main 1 Bph Trip and Z1 trip. Main 2 Bph Trip and Z1		
5	01.06.2022	12:57 hrs	01.06.2022	13:06 hrs	0	21.560	220kV Dagapela	Dagapela Substatio n	Bph to Ground	Main 1 (Yph trip, Bph Trip and Z1 trip. Main 2 Bph Trip and Z1 trip.		
6	02.06.2022	14:28 hrs	02.06.2022	14:42 hrs	0	29.050	220-132kV 80MVA ICT- 1	Jigmeling Substatio n		SEF optd.		
7	11.06.2022	08:48 hrs	11.06.2022	09:02 hrs	0	30.340	220kV Dagapela	Dagapela Substatio n	Line Fault	Main 1; R & Y phase trip, Z1 trip (BG). Main 2; R & Y phase trip, Z1 trip	Transient	
8	02.06.2022	14:27 hrs	02.06.2022	14:32 hrs	0	20	132kV Gelephu	Gelephu Substatio n	RY phase trip.	RY phase trip, zone 1 zone 2 optd.	Transient	
9	02.06.2022	14:27 hrs	02.06.2022	14:39 hrs	0	38.6	132kV Tingthi	Tingthi Substatio n	RYBph and Ground Loop.	RYB-E loop, Z1pick up. Z1 optd.	Transient	
10	23.06.2022	15:50 hrs	23.06.2022	16:19 hrs	0	34.64	132kV Tingthi	Tingthi Substatio n	RYBph and Ground Loop.	Main 1 Relay General Trip and R,Y and B phase trip. Z1/Z1B trip		



Transmission System Performance Report 2022

3. 132/66/33/11kV Gelephu Substation												
i) 66kV and above												
1	02.06.2022	14:29hrs	02.06.2022	15:16hrs	0	14.4	132kV Sal-Ge	Non	Heavy lightning	Tripped, 86 master relay opp	Temporary	Charging Code: NLDC BTN=1365, NLDC IND=130 & NERLDC=2984. At the same time 132kv Gelephu line also tripped from Jigmechling end.
2	21.06.2022	15:25hrs	21.06.2022	16:03hrs	0	18	132kV Gel-Jig	Non	Emergency shutdown taken by TMD Gelephu	non	Temporary	TMD manager was called by Gelephu Thromde official as they were facing induction problem while stringing CCTV camera fiber line below crossing our 132kV grid line. DPSO opening Code: 0811 & closing code: 1600.
4. 132/33kV Tintibi Substation												
i) 66kV & Above												
1	18.06.2022	19:03	18.06.2022	19:08	0	16.78	Tingubi-Nangtubi-Na		Temporary Fault	Distance Relay:Start Phase:AB,Trip Phase:ABC,Fault zone-1 trip,Fault location:58.60kM.	Temporary Fault	
2	23.06.2022	15:50	23.06.2022	16:19	0	18.79	Tingubi-Nangtubi-Na		Temporary Fault	Distance Relay:Start Phase:ABCN,Trip Phase:ABC,Fault zone-1 trip,Fault location:18.75kM.	Temporary Fault	



Transmission System Performance Report 2022

July 2022

Division		SMD DROTHANG		Substation		132/33/11kV Kikkur Substation		Month		Jul-22											
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration of Outage		MW before Outage (MW)	Protection Relay Oper	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks					
				Date	Time	Date	Time	(Hrs)	(Min)			Protect	Relay Oper				Relay Oper	Relay Oper			
132kV Feeders																					
1	Kachha Incomer	132kV	Tripped	07-07-2022	16:13 hrs	07-07-2022	16:18 hrs	5	4.536	NA	NA	Grid Failed	Tripped			Grid Failed from Tripped					
2	Kachha Incomer	132kV	Tripped	08-07-2022	22:55 hrs	08-07-2022	23:14 hrs	19	55.368	NA	NA	Grid Failed	Tripped			Grid failed from both the end (Zangla and Salsak)					
Division		SMD DROTHANG		Substation		132/33/11kV Kengkang Substation		Month		Jul-22											
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration of Outage		MW before Outage (MW)	Protection Relay Oper	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks					
				Date	Time	Date	Time	(Hrs)	(Min)			Protect	Relay Oper				Relay Oper	Relay Oper			
132kV																					
1	Corking to Kengkang	132	Tripping	03-07-2022	15:33	03-07-2022	15:35	0	18.828	distance protection	opt:tripping relay opt			NA		test changed the feeder, so the feeder withdrawn					
2	phantomwing to Kengkang	132	Tripping	03-07-2022	15:33	03-07-2022	16:54	1	21.348	GR-A/B Trip relay opt			NA		test changed the feeder at 16:29 hrs with charging code: 1650(GPSC) but conductor withdrawn the feeder during same fault						
3	Corking to Kengkang	132	Tripping	05-07-2022	0:42	05-07-2022	0:52	0	10	distance protection	opt:tripping relay opt	IA 585.7A, EI 541.4A, IC 98.54A		Earth fault	NA	test changed this & withdrawn					
4	phantomwing to Kengkang	132	Tripping	05-07-2022	0:42	05-07-2022	1:24	0	42	GR-A/B Trip relay opt			NA		Test changed after getting information from BPSO, thus withdrawn						
5	Corking to Kengkang	132	Grid Fail	08-07-2022	22:52	08-07-2022	23:25	0	53	53.048	NA	NA		NA		Grid Fail					
6	Corking to Kengkang	132	hand tripped	20-07-2022	14:24	20-07-2022	15:01	0	17	-10.124	NA	NA(hand tripped)		NA		Due to disk punctured and conductor snapped in 33 kv side. Disk, insulators caught fire and as emergency incomes had to be trip					
Division		SMD DROTHANG		Substation		132/33/11kV Nanglung Substation		Month		Jul-22											
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration of Outage		MW before Outage (MW)	Protection Relay Oper	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks					
				Date	Time	Date	Time	(Hrs)	(Min)			Protect	Relay Oper				Relay Oper	Relay Oper			
132kV Feeders																					
1	Nanglung-Drothang Line	132kV	Tripping	02-07-2022	16:22 hrs	02-07-2022	20:34 hrs	4	12	54.5	MCOMP4DB	Directional-OC & E/F Relay: Start O BN, Trip O N. O.C start 1-1, 5P1 start IN1-12, trip IN1-2 VAD=85.8kV, VBC=86.72kV, VCA=128kV, VAN=79.0kV, VBN=24.3kV, VCN=74.6kV, VA=226.8A, EI=1.32kA, IC=217.7A, INDistend=1.260kA, IN measured=1.261kA & tripping relay 86 operated at its end	Insulator punctured at Drothang Substation end	-		Changed after informing BPSO, Thangla					
2	Main Grid	132kV	Tripping	02-07-2022	16:13 hrs	02-07-2022	16:18 hrs	0	5	-	-	-	Transient fault	-		Sagely failed from Tethi & Drothang SS					
3	Nanglung-Nanglung	132kV	Tripping	02-07-2022	16:13 hrs	02-07-2022	16:21 hrs	0	8	-4.1	MCOMP4DB & Distance relay	Directional-OC & E/F Relay: Start O ABC, O.C start 1-1 VAD=33.0kV, VBC=35.84kV, VCA=47.2kV, VAN=27.54kV, VBN=10.1kV, VCN=26.97kV, IA=882.7A, EI=1.66kA, IC=1.57kA, INDistend=8376.3A, IN measured=575.3A & tripping relay 86 operated at its end Distance Relay: Start O ABC, Start distance distance, All lockout short, fault clearance, 73.17ms, relay trip time: 79.52ms, Fault location: 9.815KM towards Nanglung, IA=1.936kA, IB=2.078kA, IC=1.857kA, VAN=8.087kV, VBN=8.124kV, VCN=10.0kV, Fault resistance=136.1mΩ & fault at Zone-1	Tripped on fault	-		Tripped at the instance of Grid failure. Changed after receiving instruction from BPSO, Thangla					
4	132/33kV, SMVA Tif-I	132kV	Tripping	05-07-2022	00:09 hrs	05-07-2022	00:13 hrs	0	4	0.231	Non directional IDMT relay opt	O.C relay-50A & trip relay 86 operated	Tripped on feeder fault	-		Tripped due to fault on 33kV Nanglung feeder					
5	132/33kV, SMVA Tif-II	132kV	Tripping	05-07-2022	00:09 hrs	05-07-2022	00:13 hrs	0	4	0.153	Non directional IDMT relay opt	O.C relay-50A & trip relay 86 operated	Tripped on feeder fault	-		Tripped due to fault on 33kV Nanglung feeder					
7	132/33kV, SMVA Tif-I	132kV	Tripping	08-07-2022	05:41 hrs	08-07-2022	05:45 hrs	0	4	0.621	Non directional IDMT relay opt	O.C relay-50A & trip relay 86 operated	Tripped on feeder fault	-		Tripped due to fault on 33kV Nanglung feeder					
8	132/33kV, SMVA Tif-II	132kV	Tripping	08-07-2022	05:41 hrs	08-07-2022	05:49 hrs	0	5	0.405	Non directional IDMT relay opt	O.C relay-50A, 50C & trip relay 86 operated	Tripped on feeder fault	-		Tripped due to fault on 33kV Nanglung feeder					
9	132/33kV, SMVA Tif-I	132kV	Tripping	08-07-2022	05:55 hrs	08-07-2022	05:57 hrs	0	2	0.621	Non directional IDMT relay opt	O.C relay-50A, 50C & trip relay 86 operated	Tripped on feeder fault	-		Tripped while test charging 33kV Nanglung feeder					
10	132/33kV, SMVA Tif-II	132kV	Tripping	08-07-2022	05:55 hrs	08-07-2022	05:58 hrs	0	3	0.405	Non directional IDMT relay opt	O.C relay-50A, 50C & trip relay 86 operated	Tripped on feeder fault	-		Tripped while test charging 33kV Nanglung feeder					
11	132/33kV, SMVA Tif-I	132kV	Tripping	08-07-2022	15:14 hrs	08-07-2022	15:18 hrs	0	4	0.522	Non directional IDMT relay opt	O.C relay-50A, 50C & trip relay 86 operated	Tripped on feeder fault	-		Tripped while closing LBS for 33kV Nanglung feeder from Khoozi site					
12	132/33kV, SMVA Tif-II	132kV	Tripping	08-07-2022	15:14 hrs	08-07-2022	15:18 hrs	0	4	0.551	Non directional IDMT relay opt	O.C relay-50A, 50C & trip relay 86 operated	Tripped on feeder fault	-		Tripped while closing LBS for 33kV Nanglung feeder from Khoozi site					



Transmission System Performance Report 2022

Sl. No.	Name of Feeder	Voltage Level	Type of Outage	Start Date	End Date	Start Time	End Time	Duration (hrs)	MW before Outage (MW)	Protection Relay Operated	Distance Relay	Reason for Shutdown	Remarks	
13	Nangkor-Drothing Line	132kV	Tripping	08-07-2022	08-07-2022	17:29 hrs	17:32 hrs	0	-42.8	Distance Relay	Distance Relay	Transient fault	Informed to BPSO & charged as per their instruction.	
14	Nangkor-Drothing Line	132kV	Tripping	08-07-2022	08-07-2022	17:47 hrs	17:50 hrs	0	-42.8	Distance Relay	Distance Relay	Transient fault	Informed to BPSO & charged as per their instruction.	
15	Nangkor-Drothing Line	132kV	Tripping	08-07-2022	08-07-2022	17:56 hrs	21:59 hrs	4	-42.8	-	Tripping relay B6 operated	Tripped while closing CB from Drothing SS end	Informed to BPSO & as instructed kept CB in open position and at the same informed to TMD, Nangkor as there was repeated tripping of the said feeder. Charged as per the instruction from BPSO, Thimphu at 21:59 hrs.	
16	Karcho-Nangkor Line	132kV	Tripping	08-07-2022	08-07-2022	17:58 hrs	18:11 hrs	0	-41.25	Distance Relay	Distance Relay	Tripped while closing CB from Drothing SS end	Informed BPSO & as instructed closed the CB from our end.	
17	Karcho-Nangkor	132kV	Tripping	08-07-2022	08-07-2022	22:55 hrs	23:09 hrs	0	-9.9	Distance Relay	Distance Relay	Tripped at the instant of Grid failure	Informed BPSO & as instructed closed the CB from our end.	
18	Main Grid	132kV	Tripping	08-07-2022	08-07-2022	22:55 hrs	23:01 hrs	0	-	-	-	Grid failed from Rangpo SS & Solokan Grid occurred at 23:01 hrs.		
19	Nangkor-Drothing Line	132kV	Tripping	08-07-2022	08-07-2022	22:55 hrs	23:11 hrs	0	0.07	Distance Relay	Distance Relay	Tripped at the instant of Grid failure	Informed BPSO & as instructed closed the CB from our end.	
20	Nangkor-Nyangchen	132kV	Tripping	09-07-2022	09-07-2022	06:55 hrs	09:44 hrs	2	49	-	-	Transient fault; CB tripped without any relay indication; CB position	Informed to BPSO & test charged done at 07:09 hrs and 07:17 hrs, but CB didn't stand. Checked the CB & charged after checking & tightening the trip circuit.	
21	Nangkor-Nyangchen	132kV	Tripping	11-07-2022	11-07-2022	08:10 hrs	08:15 hrs	0	-5	-	-	Transient fault	CB operated without any relay indication. Informed the BPSO & closed the CB	
22	Nangkor-Nyangchen	132kV	Tripping	11-07-2022	11-07-2022	10:49 hrs	10:50 hrs	0	-9	-	-	Transient fault	CB operated without any relay indication. Informed to BPSO & closed the CB	
22	Nangkor-Nyangchen	132kV	Tripping	11-07-2022	12-07-2022	12:04 hrs	13:07 hrs	26	3	-5.58	-	Transient fault	CB operated without any relay indication. Informed to BPSO & due to repeated tripping, feeder taken under shutdown for CB recalculation work. CB closed after informing to BPSO.	
23	132/33kV, 5MVA Td-I	132kV	Tripping	14-07-2022	14-07-2022	15:28 hrs	15:29 hrs	0	1	0.6	Non directional IDMT relay op'd	O/C-50A & tripping relay B6 operated	Tripped on feeder fault	Tripped due to fault on 33kV Nangkor feeder
24	132/33kV, 5MVA Td-II	132kV	Tripping	14-07-2022	14-07-2022	15:28 hrs	15:30 hrs	0	2	0.35	Non directional IDMT relay op'd	O/C-50A & tripping relay B6 operated	Tripped on feeder fault	Tripped due to fault on 33kV Nangkor feeder
25	132/33kV, 5MVA Td-I	132kV	Tripping	14-07-2022	14-07-2022	16:04 hrs	16:05 hrs	0	1	0.591	Non directional IDMT relay op'd	O/C-50A & tripping relay B6 operated	Tripped on feeder fault	Tripped while test charging 33kV Testor feeder
26	132/33kV, 5MVA Td-II	132kV	Tripping	14-07-2022	14-07-2022	16:04 hrs	16:05 hrs	0	1	0.312	Non directional IDMT relay op'd	O/C-50A & tripping relay B6 operated	Tripped on feeder fault	Tripped while test charging 33kV Testor feeder
27	Nangkor-Nyangchen	132kV	Tripping	20-07-2022	20-07-2022	21:26 hrs	21:31 hrs	0	5	-16.7	-	Transient fault	Tripped without any relay indication. Informed to BPSO & closed the CB	

SMD DROTHING 132/33kV Drothing Substation Jul 22															
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration of Outage (Hrs)	MW before Outage (MW)	Protection Relay Operated	Tripping Details		Reason for Shutdown	Remarks	
				Date	Time	Date	Time				Fault Details (As recorded by relay)	Type Cause of Fault			
3	Drothing-Nangkor line	132kV	Tripping	02-07-2022	16:23	02-07-2022	20:37	4	14	-54.468	NI	NA	NA	Charged after the replacement of disc insulator with the closing code 1638 from BPSO given by Jangchok Solok.	
4	Drothing-Montaga line	132kV	Tripping	02-07-2022	16:23	02-07-2022	20:51	4	27	52.524	NI	NA	NA	Charged after the replacement of disc insulator with the closing code 1657 from BPSO given by Jangchok Solok.	
7	Drothing-Nangkor line	132kV	Tripping	03-07-2022	16:14	03-07-2022	16:19	0	8	-42.208	Over current	IA = 1.079A, IB = 1.155A, IC = 1.092A, IN = 0.973A	NA	Tripped at Drothing end only. No supply interruption as the supply went from Montaga substation.	
12	Drothing-Nangkor line	132kV	Shutdown	04-07-2022	9:15	04-07-2022	11:30	2	10	-43.776	NA	NI	NA	Shutdown as per opening code 0535 to BPSO from Chama saying Test spot on line isolator B phase. Charge as per the closing code 1663 by BPSO Karna.	
16	5MVA Transformer II	132/33kV	Tripping	07-07-2022	4:09	07-07-2022	4:15	0	6	0.582	Only B6 operated	NI	NA	Due to bangtor 6kV transformer got tripped. Test charge done and found normal.	
23	Drothing-Nangkor line	132kV	Tripping	08-07-2022	17:28	08-07-2022	17:34	0	6	-42.768	O/C	Fault Z1 tripped, fault location: 13.55km IA: 1.357kA, IB: 142.8kA, IC: 1.452kA, Directional relay fault value IA=1.561kA, IB=183.8kA, IC=1.457kA	Unknown	NA	Test charge done and found normal.
24	Drothing-Montaga line	132kV	Tripping	08-07-2022	17:28	08-07-2022	17:32	0	4	42.26	NA	NI	NA	At our end breaker is normal and supply resumed from Montaga end.	
25	Drothing-Nangkor line	132kV	Tripping	08-07-2022	17:48	08-07-2022	21:51	4	7	-42.768	O/C	Distance relay fault value IA=191.8kA, IB=192.8kA, IC=12.49kA. Test charged value IA=180.8kA, IB=181.5kA, IC=12.47kA	Unknown	NA	Test charge done 17:52 but couldn't stand. As information given to BPSO, lightning and thundering at Nangkor side.
26	Drothing-Nangkor line	132kV	Tripped	08-07-2022	22:58	08-07-2022	23:18	0	17	-42.768	Distance relay	under voltage	under voltage	Test charge done 23:18 hrs with the closing code 1690 given by the BPSO Karna Choden and line stand.	
27	Drothing-Montaga line	132kV	Hard trip	08-07-2022	22:32	08-07-2022	22:40	0	8	-0.9	NI	NA	NA	Breaker hard trip as to charge from Montaga substation due to substation voltage. Opening code from BPSO 0546 by Phub Zam. Closing code 1695 by BPSO Karna Choden and line stand.	
71	Nangkor-Drothing line	132kV	Tripping	23-07-2022	23:43	23-07-2022	23:48	0	5	-46.692	Distance relay	IA=1.280kA, IB=191kA, IC=1.305kA	Transient fault	Line charged as per informed by the BPSO and line hold.	
86	Transformer I (5MVA)	132kV	Tripped	30-07-2022	15:10	30-07-2022	15:16	0	6	0.3	NA	relay B6 operated	NA	Tripped by Bangtor 6kV.	
87	Transformer II (5MVA)	132kV	Tripped	30-07-2022	15:10	30-07-2022	15:17	0	7	0.3	NA	relay B6 operated	NA	Tripped by Bangtor 6kV.	



Transmission System Performance Report 2022

Division		SMD DROTHANG													
Substation		132/33kV Nganglun Substation													
Month		Feb-22													
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration of Outage		MW before Outage (MW)	Protection Relay Oper	Tripping Details Fault Details (As recorded by relay)	Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)						
1	Nganglun-Tashi feeder	132kV	Tripping	03.07.2022	16:11	03.07.2022	16:38	0	5	-14.71	Micon relay P442	IA- 952.2A IB- 982.8A IC- 953.9A VAN- 11.8kV VCN- 12.51kV Fault location 51.81km Relay Trip Time 0.60s Fault resistance - 66.92ohm Trip Phase ABCN Zone 3	Earth Fault	CB operated both end from Tanghai to & Nauglun to. No CB operated at our end only Micon relay operated.	Supply restored from Tanghai end.
2	Nganglun-Tashi feeder	132kV	Tripping	06.07.2022	07:50	06.07.2022	07:57	0	7	-0.4	Micon relay P443	Line tripped on Earth fault	Earth Fault	CB operated both end from Tanghai to & Nauglun to. No CB operated at our end only Micon relay operated.	Supply restored from Tanghai end.
3	Nganglun-Tashi feeder	132kV	Tripping	08.07.2022	22:35	08.07.2022	23:00	0	25	-2.71	Micon relay P443	IA- 1.029kA IB- 0.600kA IC- 1.007kA VAN- 12.39kV VCN- 1.9kV VCN- 11.28kV Fault location 38.77km Relay Trip Time 0.56s Fault resistance - 3.31.5ohm less Trip Phase ABC Zone 1	Earth Fault	CB operated both end from Tanghai to & Nauglun to. No CB operated at our end only Micon relay operated.	Supply restored from Tanghai end.
4	5MVA Transformer 1 HV 8kV	132kV	Tripping	08.07.2022	22:15	08.07.2022	22:26	0	11	0.889	O/C & E/F Micon relay	Tripped on Overcurrent while Test charging 33kV Decharging feeder	Earth Fault		Supply restored from bus 11
5	5MVA Transformer	132kV	Tripping	18.07.2022	07:38	18.07.2022	12:04	4	25		Micon O/C & E/F	Tripped on O/C and observed low SF6 and Normalized after refilling the Gas	Overcurrent		
6	5MVA Transformer	132kV	Tripping	18.07.2022	08:58	18.07.2022	09:01	0	3	0.75	Micon O/C & E/F	Tripped on O/C due to 33kV Decharging feeder	Overcurrent		
7	5MVA Transformer	132kV	Tripping	24.07.2022	09:54	24.07.2022	09:55	0	1	0.425	O/C & E/F Micon relay	Tripped on Overcurrent while Test charging 33kV Decharging feeder	Overcurrent		
8	Nganglun-Tashi feeder	132kV	Tripping	24.07.2022	02:10	24.07.2022	02:22	0	12	-20.56	Micon relay P442	Tripped on Overcurrent. Fault details: IA- 57.22kA IB- 1.065kA IC- 1.151kA IN- 4.374kA VAN- 13.2kV VCN- 18.92kV VCN- 106.4kV A/R lock out Zone2 Fault location 399.9km Relay Trip time 79.94ms Fault Location 85.13km Fault resistance - 399.7ohm set. Trip phase ABC	Overcurrent		
9	5MVA Transformer 1 LV side	132kV	Tripping	25.07.2022	23:05	25.07.2022	23:10	0	5	1.21	O/C & E/F Micon relay	Feeder tripped on earth fault. Unoperated 41N operated	Earth Fault		
10	5MVA Transformer	132kV	Tripping	27.07.2022	11:15	27.07.2022	11:17	0	2	0.78	O/C & E/F Micon relay	Tripped on Overcurrent while Test charging 33kV Decharging feeder	Overcurrent		
11	5MVA Transformer	132kV	Tripping	31.07.2022	05:20	31.07.2022	05:21	0	1	0.493	O/C & E/F Micon relay	Tripped on Overcurrent due to 33kV Decharging feeder fault	Overcurrent		

Division		SMD DROTHANG													
Substation		132/33kV Moringa Substation													
Month		Feb-22													
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration of Outage		MW before Outage (MW)	Protection Relay Oper	Tripping Details Fault Details (As recorded by relay)	Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)						
1	Rangin Feeder	132kV	Tripping	02.07.2022	16:22 hrs	02.07.2022	16:58hrs	0	36	46.52	EFBPTOC1, REF615	Directional-O/C & E/F Relay: Tripped on E/F & O/C. IL1= 46.5A, IL2= 657.3A, IL3= 213.9A, Frequency= 49.50Hz & tripping relay 86 & B operated at our end.	Tripped by transient fault		Informed to BPSO and changed via code- 1636(BPSO), 66(NLDC, India), 395(NERLDC).
2	Drothang Feeder	132kV	Tripping	02.07.2022	16:22 hrs	02.07.2022	20:22hrs	4	0	-51.42	EFBPTOC1, REF615	Directional-O/C & E/F Relay: Tripped on E/F & O/C. IL1= 144.6A, IL2= 1593.6A, IL3= 192.4A, Frequency= 49.97Hz & tripping relay 86 & B operated at our end.	Tripped by transient fault		Rangin & Drothang feeder tripped on same line but Drothang fix kept on hold as per BPSO, Rangin charged. Dose insulator fractured at drothang end as per BPSO. Feeder was charged after replacement of d/c insulator.
3	Phanshodang feeder	132kV	Tripping	03.07.2022	15:35 hrs	03.07.2022	21:43 hrs	0	8	-18.22	EFBPTOC1, REF615	Directional-O/C & E/F Relay: Tripped on E/F & O/C. IL1= 614.4A, IL2= 89.7A, IL3= 595.2A, Frequency= 50.12Hz & tripping relay 86 & B operated at our end.	Tripped by transient fault		changed the feeder by verbal instruction from BPSO
4	Phanshodang feeder	132kV	Tripping	05.07.2022	00:44 hrs	05.07.2022	00:59 hrs	0	6	-19.99	EFBPTOC1, REF615	Directional-O/C & E/F Relay: Tripped on E/F & O/C. IL1= 900.1A, IL2= 961A, IL3= 51.5A, Frequency= 49.99Hz & tripping relay 86 & B operated at our end.	Tripped by transient fault		changed the feeder by verbal instruction from BPSO
5	Drothang Feeder	132kV	Tripping	05.07.2022	00:44 hrs	05.07.2022	01:22 hrs	0	38	-81.56	EFBPTOC1, REF615	Directional-O/C & E/F Relay: Tripped on E/F & O/C. IL1= 690.8A, IL2= 609.5A, IL3= 145A, Frequency= 49.91Hz & tripping relay 86 & B operated at our end.			Changed the feeder by verbal instruction from BPSO
6	Rangin Feeder	132kV	Tripping	07.07.2022	09:23 hrs	07.07.2022	09:47 hrs	0	24	28.11	Distance protection, REL650	O/C & E/F Relay operated: Tripped on E/F & O/C. IL1= 159.97A, IL2= 634.59A, IL3= 131.50A, Frequency= 50.09Hz & tripping relay 86 & B operated at our end.	Transient fault		charging code: BPSO(673), NLDC, INDIA, 310 and NERLDC, INDIA(4186).
7	Drothang Feeder	132kV	Tripping	08.07.2022	17:20 hrs	08.07.2022	17:31 hrs	0	2	-42.16	EFBPTOC1, REF615	Directional-O/C & E/F Relay: Tripped on E/F & O/C. IL1= 1495.6A, IL2= 243A, IL3= 150.3A, Frequency= 49.93Hz & tripping relay 86 & B operated at our end.	Tripped by transient fault		changed the feeder by verbal instruction from BPSO
8	Rangin Feeder	132kV	Tripping	08.07.2022	17:20 hrs	08.07.2022	17:46 hrs	0	17	32.19	EFBPTOC1, REF615	Directional-O/C & E/F Relay: Tripped on E/F & O/C. IL1= 613.3A, IL2= 154.5A, IL3= 695A, Frequency= 49.92Hz & tripping relay 86 & B operated at our end.	Transient fault		charging code: BPSO(1682), NLDC, INDIA, 425 and NERLDC, INDIA(4121).
9	Drothang Feeder	132kV	Tripping	08.07.2022	22:00 hrs	08.07.2022	22:47 hrs	0	47	0.83	DEFLPDEF1, REF615	Directional-O/C & E/F Relay: Tripped on E/F & O/C. IL1= 1219A, IL2= 223.2A, IL3= 1.1A, Frequency= 50.03Hz & tripping relay 86 & B operated at our end.	Transient fault		At 22:34hrs test charge was done at our end but CB did not hold & got tripped on same fault. Field inspection carried out for any abnormalities. Informed BPSO and charged feeder with code: 3090
10	Drothang Feeder	132kV	Tripping	09.07.2022	01:13 hrs	10.07.2022	15:17 hrs	38	4	-7.47	DEFLPDEF1, REF615	Directional-O/C & E/F Relay: Tripped on E/F & O/C. IL1= 245A, IL2= 247.2A, IL3= 1.2A, Frequency= 50.01Hz. Fuse Full Break shown at REL650 distance protection relay, & tripping relay 86 & B operated at our end.	Feeder tripped on permanent fault		Feeder was stopped and there was low voltage across on B-phase. Fuse full broken conductors indicated by REL650 Relay. Informed BPSO & TMD team, Drothang Line patrolling carried out by TMD team and found that B phase jumper was cut at location no. DM 231. Replaced jumper and charged the feeder on next day upon coordination with BPSO.
11	5MVA Transformer	132/33kV	Tripping	12.07.2022	00:35 hrs	12.07.2022	00:39 hrs	0	4	3.01	Distance protection, REL650	tripping relay 86A and B and SEF operated.			changed the transformer by verbal instruction from BPSO
12	5MVA Transformer	112/33kV	Tripping	18.07.2022	04:17 hrs	18.07.2022	04:39 hrs	0	22	1.02	protection Relay 86 A&B operated	tripped on O/C & E/F, 50.51 trip	Transient fault		coordinated with BPSO and charged.
13	Rangin Feeder	132kV	shutdown	19.07.2022	11:29 hrs	19.07.2022	11:56 hrs	2	27	-4.96					For Re-W cleaning works
14	5MVA Transformer	112/33kV	Tripping	19.07.2022	14:11 hrs	19.07.2022	14:16 hrs	0	5	1.54	protection Relay 86 A&B operated	tripped on O/C & E/F, 50.51 trip, SEF protection trip.	Transient fault		Shutdown taken by Rangin end for Re-W cleaning works
15	5MVA Transformer	112/33kV	Tripping	21.07.2022	05:57 hrs	21.07.2022	06:01 hrs	0	6	0.16	Directional E/F Relay, DEFLPDEF1 & 86 A&B operated	tripped on O/C & E/F, 50.51 trip, SEF protection trip.	Transient fault		changed the feeder by verbal instruction from BPSO
16	Drothang Feeder	132kV	Tripping	23.07.2022	23:44 hrs	23.07.2022	23:52 hrs	0	8	-45.43	EFBPTOC1, REF615	Directional-O/C & E/F Relay: Tripped on E/F & O/C. IL1= 1988A, IL2= 256.2A, IL3= 1824.6A, Frequency= 49.86Hz, tripping relay 86A&B operated at our end.	Transient fault		Charged as per the instruction from BPSO.
17	Rangin Feeder	132kV	Tripping	23.07.2022	23:44 hrs	24.07.2022	00:13 hrs	0	49	37.3	EFBPTOC1, REF615	Directional-O/C & E/F Relay: Tripped on E/F & O/C. IL1= 1648.4, IL2= 297.6A, IL3= 1549.2A, Frequency= 49.88Hz, tripping relay 86A&B operated at our end.	Transient fault		charging code: BPSO(1795), NLDC, INDIA, 1259 and NERLDC, INDIA(4662).
18	Rangin Feeder	132kV	shutdown	26.07.2022	00:25 hrs	26.07.2022	11:29 hrs	0	49	37.3					For Re-W cleaning works by TMD, Pithing



Transmission System Performance Report 2022

1. 400/220/132/33kV Jigmeling Substation													
Sl. No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MW before Outage (MW)	Name of feeder	Name of the Substation/lines Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outages	Remarks
j) 132kV Above													
1	29.07.2022	5:48 hrs	29.07.2022	6:19 hrs	0	-4.65	400/220 kV ICT	Jigmeling Substation		87/87NLV			
2	03.07.2022	13:40 hrs	03.07.2022	16:20 hrs	0	-39.250	220kV ICT-1	Jigmeling Substation		Main 1&2 86.1&2 trip and RYBph trip	Main 1 Fault current I _a = 2.94kA at distance 10.8km. Main 2 Fault distance 10.8km.		
3	07.07.2022	06:17 hrs	07.07.2022	06:23 hrs	0	35.180	220kV Dagapela Feeder	Dagapela Substation	Earth fault(YBph to Ground)	Main 1 & 2 (YBph Trip and Z1 trip, Zone1 trip.	Main 1 & 2 Fault Current I _a = 10.4kA, I _b = 7.45kA, I _c = 7.35kA, Fault distance 7.3km.		
4	08.07.2022	19:48 hrs	08.07.2022	19:59 hrs	0	-15.700	220kV Tawang Feeder	Jigmeling Substation	Earth fault(L1L2- Ground)	Main 1 & 2 (L1L2-G Trip), Zone1 trip.	Main 1 & 2 Current I _a = 3.71kA, I _b = 0.14kA, I _c = 3.97kA, Fault distance (Z1) 17.6km.		
5	08.07.2022	19:50 hrs	08.07.2022	20:00 hrs	0	32.470	220kV Dagapela Feeder	Dagapela Substation	Earth fault(L1L3- Ground)	Main 1 & 2 (L1L3-G Trip), Zone1 trip.	Main 1 & 2 Current I _a = 3.80 kA, I _b = 0.11kA, I _c = 3.78kA, Fault distance 5.88km(Z1) & 3.79(Z1.2)		
6	09.07.2022	02:18 hrs	09.07.2022	02:33 hrs	0	48.100	220kV Tawang Feeder	Jigmeling Substation	Earth fault(B phase to Ground)	Main 1 (R,V & B phase trip, Zone1 trip Main 2 (R,V & B phase trip, Zone1 trip	Main 1 Fault distance 17.6km Main 2 Fault distance 17.56km		
7	09.07.2022	02:20 hrs	09.07.2022	02:34 hrs	0		220kV Dagapela Feeder	Dagapela Substation	Earth fault(Y phase to Ground)	Main 1 (R & Y phase trip, Zone1 trip Main 2 (R & Y phase trip, Zone1 trip	Main 1 Fault distance 10.9km Main 2 Fault distance 14.65km		
8	09.07.2022	19:54 hrs	09.07.2022	20:02 hrs	0	61.490	220kV Tawang Feeder	Jigmeling Substation	R,B phase to ground loop	R,B phase (Z1 Trip, I _a = 3.03kA, I _b = 0.17kA, I _c = 1.66kA, 50N/51N trip, main 1&2 trip.	Fault Dist-11.1km		
9	20.07.2022	19:54 hrs	20.07.2022	20:05 hrs	0	44.570	220kV Dagapela Feeder	Dagapela Substation	R,B phase to ground loop	R,B phase (Z1 Trip, I _a = 3.47kA, I _b = 0.28kA, I _c = 3.51kA, 50N/51N trip, main 1 and 2 88.1 & 2 trip.	Fault Dist-9.4KM		
10	21.07.2022	19:17hrs	21.07.2022	20:27hrs	1		220kV Bus Coupler	Jigmeling Substation	Over Current	50 trip			
11	22.07.2022	19:08hrs	22.07.2022	19:23hrs			220kV Bus Coupler	Jigmeling Substation	Over Current	50 trip			
12	03.07.2022	14:05 hrs	03.07.2022	14:12 hrs	0	45.06	132kV Tugthi feeder	Tugthi Substation	RYB phase trip.	Main 1&2 86.1&2 trip, RYB phase trip, Z1 trip.	Fault Current I _a = 3.74kA, I _b = 3.95kA, I _c = 3.81 kA, Distance = 10.8km.	Transient	
13	03.07.2022	15:40 hrs	03.07.2022	18:20	0	39.49	132kV ICT-1	Jigmeling Substation		Main 1&2 86.1&2 trip and RYBph trip		Transient	
14	08.07.2022	20:28 hrs	08.07.2022	20:36 hrs	0	35.17	132kV Tugthi feeder	Tugthi Substation	Earth fault (L2L3-G)	Main 1 optd, L2L3-G Trip, Zone1 trip.	Main 1 Current I _a = 0.17kA, I _b = 2.05kA, I _c = 2.18kA, Fault distance 8.00km(Z1.1)	Transient	
15	08.07.2022	20:30 hrs	08.07.2022	20:35 hrs	0	20.94	132kV Gelephu feeder	Gelephu Substation	Earth fault (L2L3-G)	Main 1&2 optd, L2L3-Genoed Trip, Zone1 trip.	Fault distance (Z1.1): 50km.	Transient	
16	24.07.2022	16:08hrs	24.07.2022	16:20hrs	0	31.66	132kV Tugthi feeder	132kV Tugthi feeder	Earth fault (L1L2-G)	Main 1&2 optd, L1L2-Genoed Trip, Zone1 optd.	Fault distance 5.00km.	Transient	
17	24.07.2022	16:11hrs	24.07.2022	16:37hrs	0	19.95	132kV Gelephu feeder	Gelephu Substation	Earth fault (L1L2L3)	Main 1&2 optd, L1L2L3 Trip, Zone1 optd.	Fault distance 6.4km.	Transient	



Transmission System Performance Report 2022

2. 220/66/33kV Dhajay Substation													
i) 66kV and above													
1	08.07.2022	19:48hrs	08.07.2022	19:58hrs	0	20.82	Tsirang-Jigmeling	Dhajay Substation	Main 1- Ia=1.86kA, Ib=0.01kA, Ic=1.87kA with distance 30.3kM. Main 2- Ia=1745.84A, Ib=103.89A, Ic=1873.28A with distance 30.38KM.	Distance relay Main 1&2(Q1.1&21.2)	Line segment	Tripped	Feeder restored after BPSO instructions.
2	09.07.2022	2:18:05hrs	09.07.2022	2:32:30hrs	0	20.82	Tsirang-Jigmeling	Dhajay Substation	Main 1- Ia=2.01kA, Ib=1.25kA, Ic=2.09kA with distance 31kM. Main 2- Ia=2043.55A, Ib=1029.94A, Ic=2093.24A with distance 17KM.	Distance relay Main 1&2(Q1.1&21.2)	Line segment	Tripped	Feeder restored after BPSO instructions.
3	20.07.2022	19:52hrs	20.07.2022	20:00hrs	0	61.58	Tsirang-Jigmeling	Dhajay Substation	Main 1- Ia=2.24kA, Ib=0.01kA, Ic=0.01kA with distance 47.21kM. Main 2- Ia=2051.34A, Ib=177.28, Ic=1681.48A, In=1663.12A with distance 31KM.	Distance relay Main 1&2(Q1.1&21.2)	Line segment	Tripped	Feeder restored after BPSO instructions.
3. 132/66/33/11kV Gelephu Substation													
i) 66kV and above													
1	08.07.2022	20.29hrs	08.07.2022	21.39hrs	1	24	132kv Sal-Gelephu ss		heavy lightning	o/c on ABC - phase IA=160.5A, IB=1595KA, IC=1.44 SKA		Temporary	Charging Code: NLDC BTN=1689, NLDC IND=430 & NERLDC=4125. At the same time 132kv Gel-Jig line also tripped from Jigmeling end weather was heavy raining, thunder & lightning
2	24.07.2022	16.06hrs	24.07.2022	16.55hrs		15	132kv Sal-Gelephu ss		heavy lightning	o/c on ABC - phase IA=1.618KA, IB=1.700KA, IC=1.741KA		Temporary	Charging Code: NLDC BTN=1808, NLDC IND=1275 & NERLDC=1681. At the same time 132kv Gel-Jig line also tripped from Jigmeling end & charged back at 16.35hrs
3	24.07.2022	17.12hrs	24.07.2022	19.26hrs	2	12	132kv Gel-Jel	Non	Isolator clamp burnt	hit down taken by	Gelephu ss	Temporary	Due to burnt (spark) on R phase line isolator Opening code: NLDC BTN=0892 & Closing code: NLDC BTN=1810. Sabkati was normal so the customer were not affected during that emergency shutdown.
4	24.07.2022	19.40hrs	24.07.2022	20.50hrs	1	12	132kv Gel-Jel	Non	Isolator clamp burnt	hit down taken by	Gelephu ss	Temporary	Due to burnt (spark) on Y phase line isolator Opening code: NLDC BTN=0894 & Closing code: NLDC BTN=1815. customer was not affected as sabkati was there.



Transmission System Performance Report 2022

4. 112.23kV Thimbi Substation											
3 66kV & Above											
1	03.07.2022	1404	03.07.2022	1413	0	-44.57	Tugthi-Sprangthi-3p	Temporary Fault	Distance- Relay Start Phase=ABC, Tri p Phase=ABC, Fault zone-1 trip, Fault Location:18.84kM	18.84kM	Temporary
2	03.07.2022	1613	03.07.2022	1618	0	14.96	Tugthi-sangthi-sae	Temporary Fault	Distance- Relay Start Phase=ABCN, Tri p Phase=ABC, Fault zone-1 trip, Fault Location:55.81kM	55.81kM	Temporary
3	06.07.2022	07.50	06.07.2022	08.03	0	2.36	Tugthi-sangthi-sae	Temporary Fault	Distance- Relay Start Phase=ABCN, Tri p Phase=ABC, Fault zone-1 trip, Fault Location:51.81kM	51.91kM	Temporary
4	08.07.2022	20.28	08.07.2022	20.28	0	-21.54	Tugthi-Sprangthi-3p	Temporary Fault	Distance- Relay Start Phase=BCN, Trip Phase=ABC, Fault zone-1 trip, Fault Location:22.89kM	22.89kM	Temporary
5	08.07.2022	22.16	08.07.2022	22.26	0	22.26	Tugthi-sangthi-sae	Temporary Fault	Distance- Relay Start Phase=ABCN, Tri p Phase=ABC, Fault zone-1 trip, Fault Location:32.17kM	32.17kM	Temporary
6	08.07.2022	22.34	08.07.2022	22.43	0	15.54	Tugthi-sangthi-sae	Temporary Fault	Distance- Relay Start Phase=DN, Trip Phase=ABC, Fault zone-1 trip, Fault Location:10.29kM	10.29kM	Temporary
7	08.07.2022	22.47	08.07.2022	22.59	0	14.54	Tugthi-sangthi-sae	Temporary Fault	Distance- Relay Start Phase=ABCN, Trip Phase=ABC, Fault zone-1 trip, Fault Location:53.47kM	53.47kM	Temporary
8	08.07.2022	15.15	08.07.2022	15.31	0	32.44	Tugthi-Sprangthi-3p	Temporary Fault	Distance- Relay Start Phase=BCN, Trip Phase=ABC, Fault zone-1 trip, Fault Location:17.34kM	17.34kM	Temporary
9	08.07.2022	15.32	08.07.2022	16.24	0	-32.2	Tugthi-Sprangthi-3p	Temporary Fault	Distance- Relay Start Phase=BCN, Trip Phase=ABC, Fault zone-1 trip, Fault Location:17.76kM	17.76kM	Temporary
10	24.07.2022	02.10	24.07.2022	02.20	0	19.66	Tugthi-sangthi-sae	Temporary Fault	Distance- Relay Start Phase=ABCN, Trip Phase=ABC, Fault zone-1 trip, Fault Location:19.69kM	19.69kM	Temporary
11	24.07.2022	14.36	24.07.2022	14.47	0	13.61	Tugthi-sangthi-sae	Temporary Fault	Distance- Relay Start Phase=AN, Trip Phase=ABC, Fault zone-1 trip, Fault Location:XY 19.76kM	19.76kM	Temporary
12	24.07.2022	16.09	24.07.2022	16.19	0	30.01	Tugthi-Sprangthi-3p	Temporary Fault	Distance- Relay Start Phase=ABCN, Tri p Phase=ABC, Fault zone-1 trip, Fault Location:24.49kM	24.49kM	Temporary



Transmission System Performance Report 2022

6. 220/33kV Dagapela Substation													
i) 66kV & Above													
1	07.07.2022	06:15hrs	7.07.2022	06:25hrs	0	-34.99	220kV limelng	Dagapela Substation	Earth fault	Master trip relay optd	zone 1 at the distance of 7.2 km(Y&B phase)	Grid fail	Tripped from limelng end due to o/c
2	8.07.2022	17:48hrs	8.07.2022	20:02hrs	2	-32.13	220kV limelng	Dagapela Substation	L1 L3 phase to ground/Earth fault	Master trip relay optd		Grid fail	Tripped from limelng end due to o/c
3	9.07.2022	02:22hrs	9.07.2022	02:34hrs	0	-34.43	220kV limelng	Dagapela Substation	R&Y phase	Master trip relay optd	zone	Grid fail	Tripped from limelng end due to o/c
4	20.07.2022	19:53hrs	20.07.2022	20:04hrs	0	-43.84	220kV limelng	Dagapela Substation	R&B to ground	Master trip relay optd	distance at 9.4km	Grid fail	Tripped from limelng end due to o/c

August 2022

Division: IMD DROTHANG																
Substation: 132/33/11kV Khamyang Substation 466-22																
Month: Aug-22																
Sl. No.	Name of Feeder	Voltage Level	Type of Change (Shutdown/Tripping)	Shutdown/Tripping Time		Synchronization Time		Duration of Outage		MVA before Outage (MVA)	Protection Relay Optd (Status of relay)	Tripping Details (Fault Details (As recorded by relay))	Type/Cause of Fault (If tripped)	Reason for Shutdown	WSPM/Condition during the Outage	Remarks
132kV																
2	Khamyang-Phuntsho Line	132	tripping	07/08/2022	08:00	07/08/2022	08:00	0	0	17.11	NA	NA	NA	NA	Clear	Grid fail
4	Khamyang-Phuntsho Line	132	tripping	08/08/2022	07:00	08/08/2022	07:24	0	0	13.04	Distance relay optd	Distance relay optd	Due to lightning	NA	Clear	Due to lightning it causes to get the protection from BPSO without changing case

Division: IMD DROTHANG																
Substation: 132/33/11kV Nangyal Substation 466-01																
Month: Aug-22																
BPSO-SAMD 132kV-NAN-2022 (SUMOR)																
Sl. No.	Name of Feeder	Voltage Level	Type of Change (Shutdown/Tripping)	Shutdown/Tripping Time		Synchronization Time		Duration of Outage		MVA before Outage (MVA)	Protection Relay Optd	Tripping Details (Fault Details (As recorded by relay))	Type/Cause of Fault	Reason for Shutdown	WSPM/Condition during the Outage	Remarks
132kV Feeder																
1	132/33kV-5MVA Td-1	132kV	Tripping	08-08-2022	10:19 hrs	08-08-2022	10:22 hrs	0	2	0.286	Non-directional DMAT relay optd	O/C side-50C & trip order/66 operated	Tripped on feeder fault	NA	Clear	Tripped due to fault on 33kV Turbine feeder
2	132/33kV-5MVA Td-2	132kV	Tripping	08-08-2022	10:19 hrs	08-08-2022	10:23 hrs	0	3	0.238	Non-directional DMAT relay optd	O/C side-50C & trip order/66 operated	Tripped on feeder fault	NA	Clear	Tripped due to fault on 33kV Turbine feeder
3	132/33kV-5MVA Td-1	132kV	Tripping	11-08-2022	18:55 hrs	11-08-2022	18:59 hrs	0	5	0.427	Non-directional DMAT relay optd	O/C side-50C & trip order/66 operated	Tripping on feeder fault	NA	Clear	Tripped at the instance of changing 132V Nangyal feeder
4	132/33kV-5MVA Td-2	132kV	Tripping	11-08-2022	18:55 hrs	11-08-2022	18:57 hrs	0	6	0.42	Non-directional DMAT relay optd	O/C side-50C & trip order/66 operated	Tripped on feeder fault	NA	Clear	Tripped at the instance of changing 132V Nangyal feeder
5	Nangyal-Nangyal Line	132kV	Tripping	11-08-2022	03:13 hrs	11-08-2022	03:13 hrs	0	1	4.35	NA	NA	NA	Heavy manual	Referenced to BPSO & cleared the CB	
6	Nangyal-Nangyal Line	132kV	Tripping	11-08-2022	03:47 hrs	11-08-2022	03:47 hrs	1	63	8.35	NA	NA	NA	Heavy manual	Referenced to BPSO & cleared the CB	
8	Nangyal-Nangyal Line	132kV	Tripping	11-08-2022	08:54 hrs	11-08-2022	08:57 hrs	2	41	-6.35	NA	NA	NA	Heavy manual	Referenced to BPSO. Due to heavy maintenance to Turbine side held. Checked the circuit breaker after opened and found ok & cleared the CB	
10	Nangyal-Nangyal Line	132kV	Tripping	11-08-2022	09:41 hrs	11-08-2022	15:03 hrs	5	22	9.57	NA	NA	NA	Heavy manual	Due to heavy maintenance the tower base dropped into CB mechanism from 8 to 10 m height. Heavy manual	

Division: IMD DROTHANG																
Substation: 132/33/11kV Drothang Substation 466-01																
Month: Aug-22																
Sl. No.	Name of Feeder	Voltage Level	Type of Change (Shutdown/Tripping)	Shutdown/Tripping Time		Synchronization Time		Duration of Outage		MVA before Outage (MVA)	Protection Relay Optd	Tripping Details (Fault Details (As recorded by relay))	Type/Cause of Fault	Reason for Shutdown	WSPM/Condition during the Outage	Remarks
4	Transmision (A & B) 750kV	110V	tripping	08/08/2022	11:54	08/08/2022	11:58	0	0	NA	NA	NA	NA	NA	NA	Due to change done and final normal
10	BDVA Transmision A	110V	tripping	14/08/2022	06:00	14/08/2022	06:00	0	0	0.042	Ground/Distance relay at 200V bus, was after	NA	NA	NA	Clear	Due to change done final normal
10	BDVA Transmision B	110V	tripping	03/08/2022	06:00	03/08/2022	06:00	0	1	0.031	Ground/Distance relay at 200V bus, was after	NA	NA	NA	Clear	Due to change done final normal
21	BDVA Td-1	110V	tripping	21/08/2022	19:01	21/08/2022	19:20	0	0	1.344	NA	NA	NA	NA	Clear	Tripped due to lightning. CB Trip change done final normal
18	BDVA Td-2	110V	tripping	21/08/2022	19:01	21/08/2022	19:20	0	0	1.308	NA	NA	NA	NA	Clear	Tripped due to lightning. CB Trip change done final normal
48	Shangluo-Drothang LC	110V	Shutdown	21/08/2022	08:20	25/08/2022	18:55	8	35	-48.132	NA	NA	NA	NA	Clear	The BPSO working from localities from 20:45 to 12



Transmission System Performance Report 2022

Division		SMD DEOTRANG									
Substation		132/33kV Nganglam Substation									
Month		SEP									
Sl.No	Substation Name (Select from list)	Feeder Name (Select from list)	Outage Reason (Select from list)	Fault Location (Select from list)	Tripping Date & Time (dd/mm/yyyy hh:mm:ss)	Normalization Date & Time (dd/mm/yyyy hh:mm:ss)	Customers affected (Yes/No)?	Remark	Outage Duration (hh:mm:ss)	Outage in Minutes (r)	No. of Customers Interrupted (N)
02	Nganglam	132kV Nganglam-DCCL Factory	Fault	Transmission Line	01-09-2022 09:11:00	01-09-2022 09:14:00	Yes	Tripped on Overcurrent & Earth Fault (50A & 50C)	00:03:00		1
03	Nganglam	132kV Nganglam-DCCL Factory	Fault	Transmission Line	01-09-2022 07:14:00	01-09-2022 07:26:00	Yes	Tripped on Overcurrent & Earth Fault (50A & 50C)	00:12:00		130
09	Nganglam	132kV Nganglam-Thinbi	Fault	Transmission Line	03-09-2022 10:44:00	03-09-2022 10:53:00	No	Tripped on Earth Fault Fault details: IA= 447.5A IB= 7.227A IC= 5.759A IM= 437.4A VAM= 111.8kV VBM= 131.5kV VCM= 125.2kV	00:09:00		0
14	Nganglam	132kV Nganglam-Thinbi	Fault	Transmission Line	06-09-2022 12:16:00	06-09-2022 12:22:00	No	Tripped on over current. Ready opted BS Fault Zone-1 Fault: Duration= 76.74ms. Relay tripped time= 80.06ms. Fault loc= 19.2 km. I= 157.9A IB= 2.607KA IC= 137.7A VAM= 137.7A, VBM= 8.001kV VCM= 83.07kV. Fault Resistance= 1.60 Ohm	00:12:00		0
15	Nganglam	132/33kV, SMVA Transformer-1	Fault	Substation	06-09-2022 12:10:00	06-09-2022 12:14:00	Yes	Tripped due to 132 kV Nganglam-Thinbi	00:04:00		3244
29	Nganglam	132/33kV, SMVA Transformer-1	Fault	Distribution Line	14-09-2022 14:24:00	14-09-2022 14:27:00	Yes	Tripped on Overcurrent	00:03:00		3244
30	Nganglam	132/33kV, SMVA Transformer-1	Fault	Substation	14-09-2022 14:27:00	14-09-2022 14:30:00	Yes	Tripped on overcurrent due to 33kV Druk GYP feeder. Feeder CB not Operated	00:03:00		3244
36	Nganglam	132/33kV, SMVA Transformer-1	Fault	Substation	15-09-2022 15:16:00	15-09-2022 15:18:00	Yes	SMVA Tr-1 (LV) side tripped due to 33kV DCL Err on B/F	00:02:00		3244
37	Nganglam	132/33kV, SMVA Transformer-1	Fault	Distribution Line	18-09-2022 06:45:00	18-09-2022 06:47:00	Yes	SMVA Tr-1 (HV) & LV tripped due to 33kV Dechebang feeder	00:02:00		1458
42	Nganglam	132/33kV, SMVA Transformer-1	Fault	Distribution Line	20-09-2022 07:10:00	20-09-2022 07:22:00	Yes	Tripped on Overcurrent due to 33kV Paabang feeder fault while extending supply from Thinbiang LDC	00:04:00		338
51	Nganglam	132/33kV, SMVA Transformer-1	Fault	Distribution Line	23-09-2022 11:41:00	23-09-2022 11:52:00	Yes	Tripped due to 33kV Dechebang Feeder Fault	00:11:00		3244
52	Nganglam	132/33kV, SMVA Transformer-1	Fault	Distribution Line	23-09-2022 22:12:00	23-09-2022 22:13:00	Yes	Tripped on Overcurrent. The SMVA Tr-1 is kept in Idle Charged and SMVA Transformer is put in service	00:01:00		3244
53	Nganglam	132/33kV, SMVA Transformer-2	Shutdown	Distribution Line	23-09-2022 18:25:00	23-09-2022 18:26:00	No	SMVA Transformer was put in Parallel with SMVA transformer after the installation of 2No. of CB Interrupter at SMVA Tr-1 LV side and SMVA Transformer was kept in Idle charged	00:01:00		0
67	Nganglam	132kV Nganglam-Nanghor	Shutdown	Transmission Line	31-09-2022 04:02:00	31-09-2022 05:50:00	No	CB could not Closed at Nanghor end after tripping. BPSO instructed us to Open CB at our end and Closed first at Nanghor end	01:45:00		0
68	Nganglam	132kV Nganglam-Nanghor	Shutdown	Transmission Line	31-09-2022 13:30:00	31-09-2022 15:03:00	No	To do CB maintenance at Nanghor 5/C	01:33:00		0



Transmission System Performance Report 2022

Division:		SMD/OT/TRA/NO		Substation:		DZARA Miranga Substation		Date: 01.08.2022							
Main:															
Sl. No.	Name of Feeder	Voltage Level	Type of Charge (Shutdown/Type)	Shutdown/Trapping Time		Notification Time		Duration of Outage (Hrs)	MW before Outage (MW)	Protection Relay Oper	Tripping Details	Type/Cause of Fault	Reason for Shutdown	Operator/Condition	Remarks
				Date	Time	Date	Time								
1	15MVA Transformer	132kV	Tripping	02-08-2022	20:48 hrs	02-08-2022	20:42 hrs	0	0.22	EDIPROCI, REF151	Directional-O/C & R/F Relay: Tripped on D.F. & O.C. I1= 806.92A, I2= 242.57A, I3= 208.11A, Frequency= 49.98Hz. A tripping relay 15.1 B operated at our end.	Tripped by transient fault	-	none	Grid failed. DZARA, Rangaj and P. Thang TB tripped at the same time.
2	Deochang Feeder	132kV	Tripping	03-08-2022	20:00 hrs	03-08-2022	20:00 hrs	0	55.3	EDIPROCI, REF151	Directional-O/C & R/F Relay: Tripped on D.F. & O.C. I1= 275A, I2= 308.4A, I3= 205.6A, Frequency= 49.98Hz. A tripping relay 15.1 B operated at our end.	Tripped by transient fault	-	none	Coordinated with BPSO and P. Thang TB tripped at the same time.
3	Phantshong Feeder	132kV	Tripping	03-08-2022	20:09 hrs	03-08-2022	20:09 hrs	0	17.71	EDIPROCI, REF151	Directional-O/C & R/F Relay: Tripped on D.F. & O.C. I1= 708.1A, I2= 71.6A, I3= 55.1A, Frequency= 50.37Hz. A tripping relay 15.1 B operated at our end.	Tripped by transient fault	-	None	Coordinated with BPSO about the charging impedance of feeder. Checked as per field instruction.
4	Rangaj Feeder	132kV	Tripping	03-08-2022	20:40 hrs	03-08-2022	21:12 hrs	0	48.31	EDIPROCI, REF151	Directional-O/C & R/F Relay: Tripped on D.F. & O.C. I1= 427.2A, I2= 172.5A, I3= 200A, Frequency= 49.98Hz. A tripping relay 15.1 B operated at our end.	Tripped by transient fault	-	None	Change code: BPSO/15/1, 30.1/DC, DZARA, 101 and 100/1/DC, DZARA/101
5	15MVA Transformer	132/33kV	Tripping	06-08-2022	00:59 hrs	06-08-2022	00:59 hrs	0	11	EDIPROCI, REF151	Directional-O/C & R/F Relay: Tripped on D.F. & O.C. I1= 951A, I2= 946A, I3= 0.65A, Frequency= 50.37Hz. A tripping relay 15.1 B operated at our end.	Tripped by transient fault	-	None	Checked by verbal instruction from BPSO.
6	15MVA Transformer	132/33kV	Tripping	12-08-2022	12:44 hrs	12-08-2022	12:50 hrs	0	0.17	Directional protection, REF150	O/C & R/F Relay: Tripped on D.F. & O.C. I1= 951A, I2= 946A, I3= 0.65A, Frequency= 50.37Hz. A tripping relay 15.1 B operated at our end.	Transformer fault	-	none	-
7	Phantshong Feeder	132kV	Shutdown	15-08-2022	09:07 hrs	15-08-2022	17:31 hrs	8	-16.52	-	-	-	Ex. clearing fault of wire off line	none	Shutdown taken by TLMSD, Phantshong
8	15MVA Transformer	132/33kV	Tripping	18-08-2022	20:21 hrs	18-08-2022	20:21 hrs	0	10	Directional protection, REF150	Directional-O/C & R/F Relay: Tripped on D.F. & O.C. I1= 10.5A, I2= 711.5A, I3= 215.5A, Frequency= 49.97Hz. A tripping relay 15.1 B operated at our end.	Transformer fault	-	none	checked
9	Phantshong Feeder	132kV	Tripping	21-08-2022	17:18 hrs	21-08-2022	17:21 hrs	0	-17.84	DETLPCF1, REF151	Directional-O/C & R/F Relay: Tripped on D.F. & O.C. Frequency= 50.02Hz. A tripping relay 15.1 B operated at our end.	Transformer fault	-	critical	At 17:18hrs 132kV Deochang and Phantshong Feeder tripped at the same time. The fault was cleared by the grid back of line & coordinated with BPSO.
10	Deochang Feeder	132kV	Tripping	21-08-2022	17:18 hrs	21-08-2022	17:21 hrs	0	-48.14	DETLPCF1, REF151	Directional-O/C & R/F Relay: Tripped on D.F. & O.C. Frequency= 50.02Hz. A tripping relay 15.1 B operated at our end.	Transformer fault	-	critical	Change code: 101.
11	15MVA Transformer	132/33kV	Tripping	23-08-2022	11:54 hrs	23-08-2022	11:27 hrs	0	3.4	Directional protection, REF150	Tripping relay 15.1 B and 15.1 B tripped.	-	-	none	Checked the transformer by verbal instruction from BPSO.
12	15MVA Transformer	132/33kV	Tripping	28-08-2022	17:09 hrs	28-08-2022	17:28 hrs	0	19	Directional protection, REF150	Directional-O/C & R/F Relay: Tripped on D.F. & O.C. I1= 1.42A, I2= 1.2A, I3= 0.4A, Frequency= 49.98Hz. A tripping relay 15.1 B operated at our end.	Transformer fault	-	none	coordinated with BPSO and changed.
13	15MVA Transformer	132/33kV	Tripping	29-08-2022	16:20 hrs	29-08-2022	16:21 hrs	0	0.30	Directional protection, REF150	Tripping relay 15.1 B and 15.1 B tripped.	-	-	none	coordinated with BPSO and changed.
14	15MVA Transformer	132/33kV	Tripping	31-08-2022	11:56 hrs	31-08-2022	11:42 hrs	0	0.29	Directional protection, REF150	Tripped on O.C. & R/F. 50.51 Hz. STP protection trip.	Transformer fault	-	none	coordinated with BPSO and changed.
15	15MVA Transformer	132/33kV	Tripping	31-08-2022	18:43 hrs	31-08-2022	18:43 hrs	0	0.06	Directional protection, REF150	Tripped on O.C. & R/F. 50.51 Hz. STP protection trip.	-	-	none	-



Transmission System Performance Report 2022

September 2022

Division		Substation		Month		Station/Trapping Time		Name/Location Time		Duration of Outage		MW Losses	Protection Relay Oper	Tripping Details	Type/Cause of Fault	Reason for Shutdown	Weather Condition during the	Remarks
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Trapping)	Date	Time	Date	Time	(From)	(To)	(MW)	(MW)	(MW)	(MW)	Event Details (As recorded by relay)	(If tripped)	(If shutdown)	(If cloudy)	
Division: SMO BIZTRANG Substation: IME331110V Rangjung Substation Month: Sep 22																		
1	Chering	132	Tripped	08/30/2022	15:56	08/30/2022	18:19	2	14	-19.332	11.569		Distance Relay Oper	Shard place = A, N, Ia = 307.5A, IB= 103.1A, IC = 106.4A, ID = A, Fault Location = 1.314km, Fault n = 2km.	B phase line breaker punctured and tripped on B phase CT removal malfunction	NA	Cloudy	Supply tripped on Distance relay operated and B phase line breaker punctured and tripped on B phase CT removal and main bus. In long under tripped position and done the re-energizing work. Charging Code from BPSO: 257 (Max. Karma Yangtse)
2	Phantochang	132	Tripped	08/30/2022	15:56	08/30/2022	18:19	2	14	11.289			GR - A-B Trip relay operated	B phase line breaker punctured and tripped on B phase CT removal malfunction	NA	Cloudy	Supply tripped on Distance relay operated and B phase line breaker punctured and tripped on B phase CT removal and main bus. In long under tripped position and done the re-energizing work. Charging Code from BPSO: 257 (Max. Karma Yangtse)	
Division: SMO BIZTRANG Substation: IME331110V Rangjung Substation Month: SEPT																		
BPC SMD 132KV S/S#2412/65/91																		
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Trapping)	Date	Time	Date	Time	(From)	(To)	(MW)	Losses (MW)	Protection Relay Oper	Tripping Details	Type/Cause of Fault	Reason for Shutdown	Weather Condition during the	Remarks	
132KV Feeder																		
1	Shangtse-Dorshang Line	132kV	Tripping	04/09/2022	03:43 hrs	04/09/2022	03:59 hrs	0	14	42.0		MCOMF43 Agle	Distance Relay Relay: Trip @ ASD: start @ ABCN. Start distance Distance. TOC start. Distance trip #1. Fault distance 80.9km, fault location= 77.9KM, LB=1.302A, IB=1.412A, IC=1.318KA, VAN=7.24KV, VBN=7.22KV, VCN=7.93KV, fault resistance=11.8MΩ & trip relay #5	Tripped on fault		Heavy rainfall with thunder & lightning	Referenced to BPSO & changed the feeder	
2	Shangtse-Dorshang Line	132kV	Tripping	04/09/2022	05:41 hrs	04/09/2022	05:47 hrs	0	4	44.5		MCOMF43 Agle	Distance Relay Relay: Trip @ R start @ BSN. Start distance Distance. TOC start. Distance trip #1. Fault distance=69.9km, fault location=20.8KM, Ia=72.0KA, Ib=1.77KA, IC=200.7A, VAN=7.92KV, VBN=7.13KV, VCN=66.2KV, fault resistance=7.43MΩ	Tripped on fault		Heavy rainfall with thunder & lightning	Referenced to BPSO & changed the feeder	
3	Shangtse-Dorshang Line	132kV	Tripping	04/09/2022	05:51 hrs	04/09/2022	10:17 hrs	4	20	44.5		MCOMF43 Agle	Distance Relay Relay: Trip @ R start @ BSN. Start distance Distance. TOC start. Distance trip #1. Fault distance=69.9km, fault location=20.8KM, Ia=1.17KA, Ib=1.97KA, IC=1.06KA, VAN=7.73KV, VBN=7.13KV, VCN=67.7KV, fault resistance=1.59MΩ	Tripped on fault		Heavy Rainfall	Referenced to BPSO & no auto reclosed but charged at 05:56 hrs & 06:51 hrs but couldn't start charging once fault	
4	Shangtse-Dorshang Line	132kV	Tripping	04/09/2022	23:55 hrs	05/08/2022	15:03 hrs	15	14	43.0		MCOMF43 Agle	Distance Relay Relay: Trip @ R start @ BSN. Start distance Distance. TOC start. Distance trip #1. Fault distance=78.9km, relay trip time=78.9km, fault location=23.88KM, Ia=124.7A, Ib=1.74KA, IC=285.1A, VAN=7.63KV, VBN=7.13KV, VCN=66.95KV, fault resistance=1.05MΩ	Tripped on fault		Heavy Rainfall	Referenced to BPSO & no auto reclosed but charged at 23:59 hrs & 06:23 hrs of 06/09/2022 but couldn't start charging once fault	
5	132KV SMD A-I	132kV	Tripping	08/08/2022	11:11 hrs	08/08/2022	11:24 hrs	0	2	0.54			Tripping relay #6 operated	Tripped on feeder fault		Cloudy	Tripped at the instant of 132KV Yarang feeder tripping	
6	132KV SMD A-II	132kV	Tripping	08/08/2022	11:11 hrs	08/08/2022	11:27 hrs	0	2	0.49		Non directional PROCN Relay operated	O/C relay-50A & trip relay #6 operated	Tripped on feeder fault		Cloudy	Tripped at the instant of 132KV Yarang feeder tripping	
7	132KV SMD A-I	132kV	Tripping	08/08/2022	12:51 hrs	08/08/2022	12:55 hrs	0	2	0.45		Non directional PROCN Relay operated	O/C relay-50A & trip relay #6 operated	Tripped on feeder fault		Cloudy	Tripped at the instant of 132KV Yarang feeder tripping	
8	132KV SMD A-II	132kV	Tripping	08/08/2022	12:51 hrs	08/08/2022	12:54 hrs	0	4	0.27		Non directional PROCN Relay operated	O/C relay-50A & trip relay #6 operated	Tripped on feeder fault		Cloudy	Tripped at the instant of 132KV Yarang feeder tripping	
9	Shangtse-Dorshang Line	132kV	Tripping	22/08/2022	06:20 hrs	22/08/2022	08:73 hrs	4	39	46.8		MCOMF43 Agle	Top @ R start @ BSN. Start distance Distance. TOC start. Distance trip #1. Fault distance=75.0km, relay trip time=80.0km, fault location=20.8KM, Ia=114.1A, Ib=1.77KA, IC=241.7A, VAN=6.45KV, VBN=7.12KV, VCN=66.8KV, fault resistance=7.31MΩ	Tripped on fault		Rainfall	Referenced to BPSO & line charged at 04:24 hrs & 07:09 hrs, but couldn't start	
10	Shangtse-Dorshang Line	132kV	Tripping	21/09/2022	07:00 hrs	22/09/2022	07:31 hrs	0	10	77.9		MCOMF43 Agle	Top @ ASD: start @ BSN. Start distance Distance. TOC start. Distance trip #1. Fault distance=106.0km, relay trip time=78.9km, fault location=21.10KM, Ia=100.0A, Ib=1.18KA, IC=254.1A, VAN=6.85KV, VBN=7.15KV, VCN=64.81KV, fault resistance=1.01MΩ, Fault size=2	Tripped on fault		Rainfall	Referenced to BPSO & changed the feeder.	



Transmission System Performance Report 2022

Division:		SMD-DEOTHANG									
Substation:		132/33/11kV Nganglam Substation									
Month:		#REF!									
SL.No	Substation Name (Select from list)	Feeder Name (Select from list)	Outage Reason (Select from list)	Fault Location (Select from list)	Tripping Date & Time (dd/mm/yyyy hh:mm:ss)	Normalization Date & Time (dd/mm/yyyy hh:mm:ss)	Customers affected (Yes/No)?	Remarks	Outage Duration(hh:mm:ss)	Outage in Minuts(ri)	No. of Customers Interrupted (Ni)
3	Nganglam	132/33kV, 3MVA Transformer-2	Fault	Transmission Line	02-09-2022 18:01	02-09-2022 18:05	No	Tripped due to 33kv Panabug feeder	00:04:00	4	0
14	Nganglam	132kV Nganglam-Tutibi	Fault	Transmission Line	08-09-2022 11:29	08-09-2022 11:42	No	feeder tripped due to earth fault. 86 relay operated, IA=472.7A, IB=57.17A, IC=74.40A, IN=530.1A, VAN=109.6kv, VBN=77.98kv, VCN=125.2kv	00:13:00	13	0
15	Nganglam	132kV Nganglam-Tutibi	Fault	Transmission Line	08-09-2022 12:03	08-09-2022 12:09	No	Fdr Tripped due to Earth fault. 86 relay operated, IA=382.7A, IB=55.87A, IC=66.53A, IN=438.7A	00:06:00	6	0
52	Nganglam	132kV Nganglam-Tutibi	Fault	Transmission Line	23-09-2022 05:18	23-09-2022 05:23	No	Tripped on Overcurrent. Fault details; IA- 1.435KA IB- 1.360KA IC- 1.352KA IN- 253.5A Fault duration 73.31ms Relay Trip Time 79.98ms Fault Location 4.689km Fault resistance 513.6ms A/R Lookout	00:05:00	5	0
53	Nganglam	132kV Nganglam-Tutibi	Fault	Transmission Line	23-09-2022 05:30	23-09-2022 12:48	No	Tripped on Overcurrent. Fault details; IA- 1.352KA IB- 1.279KA IC- 1.203KA IN- 118.9A Fault duration 73.28ms Relay Trip Time 79.94ms Fault Location 4.913km Fault Resistance 643.8ms	07:18:00	438	0
55	Nganglam	132kV Nganglam-DCCL Factory	Fault	Transmission Line	23-09-2022 05:47	23-09-2022 05:53	Yes	Over Current	00:06:00	6	1
63	Nganglam	132kV Nganglam-Tutibi	Fault	Transmission Line	25-09-2022 02:38	25-09-2022 02:49	No	Earth Fault	00:11:00	11	0



Transmission System Performance Report 2022

Divisions													Date: 01.08.2022				
Substation: 132/33kV Miranga Substation																	
Month: 08/22																	
BDRPC/SMD/MNS/2022/072																	
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Notification Time		Duration of Outage		MW before Outage (MW)	Protection Relay Oper.	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Operator/Condition	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)			Fault Details (As recorded by relay)	Phase				
1	150kV Transmission	112.9kV	Tripping	01-09-2022	15:27 hrs	01-09-2022	15:32 hrs	0	5	0.37	RE1650, transmission differential relay	Tripped on R-F & C-C. IL1= 5.21A, IL2= 6.18A, IL3= 17.26A, Frequency= 49.93Hz & tripping relay 96A & SEF operated at one end	-	-	none	Transformer was tripped while changing of 132kV 5 position feeder. Charged after receiving verbal instruction from BPSO	
2	150kV Transmission	112.9kV	Tripping	01-09-2022	18:51 hrs	01-09-2022	19:51 hrs	0	5	0.25	RE1650, transmission differential relay	Tripped on R-F & C-C. IL1= 4.44A, IL2= 6.17A, IL3= 18.15A, Frequency= 49.91Hz & tripping relay 96A & SEF operated at one end	-	-	none	132kV 5 position feeder was not charged, and the transmission was tripped while not changing the feeder.	
3	150kV Transmission	112.9kV	Tripping	02-09-2022	16:14 hrs	02-09-2022	16:59 hrs	0	5	0.21	DEFLP001, RE1651	Dimensional-GIS & R-F Relay. Tripped on R-F & C-C. IL1= 0.00120k, IL2= 0.018k, IL3= 0.47k, Frequency= 50.11Hz & tripping relay 96A & SEF operated at one end	-	-	none	Tripped while changing 23kV 6 position feeder.	
4	150kV Transmission	112.9kV	Tripping	04-09-2022	23:50 hrs	04-09-2022	23:54 hrs	0	4	1.04	RE1650, transmission differential relay	Dimensional-GIS & R-F Relay. Tripped on R-F & C-C. IL1= 171.91A, IL2= 17.17A, IL3= 12.21A, Frequency= 50.18Hz & tripping relay 96 operated	Tripped by manual fault	-	none	Changed verbally by the instruction of BPSO	
5	Shielding Feeder	132kV	Tripping	04-09-2022	00:18 hrs	04-09-2022	00:24 hrs	0	4	-02.21	DIVLFO001, RE1614	Dimensional-GIS & R-F Relay. Tripped on R-F & C-C. IL1= 3.837kA, IL2= 1.788kA, IL3= 1.517kA, Frequency= 50.11Hz & tripping relay 96A & SEF operated at one end	Tripped by manual fault	-	none	Checked by verbal instruction from BPSO	
6	150kV Transmission	112.9kV	Tripping	05-09-2022	9:30 hrs	05-09-2022	9:33 hrs	0	3	1.25	EHP1001, RE1643	Dimensional-GIS & R-F Relay. Tripped on R-F & C-C. IL1= 0.975kA, IL2= 0.949kA, IL3= 0.948kA, Frequency= 50.10Hz & tripping relay 96A & SEF operated at one end	Transmission fault	-	none	Changed after obtaining verbal clearance from BPSO	
7	150kV Transmission	112.9kV	Tripping	05-09-2022	7:52 hrs	05-09-2022	7:55 hrs	0	3	2.04		Fault values not recorded by the relay. Frequency= 50.18Hz & tripping relay 96A & SEF operated at one end	Transmission fault	-	none	-	
8	150kV Transmission	112.9kV	Tripping	10-09-2022	14:11 hrs	10-09-2022	14:13 hrs	0	3	1.43	EHP1001, RE1643	Dimensional-GIS & R-F Relay. Tripped on R-F & C-C. IL1= 0.497kA, IL2= 0.472kA, IL3= 0.471kA, Frequency= 50.11Hz & tripping relay 96A & SEF operated at one end	Transmission fault	-	clearly	-	
9	150kV Transmission	112.9kV	Tripping	16-09-2022	15:12 hrs	16-09-2022	15:11 hrs	0	19	1.34		Fault values not recorded by the relay. Frequency= 50.18Hz & manual tripping relay 96A operated	Transmission fault	-	none	-	
10	150kV Transmission	112.9kV	Tripping	22-09-2022	05:04 hrs	22-09-2022	05:09 hrs	0	3	0.34		Fault values not recorded by the relay. Frequency= 50.11Hz & manual tripping relay 96A operated	Transmission fault	-	none	Changed after obtaining verbal clearance from BPSO	
11	150kV Transmission	112.9kV	Tripping	29-09-2022	04:14 hrs	29-09-2022	04:20 hrs	0	3	0.14		Fault values not recorded by the relay. Frequency= 50.12Hz & manual tripping relay 96A operated	Transmission fault	-	none	Changed after obtaining verbal clearance from BPSO	
Divisions													Date: 01.08.2022				
Substation: 132/33kV Kamjong Substation																	
Month: 08/22																	
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Notification Time		Duration of Outage		MW before Outage (MW)	Protection Relay Oper.	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Operator/Condition	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)			Fault Details (As recorded by relay)	Phase				
8	152 kV Kamjong Feeder	132 kV	Tripping	08-08-2022	15:53 hrs	08-08-2022	15:03 hrs	2	15	19.725	Distance Relay (R412) and Back up Relay (R100)	Distance Relay (R412) operated in Zone 1. Recorded fault values: Voltage phase ABCN, Tripping phase-A. Shorted distance Distance-Chg voltage stat V _{bc} . Distance Trip Z1, V _{bc} Alarm, System Frequency: 49.85 Hz, Fault duration 2.741 sec, relay trip time: 50.12 sec, Fault location: 10.15 km, I _A : 990A, I _B : 81.16A, I _C : 167.55A, Y _{bc} : 11.81 kV, S _{bc} : 79.58 MV, V _{bc} : 79.54 kV, Fault Resistance: 3.27 Ohm, Fault in Zone-2 sec Backup Relay (R410): Tripped phase-ABC, OC manual-L, L-F 1 sec 20"-1.5 sec, System Frequency: 49.90 Hz, I _A : 919.5A, I _B : 79.89A, I _C : 111.1A, V _{AB} : 81.78 kV, V _{BC} : 112.5 kV, V _{CA} : 84.89 kV, P _S : 877.7 A, 2% Demand: 877.2A, V _{AN} : 12.26kV, V _{BN} : 78.82kV, V _{CN} : 77.58kV, V _{SC} : 20.1kV	Dist. limiter operation at Kamjong Substation	-	clearly	In 15.55 km Kamjong Feeder was trip and returned to BPSO. As per instruction from BPSO this limiter was performed at Kamjong Substation. Line was charged at 18:00 hrs after receiving 60 fault at Kamjong Substation.	
Divisions													Date: 01.08.2022				
Substation: 132/33kV Phunshelkhang Substation																	
Month: 08/22																	
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Notification Time		Duration of Outage		MW before Outage (MW)	Protection Relay Oper.	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Operator/Condition	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)			Fault Details (As recorded by relay)	Phase				
27	Kamjong (KTLA)	132kV	Trip on Fault	08-08-2022	15:35	08-08-2022	15:38	2	14	18.14	TRIP OVSV TRIP 96A and 902	Fault value: IL1: 449.23A, IL2: 240.1A, IL3: 69.5A, I _A : 500.99A	Over current	NO	clearly	20 15:55 limiter got open and after clearing the fault at Kamjong Substation. Line charged at 18:05 (subjective with Kamjong end after receiving clearing order) 2:15 issued by MNS Kamjong (BPSO).	



Transmission System Performance Report 2022

1. 480/220/132/33kV Jigaching Substation													
Sl No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MW before Outage (MW)	Name of Feeder	Name of the Substation/lines Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outages	Remarks
0/132kV Above													
1	09.09.2022	09:44 hrs	09.09.2022	10:28 hrs	0	178.76	400kV laterin Circut-1	Alipurdhar	DTT	R/Y/B phase pick-up	Fault current: I1 = 0.26kA, I2 = 0.38kA, I3 = 0.26kA		
2	22.08.2022	05:54 hrs	22.09.2022	10:02 hrs	4	-315.6	400kV Mdpn line 5	Alipurdhar	Over voltage	Over voltage			
3	22.08.2022	04:45 hrs	2.09.2022	06:33 hrs	1	307.74	400kV Alpur Direct line-2	Alipurdhar	R/Y pick-up	R/Y pick-up, Ground pick-up, Z2 optd	Main 1 Fault current, I1=2.43kA, I2=1.38kA, I3=3.9kA, Fault Dist = 56.5km Main 2 Fault current, I1=2.38kA, I2=2.97kA, I3=1.336kA, Fault Dist = 56.4km		
4	22.09.2022	05:54 hrs	22.09.2022	07:51 hrs	1	391.96	400kV Alpur Direct line-1	Alipurdhar	Over voltage	Over voltage			
5	4.09.2022	02:47hrs	24.09.2022	04:41hrs	1	-292.33	400kV Mdpn line 1	Alipurdhar	Over voltage	Over voltage	Over voltage, R/Y/B tripped, zone 1 optd.		
6	24.09.2022	02:47hrs	24.09.2022	04:25hrs	1	-4.01	500MVA ICT	Alipurdhar	Over voltage	Over voltage	R/Y/B phase tripped		
7	24.09.2022	03:10hrs	24.09.2022	04:27hrs	1	-292.33	400kV MRPA line 3	Alipurdhar	Over voltage	Over voltage	R/Y/B phase tripped, zone 1 optd.		
8	24.09.2022	03:10hrs	24.09.2022	03:25hrs	0	214.41	400kV Alpur Direct line-1	Alipurdhar	Over voltage	Over voltage	R/Y/B phase tripped on over voltage		
9	24.09.2022	03:10hrs	24.09.2022	03:05hrs	1	213.3	400kV Alpur Direct line-2	Alipurdhar	Over voltage	Over voltage	R/Y/B phase tripped on over voltage		
10	22.09.2022	05:54 hrs	22.09.2022	06:04 hrs	0	-20.480	80MVA ICT-2	Jigaching SS	LV SEF trip	Relay General Trip, LV SEF trip			
11	2.09.2022	05:54 hrs	22.09.2022	07:05 hrs	1	-20.110	80MVA ICT-1	Jigaching SS	LV SEF trip	Relay General Trip, LV SEF trip			
12	08.08.2022	18:38hrs	08.09.2022	18:48hrs	0	62.1	132kV Tamhi Feeder	Tamhi	Earth fault	Rand V ph trip, R/y to ground fault	41.5km	transfer	
13	2.09.2022	04:56 hrs	2.09.2022	05:08 hrs	0	61.69	132kV Tamhi Feeder	Tamhi	R,Y,B phase loop	Main 1 (R,Y & B) phase trip, Z1,Z2 trip, zone 1 trip	Main 1 Fault current, I1=3.95kA, I2=3.72kA, I3=0.03kA, Fault Dist = 24.1km		
14	22.09.2022	05:20 hrs	22.09.2022	05:29 hrs	0	61.69	132kV Tamhi Feeder	Tamhi	R,Y,B phase loop	Main 1 (R,Y & B) phase trip, Z1,Z2 trip, zone 1 trip	Main 1 Fault current, I1=3.5kA, I2=3.69kA, I3=0.61kA, Fault Dist = 31.9km		
15	22.09.2022	06:01 hrs	22.09.2022	11:48 hrs	5	19.86	132kV Tamhi Feeder	Tamhi	R,Y,B phase loop	Main 1 (R,Y & B) phase trip, Z1,Z2 trip, zone 1 trip	Main 1 Fault current, I1=1.23kA, I2=0.15kA, I3=1.14kA, Fault Dist = 25.3km		Line charged from Tamhi end, due to voltage issue CB at Jigaching end kept opened as per BPSO instruction and bar was taken shutdown by TMD
16	24.09.2022	02:47hrs	24.09.2022	03:29hrs	0	24.6	132kV Tamhi Feeder	Tamhi	Due to over voltage	Main 1 & 2 picked up, R/Y/B phase tripped on over voltage			
2. 220/66/33kV Dhaajo Substation													
0/66kV and above													
1	12.09.2022	19:19hrs	12.09.2022	19:33hrs	0		220kV Bus Coupler	Dhaajo Substation		50-51N Relay	Substation	Tripped	Feeder restored after O&M head ESID Tamang confirmed line clearance
2	24.09.2022	3:10hrs	24.09.2022	3:21hrs	0	19.72	Tokang-Jigaching Feeder	Dhaajo Substation	over current	Distance relay (mm-2(21.2)-I1=574.01A, I2=653.65A, I3=729.24A, I4=41.91A)	Substation	Tripped	Feeder restored after O&M head ESID Tamang confirmed line clearance
3. 132/66/33/11kV Gelephu Substation													
0/66kV and above													
1	07.09.2022	09:30hrs	09.09.2022	16:45hrs	31	18	Gelephu-Jigaching	None	shutdown taken by SNG, Jigaching	None	Gelephu Substation	Temporary	Shutdown taken to start the Jigaching Panel towards Substation Panel (Rearrangement of Panels due to Substation upgrade work)
2	24.09.2022	03:09hrs	24.09.2022	03:35hrs		16	phr-Solokati & Jgan	Gelephu & Jigaching	Grid fall	86 relay operated	Solokati line	Temporary	Supply extended from Jigaching at 03:22hrs



Transmission System Performance Report 2022

4. 132/33kV Timshi Substation												
① 66kV & Above												
1	08.09.2022	11:29hrs	08.09.2022	11:45hrs	0	12.43	kV Timshi-nanglam 32kV Timshi-nanglam F	Temporary Fault	Distance Relay Start Phase:ABC, Trip Phase:ABC, Fault zone-1 wip, Fault location:XY 21.16 KM	21.16KM		Temporary
2	08.09.2022	12:04hrs	08.09.2022	12:12hrs	0	11.74	kV Timshi-nanglam 32kV Timshi-nanglam F	Temporary Fault	Distance Relay Start Phase:AN, Trip Phase:ABC, Fault zone-1 wip, Fault location:XY 18.78 KM	XY 18.79		Temporary
3	22.09.2022	04:56hrs	22.09.2022	05:08hrs	0	-59.76	kV Timshi-Angmal 2kV Timshi-Angmal F	Temporary Fault	Distance Relay Start Phase:ABN, Trip Phase:ABC, Fault zone-1 wip, Fault location:20.22KM	20.22		Temporary
4	22.09.2022	05:20hrs	22.09.2022	05:29hrs	0	-59.76	kV Timshi-Angmal 2kV Timshi-Angmal F	Temporary Fault	Distance Relay Start Phase:ABC, Trip Phase:ABC, Fault zone-1 wip, Fault location:17.64KM	17.64		Temporary
5	22.09.2022	06:01hrs	22.09.2022	06:17hrs	0	-19.58	kV Timshi-Angmal 2kV Timshi-Angmal F	Temporary Fault	Distance Relay Start Phase:ACN, Trip Phase:ABC, Fault zone-1 wip, Fault location:17.64KM	17.64		Temporary
6	23.09.2022	03:48hrs	23.09.2022	03:53hrs	0	27.8	kV Timshi-nanglam 32kV Timshi-nanglam F	Temporary Fault	Distance Relay Start Phase:BN, Trip Phase:ABC, Fault zone-1 wip, Fault location:35.22 KM	35.22		Temporary
7	23.09.2022	05:18hrs	23.09.2022	05:23hrs	0	33.41	kV Timshi-nanglam 32kV Timshi-nanglam F	Temporary Fault	Distance Relay Start Phase:ABC, Trip Phase:ABC, Fault zone-1 wip, Fault location:41.29KM	41.29		Temporary
8	23.09.2022	05:30hrs	23.09.2022	12:49hrs	7	33.41	kV Timshi-nanglam 32kV Timshi-nanglam F	Temporary Fault	Distance Relay Start Phase:ABCN, Tri p Phase:ABC, Fault zone-1 wip, Fault location:37.43KM	37.48		Temporary
9	25.09.2022	02:38hrs	25.09.2022	02:50hrs	0	20.92	kV Timshi-nanglam 32kV Timshi-nanglam F	Temporary Fault	Distance Relay Start Phase:AN, Trip Phase:ABC, Fault zone-1 wip, Fault location:34.01KM	34.01		Temporary
10	28.09.2022	22:38hrs	28.09.2022	22:44hrs	0	43.27	kV Timshi-nanglam 32kV Timshi-nanglam F	Temporary Fault	Distance Relay Start Phase:AN, Trip Phase:ABC, Fault zone-1 wip, Fault location:30.10KM	30.1		Temporary
5. 132/33kV Yumoo Substation												
① 66kV & Above												
1	08.09.2022	18:40hrs	08.09.2022	18:47hrs	0	-32.9	112kV Timsha 1C	Yumoo Ss	O.C. Y&B	85 relay optd	Yumoo Ss	
2	17.09.2022	02:33hrs	17.09.2022	02:40hrs	0	-35.0	112kV Timsha 1C	Yumoo Ss	Undervoltage	85 relay optd	Yumoo Ss	Changed as per the BP
3	21.09.2022	09:31hrs	21.09.2022	09:36hrs	0	-32.3	40MVA Tr-1	Yumoo Ss	NCI wiring	85 relay optd	Yumoo Ss	Changed as per the BP
4	22.09.2022	06:02hrs	22.09.2022	06:07hrs	0	-37.4	112kV Timsha 1C	Yumoo Ss	Undervoltage	85 relay optd	Yumoo Ss	Changed as per the BP
5	23.09.2022	04:48hrs	23.09.2022	05:00hrs	0	-37.5	40MVA Tr-1	Yumoo Ss	NCI wiring	85 relay optd	Yumoo Ss	Changed as per the BP
6	23.09.2022	04:47hrs	24.09.2022	04:49hrs	0	-36.5	132kV MIPA Line 2	Yumoo Ss	Grid fal	Nil	MEPA	On dated- 24.09.2022
6. 220/33kV Daggola Substation												
① 66kV & Above												
1	13.09.2022	15:09hrs	13.09.2022	15:12hrs	0	26.28	Transformer II	Daggola SS	Heavy rainfall	Master trip relay A & B	DaggolaSS Switchyard	Transformer II restored



Transmission System Performance Report 2022

October 2022

Division: SMD DEOTHRANG		Substation: 112/111kV Nauglar Substation		Month: Oct-22		BPC SMD 112KV-2022-09-09		Date: 01.11.2022						
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Non-availability Time		Duration of Outage (Hrs)	MW before Outage (MW)	Protection Relay Oper	Tripping Details Fault Details (As recorded by relay)	Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time							
1	Man Grid	112kV	Tripping	01-10-2022	06:24 hrs	01-10-2022	06:39 hrs	0	-	-	-	-	-	Single fault from Tank & Meters Substation
2	Nauglar Deothang Line	112kV	Tripping	08-10-2022	04:30 hrs	08-10-2022	15:02 hrs	10	48.9	MCCOMP40 Agpt	Distance Relay Relay Trip @ 0.1 sec @ 50% Start distance Distance, distance trip Z1, fault duration 05.58sec, relay trip time 79.41sec. Fault location=20.158KM, LA=119.6A, IB=1.090A, IC=241.0A, VAN=71.28kV, VBN=45.14kV, VCN=67.42kV, fault resistance=2.811(Ω)	Unknown	-	Informed to BPSO & an instructed test changed at 04:44 hrs & 10:22 hrs but couldn't stand with operation of distance relay.
3	Nauglar Deothang Line	112kV	Tripping	10-10-2022	09:08 hrs	10-10-2022	18:19 hrs	16	47.42	MCCOMP40 Agpt	Distance Relay Relay Trip @ 0.1 sec @ 50% Start distance Distance, TCC dist distance trip Z1, fault duration 01.45sec, fault location=20.158KM, LA=119.6A, IB=1.090A, IC=241.0A, VAN=71.28kV, VBN=45.14kV, VCN=67.42kV, fault resistance=2.811(Ω)	Unknown	-	Informed to BPSO & an instructed test changed at 09:15 hrs & 09:22 hrs but couldn't stand with operation of distance relay.
4	Nauglar Deothang Line	112kV	Tripping	11-10-2022	04:03 hrs	12-10-2022	17:44	37	44.5	MCCOMP40 Agpt	Distance Relay Relay Trip @ 0.1 sec @ 50% Start distance Distance, TCC dist distance trip Z1, fault duration 01.45sec, fault location=20.158KM, LA=119.6A, IB=1.090A, IC=241.0A, VAN=71.28kV, VBN=45.14kV, VCN=67.42kV, fault resistance=2.811(Ω)	Unknown	-	Informed to BPSO & an instructed test changed at 04:03 hrs, 04:54 hrs & 09:15 hrs but couldn't stand with operation of distance relay. Feeder CB kept operated three after & on 12/10/22, at 09:44 hrs all switch gear operated as per approved shut down table in TMS. Nauglar & Man Grid code=003 from BPSO.
5	112/111kV Transformer-1 (SMVA)	112kV	Tripping	10-10-2022	14:11 hrs	10-10-2022	14:03 hrs	0	0.54	Non directional PROTON Relay operated	OC relay- 50A & trip relay 18 oppt.	Unknown	-	Tripped at the notice of 11kV Young feeder tripping.
Division: SMD DEOTHRANG		Substation: 112/111kV Nauglar Substation		Month: October 2022										
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Non-availability Time		Duration of Outage (Hrs)	MW before Outage (MW)	Protection Relay Oper	Tripping Details Fault Details (As recorded by relay)	Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time							
2	Nauglar Deothang line	112kV	Tripping	06-10-2022	4:50	06-10-2022	6:32	0	37.568	OC & EF	IA=119.6A, IB=218A, IC=225.92A, I=1152A, Test char val=4.68A, I=452A, S=595A, I=456A	Unknown	NA	Test change was done as per the instruction of BPSO and found normal
3	Deothang-Monaga Line	112kV	Tripping	06-10-2022	4:50	06-10-2022	18:39	0	0.288	OC & EF	Fault Value=IA=248, IB=1.114kV, IC=124A, IN=107.4 Test change value=IA=146.9A, IB=1.918A, IC=152.1A, IN=104.015	Unknown	NA	Test change was done as per the instruction of BPSO and found normal
4	Deothang-Monaga Line	112kV	Tripping	08-10-2022	10:31	08-10-2022	10:35	0	0.125	OC	Fault Value=IA=151.0A, IB=1.129KA, IC=111.4A	Unknown	NA	when Nauglar Deothang feeder was test change feeder got tripped and test change done without
8	Nauglar Deothang line	112kV	Tripping	10-10-2022	0:05	10-10-2022	13:29	13	-40.384	OC & EF	IA=159.1A, IB=1.271kA, IC=241.0A, IN=1.111kA, Distance relay= 34.726M, Ia=157.1A, Ib=1.271kA, Ic=249.7A and zone 2 trip	Unknown	TO super Jangteq at ND 01	Test change from Nauglar to Man Grid test. Test change done with the closing code 150 by Man Grid (Wangdar EPSON) after Jangteq on Man ND 01 at Man end and try for TCC changed and normal.
9	Deothang-Monaga Line	112kV	Tripping	10-10-2022	9:05	10-10-2022	1:13	1	47.196	OC & EF	IA=11.72A, IB=1.196A, IC=143.6A, IN=821.9A	Unknown	NA	Single fault fed from Monaga to Man Grid was the fault between Nauglar to Deothang line.
12	Nauglar Deothang line	112kV	Tripping	11-10-2022	2:56	11-10-2022	3:02	0	-46.136	OC	IA=1.498A, IB=1.493A, IC=1.495A, Distance relay	Unknown	NA	After conducting from BPSO test change done and found normal in 3.02hrs
15	Nauglar Deothang line	112kV	Tripping	11-10-2022	4:41	12-10-2022	17:46	37	-48.60	EF	IA=121.9A, IB=1.223KA, IC=219.1A, IN=1.178KA. Test change value at 4:41 hrs IA=4.698A, IB=1.493A, IC=1.520A, IN=1.497KA.	Unknown	NA	Test change from Nauglar to Man Grid test. Again test done at 9:11 hrs. Deothang to Monaga line got test from Monaga end and as per test table as in normal condition. Single returned from Monaga end after opening the number Disconnector with code 179 from BPSO (Mohan Jangteq). It's changed after changing number in 3 phase from location 00 to 01 with the code 150 from BPSO (Mohan Jangteq).
16	Deothang-Monaga Line	112kV	Tripping	11-10-2022	4:01	11-10-2022	5:06	0	44.892	EF	IA=41.24A, IB=1.128A, IC=117A, IN=839.5A. Test change value IA=1.491A, IB=1.108A, IC=1.58A, IN=1.498A.	Unknown	NA	While doing test change of Nauglar Deothang line, breaker got tripped at Man end supply back fed from Monaga as in there was the fault between Nauglar to Deothang line.
Division: SMD DEOTHRANG		Substation: 112/111kV Nauglar Substation		Month: October 2022										
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Non-availability Time		Duration of Outage (Hrs)	MW before Outage (MW)	Protection Relay Oper	Tripping Details Fault Details (As recorded by relay)	Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time							
1	112/111kV Nauglar-110kV	112kV	Grid Fail	03-10-2022	08:25:00	03-10-2022	08:15:00	00:00:00	-1.18	-	-	Grid Fail	NA	No CB is operated at one end.
2	112/111kV Nauglar-110kV	112kV	Grid Fail	03-10-2022	08:25:00	03-10-2022	08:19:00	00:04:00	-0.34	-	-	Grid Fail	NA	No CB is operated at one end.
3	112/111kV, 20MVA Transformer-1	112kV	Fault	08-10-2022	18:38:00	08-10-2022	18:19:00	00:29:00	0.02	-	-	Tripped by side order. Supply restored from Transformer-0	-	-
5	112/111kV, 20MVA Transformer-1	112kV	Fault	30-10-2022	13:05:00	30-10-2022	15:00:00	01:55:00	0.888	-	-	Disk Punctured	NA	110V Main Bus. Disk insulator got punctured. All 110V and 11kV customers are affected.



Transmission System Performance Report 2022

Division		SMID DEOTHRANG		Substation		132/38KV Morigang Substation		Month		October 2022									
Sl. No.	Name of Feeder (33kV Feeder and Transformer-RT)	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Non-availability Time		Duration of Outage (hrs)	MW before Outage (MW)	Protection Relay Oper.	Tripping Details (As recorded by relay)	Type/Cause of Fault	Reason for Shutdown	Remarks					
				Date	Time	Date	Time												
1	1530VA Transformer	112.53kV	Trip	02-10-2022	07:47 hrs	02-10-2022	07:51 hrs	0	0.17	RETE50, transformer differential relay	Tripping relay 50A & SEF operated, trip values not displayed by the relay	Transient fault	-	BPSO Clearing code: 1463.					
2	1530VA Transformer	112.53kV	Trip	02-10-2022	14:24 hrs	02-10-2022	14:27 hrs	0	0.23	DFPH.PDOCI, RSE415	Tripped on EF & OC. I1=0.932A, I2=0.451A, I3=0.414A, RE1659 Relay Indication: Differential protection opnd, R phase trip, Y phase trip, 50CB50 Indication: 50A operated	Transient fault	-	Changed after receiving verbal instruction from BPSO					
3	Deotrang Feeder	112kV	Trip	03-10-2022	06:24 hrs	03-10-2022	06:29 hrs	0	-37.29	REL570, Distance Relay	Distinction-OC & E.F. Relay: Tripped on EF & OC. I1=179.97A, I2=1922.51A, I3=1177.01A, Frequency=50.11Hz, & tripping relay 50A, 50B operated	Transient fault	-	BPSO Clearing code: 1468.					
4	1530VA Transformer	112.53kV	Trip	05-10-2022	11:11 hrs	05-10-2022	11:13 hrs	0	0.17	RETE50, transformer differential relay	Tripped on OC and E.F. Trip values not displayed, Frequency=50.10Hz, & tripping relay RE1659 Indication: 16A&B operated, R, Y & B trip	Transient fault	-	BPSO Clearing code: 1476.					
5	1530VA Transformer	112.53kV	Trip	05-10-2022	11:27 hrs	05-10-2022	11:30 hrs	0	0.17	DFPH.PDOCI, RSE415	Distinction-OC & E.F. Relay: Tripped on EF & OC. I1=0.250A, I2=0.175A, I3=0.123A, Frequency=50.12Hz, & tripping relay 50A, 50B operated at one end.	Tripped by transient fault	-	BPSO Clearing code: 1477.					
6	1530VA Transformer	112.53kV	Trip	05-10-2022	14:51 hrs	05-10-2022	14:53 hrs	0	0.17	RETE50, transformer differential relay	Differential relay, RETE50 Indication: I1=59.47A, I2=42.92A, I3=22.15A, Frequency=50.11Hz, & tripping relay 50A, 50B operated, R, Y & B trip at one end.	Transient fault	-	BPSO Clearing code: 1478.					
7	1530VA Transformer	112.53kV	Trip	06-10-2022	14:22 hrs	06-10-2022	14:24 hrs	0	0.28	RETE50, transformer differential relay	Fault values not recorded by the relay, Frequency=50.10Hz, & tripping relay 50A & SEF operated at one end.	-	-	Test changed at 14:25hrs but did not hold and tripped on same fault. At 14:34hrs changed with the instruction from BPSO, code: 1482					
8	1530VA Transformer	112.53kV	Trip	06-10-2022	14:38 hrs	06-10-2022	14:43 hrs	0	0.28	DFPH.PDOCI, RSE415	Distinction-OC & E.F. Relay: DFPH.PDOCI, I1=0.2425A, I2=0.1545A, I3=0.1305A, Tripped on OC, Frequency=50.07Hz, & tripping relay 50A, 50B operated at one end.	Transient fault	-	-					
9	1530VA Transformer	112.53kV	Trip	06-10-2022	16:42 hrs	06-10-2022	16:44 hrs	0	0.23	DFPH.PDOCI, RSE415	Fault values not recorded by the relay, Frequency=50.09Hz, & tripping relay 50A, 50B operated at one end.	Transient fault	-	-					
10	Deotrang Feeder	112kV	Trip	11-10-2022	02:57 hrs	11-10-2022	03:04 hrs	0	-42.8	REL570, Distance Relay	Distinction-OC & E.F. Relay: Tripped on EF & OC. I1=1799.97A, I2=1922.51A, I3=1177.01A, Frequency=50.11Hz, & tripping relay 50A, 50B operated	Transient fault	-	Changed with verbal instruction from BPSO					
11	Deotrang Feeder	112kV	Trip	11-10-2022	04:41 hrs	11-10-2022	04:48 hrs	0	-41.96	REL570, Distance Relay	Distinction-OC & E.F. Relay: Tripped on EF & OC. I1=1799.97A, I2=1922.51A, I3=1177.01A, Frequency=50.11Hz, & tripping relay 50A, 50B operated	Transient fault	-	Changed with verbal instruction from BPSO					
12	Deotrang Feeder	112kV	Trip	11-10-2022	04:48 hrs	11-10-2022	05:07 hrs	0	-41.96	REL570, Distance Relay	Distinction-OC & E.F. Relay: Tripped on EF & OC, and I1=1799.97A, I2=1922.51A, I3=1177.01A, Frequency=50.11Hz, & tripping relay 50A, 50B operated	Transient fault	-	Changed with verbal instruction from BPSO					
13	1530VA Transformer	112.53kV	Trip	11-10-2022	08:54 hrs	11-10-2022	08:56 hrs	0	0.32	RETE50, transformer differential relay	RETE50 Relay Indication: Tripped on OC & E.F. I1=1095.15A, I2=14.10A, I3=1396.27A, Frequency=50.12Hz, & tripping relay 50A, 50B operated	-	-	At 8:56hrs changed transformer but did not hold and tripped on same fault. Test changed again at 9:42hrs, HV side, stand but tripped again while changing LV. At 9:53hrs stand for handtrip. Changed X-line at 9:55hrs with code: 1570, 33kV. Again kept under shutdown for the maintenance.					
14	Deotrang Feeder	112kV	Trip	11-10-2022	09:11 hrs	11-10-2022	09:17 hrs	0	1.51	REL570, Distance Relay	RETE50 Relay Indication: Tripped on OC & E.F. I1=156.34A, I2=159.66A, I3=0.11A, Frequency=50.12Hz, & tripping relay 50A, 50B operated	Transient fault	-	BPSO Clearing code: 1508					
15	1530VA Transformer	112.53kV	Trip	11-10-2022	09:18 hrs	11-10-2022	09:20 hrs	0	0.03	RETE50, transformer differential relay	RETE50 Relay Indication: Tripped on OC & E.F. I1=0.713A, I2=1.05A, I3=0.74A, Frequency=50.08Hz, & tripping relay 50A, 50B operated	-	-	-					
16	1530VA Transformer	112.53kV	Trip	12-10-2022	22:33 hrs	12-10-2022	22:36 hrs	0	0.15	RETE50, transformer differential relay	Tripped on OC & E.F. Trip values not displayed, Frequency=50.61Hz, & tripping relay RE1659 Indication: 16A&B operated, R, Y & B trip	Transient fault	-	-					
17	1530VA Transformer	112.53kV	Trip	13-10-2022	19:48 hrs	13-10-2022	19:59 hrs	0	0.28	RETE50, transformer differential relay	RETE50 Relay Indication: Tripped on OC & E.F. I1=13.45A, I2=18.92A, I3=27.82A, Frequency=50.05Hz, & tripping relay 50A, 50B operated	Transient fault	-	-					
18	1530VA Transformer	112.53kV	Trip	14-10-2022	14:11 hrs	14-10-2022	14:13 hrs	0	0.35	RETE50, transformer differential relay	RETE50 Relay Indication: Tripped on OC & E.F. I1=33.97A, I2=23.70A, I3=49.51A, Frequency=50.06Hz, & tripping relay 50A, 50B operated	Transient fault	-	Clearing code: 1525					
19	1530VA Transformer	112.53kV	Trip	21-10-2022	15:06 hrs	21-10-2022	15:07 hrs	0	0.19	RETE50, transformer differential relay	RETE50 Relay Indication: Tripped on OC & E.F. I1=23.46A, I2=24.91A, I3=43.14A, Frequency=50.07Hz, & tripping relay 50A, 50B operated	-	-	The X-line was test changed at 15:06hrs but did not hold. It was changed at 15:37hrs with clearing code: 1548					
20	1530VA Transformer	112.53kV	Trip	22-10-2022	15:49 hrs	22-10-2022	15:52 hrs	0	0.03	RETE50, transformer differential relay	RETE50 Relay Indication: Tripped on OC & E.F. I1=18.99A, I2=25.68A, I3=41.05A, Frequency=50.05Hz, & tripping relay 50A, 50B operated	Transient fault	-	Changed with verbal instruction from BPSO.					
21	1530VA Transformer	112.53kV	Trip	24-10-2022	12:18 hrs	24-10-2022	12:21 hrs	0	0.17	RETE50, transformer differential relay	RETE50 Relay Indication: Tripped on OC & E.F. I1=13.15A, I2=17.68A, I3=17.06A, DF test's operated, R, Y & B trip and 50A, 50B operated	-	-	Changed with verbal instruction from BPSO.					
22	1530VA Transformer	112.53kV	Trip	24-10-2022	15:51 hrs	24-10-2022	15:53 hrs	0	0.38	RETE50, transformer differential relay	RETE50 Relay Indication: Tripped on OC & E.F. I1=14.54A, I2=17.11A, I3=19.36A, DF test's operated, R, Y & B trip and 50A, 50B operated	-	-	Changed with verbal instruction from BPSO.					
23	1530VA Transformer	112.53kV	Trip	24-10-2022	16:00 hrs	24-10-2022	16:09 hrs	0	0	RETE50, transformer differential relay	RETE50 Relay Indication: Tripped on OC & E.F. I1=15.74A, I2=15.18A, I3=16.15A, DF test's operated, R, Y & B trip and 50A, 50B operated	-	-	Test changed at 16:03hrs but did not hold and tripped on same fault. Changed at 16:09hrs with code: 1548					
24	1530VA Transformer	112.53kV	Trip	24-10-2022	16:20 hrs	24-10-2022	16:23 hrs	0	0	RETE50, transformer differential relay	RETE50 Relay Indication: Tripped on OC & E.F. I1=15.41A, I2=16.14A, I3=16.50A, DF test's operated, R, Y & B trip and 50A, 50B operated	-	-	BPSO Clearing code: 1563					
25	1530VA Transformer	112.53kV	Trip	24-10-2022	16:37 hrs	24-10-2022	16:48 hrs	0	0	RETE50, transformer differential relay	RETE50 Relay Indication: Tripped on OC & E.F. I1=14.59A, I2=16.10A, I3=16.16A, DF test's operated, R, Y & B trip and 50A, 50B operated	-	-	BPSO Clearing code: 1569					
26	1530VA Transformer	112.53kV	Trip	24-10-2022	16:55 hrs	24-10-2022	17:04 hrs	0	0	RETE50, transformer differential relay	RETE50 Relay Indication: Tripped on OC & E.F. I1=22.21A, I2=30.79A, I3=40.71A, DF test's operated, R, Y & B trip and 50A, 50B operated	-	-	Changed with verbal instruction from BPSO.					



Transmission System Performance Report 2022

Sl. No.	Date of Tripping	Time of Outage/ Time of Tripping	Date of Notification	Time of Fault was Cleared	Duration of Outage (Hrs)	MV Index Outage (MV)	Name of feeder	Name of the Substation lines affected by the Fault	Reason of Fault	Relay Operation	Fault Location(KM)	Type of outages	No. of Customers Affected	Remarks
1. 100/110/132/138KV Ngangpho Substation														
0.133KV Above														
1	09.10.2022	09:12 hrs	09.10.2022	09:12 hrs	0	195.51	433KV Alapahar Line 1	Alapahar SS	Fault loop-1/3ph-Ground	Max 1 and Min 2 open Fault loop-1/3ph-Ground loop Zone 1 open	Min 1 Fault current IA = 2.27kA, Fault Distance 115.7km(21.1) and 114.7km(21.2)	Transient		
2	24.10.2022	22:55 hrs	24.10.2022	23:04 hrs	0	-145.44	60kV MIRA LINE 1	MIPA	Fault loop-1/3ph-Ground	131kV pickup, Zone 1 open, Fault loop-1/3ph-Ground trip	Min 1 Fault current I1 = 5.6kA, Fault Distance 22.3km, current I2=5.6kA and Fault Distance 22.3km	Min 2 Fault		
3	20.10.2022	09:41 hrs	20.10.2022	09:47 hrs	0	19.210	220kV Tawang	Dhaje SS	Relay Ground trip	Min-2 (older ground trip)				Line tripped while changing under voltage relay settings
4	26.10.2022	10:08hrs	26.10.2022	10:19hrs	0	-15.66	800kVA ICT 2	Ngangpho ss	STPC(V)	07.07.00.57				
5	12.10.2022	03:40hrs	12.10.2022	14:4hrs	0	11.310	Colaphe Feeder	Colaphe substation	Phase Loop	main 1 - R,Y & B phase trip 22 hrs main 2 - R,Y & B phase trip 22 hrs	83.3km	Transient		
2. 220/66/22KV Dhaje Substation														
0.66KV and above														
1	26.10.2022	10:08hrs	26.10.2022	10:20hrs	0	67.99	220kV Dapuche Feeder	Dhaje Substation	Line voltage	Distance relay non-trip Z(21.2): Ia=0.12A, Ib=0.00A, Ic=0.00A, Ip=0.02A, Vm=124.9kV, Vm=145.9kV, Vm=105kV	Substation	Tripped		Feeder restored after get a confirmation from BPSO
3. 132/66/22.11KV Colaphe Substation														
0.66KV and above														
1	12.10.2022	01:40 hrs	12.10.2022	02:28 hrs	0	28.8	132 kV Substat	132 kV Substat	Line fault	Tripped on 1 ph, zone 2, distance =2.871 km, fault current value Ia=1.911 ka, Ib=2.075 ka, Ic=1.985 ka	Colaphe ss	Temporary		Charging Code, NUDC: B7No=1313, NUDC: ND=1105 & NRRDC=0414. At the same time 132kV Gd-1g line also tripped from Ngangpho end. (Over) lightning & wind
4	19.10.2022	20:55hrs	19.10.2022	21:00hrs	0	-20	132kV Gd-1g	132kV Gd-1g	Line fault	shortcircuit	Ngangpho ss			To change B-ph, CT polarity at Ngangpho SS
5	21.10.2022	17:30hrs	21.10.2022	17:47hrs	0	16	132kV Gd-1g	132kV Gd-1g	Line fault	shortcircuit	Ngangpho ss			Emergency call taken by Ngangpho to check phase sequence
4. 132/33KV Tangle Substation														
0.66KV & Above														
1	08.10.2022	06:24hrs	08.10.2022	06:33hrs	0	-14.4	kV Tangle-angden/2kV Tangle-angden F	Temporary Fault	Distance Relay Start Phase-ON, Trip Phase-ABC Fault zone 1 trip, Fault location=8.46 KM		85.46	Temporary	NA	
2	12.10.2022	03:39hrs	2.10.2022	02:00hrs	0	-10.44	kV Tangle-angden/2kV Tangle-angden F	Temporary Fault	Distance Relay Start Phase-ABC, Trip Phase-ABC Fault zone 1 trip, Fault location=5.57KM		52.57	Temporary	NA	

November 2022

Sl.No	Substation Name (Defect from line)	Feeder Name (Defect from line)	Outage Reason (Defect from line)	Fault Location (Defect from line)	Tripping Date & Time (dd/mm/yyyy hh:mm:ss)	Notification Date & Time (dd/mm/yyyy hh:mm:ss)	Customers affected (Yes/No)	Remarks	Outage Duration(hh:mm:ss)	Outage in Minutes[1]	No. of Customers Interrupted (No)	Reason for Outage	Remarks
Division: SMD-BIOTHRANG Substation: 132/33/11KV Ngangpho Substation Month: Nov-22													
1	132/33KV, 33/11KV Transfeeder 2	132KV	Phase		21.11.2022	11:08:00	11.11.2022	11:07:00	00:01:00	0	1300	Phase-ABC, 4.87 km	Tripped on Earth Fault
Division: SMD-BIOTHRANG Substation: 132/33/11KV Ngangpho Substation Month: Nov-22													
9	132/33KV, 33/11KV Transfeeder 1	132KV	Phase		21.11.2022	11:08:00	11.11.2022	11:07:00	00:01:00	0	1300	Phase-ABC, 4.87 km	Tripped on Earth Fault



Transmission System Performance Report 2022

Division:		WHD DIGHTING												
Substation:		135KV Motang Substation												
Month:		Nov 22												
WBPC SMD 5/9/2022 2:73														
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (If possible specify)	Outage Tripping Time		Outage Duration (Hrs)		MW before Outage (MW)	Protection Relay Used	Tripping Details		Type/Cause of Fault	Reason for Shortfall	Remarks
				Date	Time	Date	Time			Hrs	Mins			
1	15MVA Transformer	132.2kV	Tripping	02-11-2022	19:33 hrs	02-11-2022	19:36 hrs	0	2.14	R1765, busbarzone differential relay	Tripping code 012 & 018 reported, R 17: 910A, ICS 904g, R 21: 912A-74 904g, R 20: 910A, ICS 904g, R 22: 907A, ICS 904g by 912g	Transient fault	-	Clear feed with the verbal instruction from RPSO
2	15MVA Transformer	132.2kV	Tripping	06-11-2022	17:44 hrs	06-11-2022	17:47 hrs	0	2.06	-	Fault values not recorded by the relay	-	-	Changed after receiving verbal instruction from RPSO
3	15MVA Transformer	132.2kV	Tripping	12-11-2022	09:07 hrs	12-11-2022	09:11 hrs	0	0.23	-	Fault values not recorded by the relay	-	-	RPSO Changing code: 0027
1. 600-220/132.2kV Jigmekang Substation														
Sl. No.	Date of Tripping	Time of Outage/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outage (Hrs)	MW before Outage (MW)	Name of Feeder	Name of the Substation/Line Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outage	Remarks	
0 132kV Above														
1	25.11.2022	1:34 hrs	25.11.2022	1:38 hrs	0	-180.9	400kV SHEEP Line -3	Agreeing and Abnormal		Matn: 021.1: Y & B pick up Matn: 021.2: Y and B phase pick up	Matn 1: Fault current: 5.1kA, Fault distance: 57.3km Matn 2: Fault current: 5.11kA, Fault distance: 55.3km		Line auto reclosed	
2	29.11.2022	01:22 hrs	29.11.2022	20:04 hrs	38	0.070	132.2kV-15MVA Transformer	Tapdancer	Tripped on 877. After auto reclose	877, differential relay, REF and 807				
2. 220kV-230kV Dhaagye Substation														
0 66kV and above														
1	02.11.2022	4:04hrs	02.11.2022	4:53.27hrs	0	45.9	220kV Tawang- Jigmekang	Dhaagye Substation	over voltage	Distance relay matn-021.2: Ia=0.09A, Ib=0.09A, Ic=0.09A, Ia=0.11A, Va=112.24kV, Vb=112.97kV, Vc=112.68kV	Substation	Tripped	Feeder restored after get a confirmation from RPSO	
2	10.11.2022	17:08hrs	10.11.2022	17:4 hrs	0	4.24	220kV Tawang- Jigmekang	Dhaagye Substation	over voltage	Distance relay matn-021.2: Ia=0.07A, Ib=0.09A, Ic=0.15A, Ia=0.17A, Va=141kV, Vb=145.9kV, Vc=132kV	Substation	Tripped	Feeder restored after get a confirmation from RPSO	



Transmission System Performance Report 2022

December 2022

MONTHLY OUTAGE REPORT FOR THE MONTH OF DECEMBER, 2022 UNDER SMD DEOTHANG, TD, BPC.

Division:	SMD-DEOTHANG
Substation:	132/33/11kV Nganglam Substation
Month:	#REF!

Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Fault)	Shutdown/Tripping Time		Normalization Time		Duration of Outage (Hrs)	MW before Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks	
				Date	Time	Date	Time			Protecton Relay Optd	Fault Details (As recorded by relay)				
132kV															
1	132/33kV, 5MVA Transformer-1	132kV	Fault	03-12-2022	09:34:00	03-12-2022	09:39:00	00:05:00	0.516	O/C & E/F Relay	triped due to O/C 86 opt				Test charged was done and line stand.
4	132kV Nganglam-Tintibi	132kV	Fault	22-12-2022	15:43:00	22-12-2022	15:58:00	00:15:00	-19.33	O/C & E/F Relay	Triped due to earth fault ,IA66.02A,IB722.0A,IC:114.6A,IN:702.7A				Test charged was done and line stand.
1. 400/220/132/33kV Jigmeling Substation															
Sl. No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MW before Outage (MW)	Name of feeder	Name of the Substation/lines Affected by the Fault	Relay Operations	Fault Location(KM)	Type of outages	No. of Customers Affected	Customer * Hours Affected	Remarks	
i) 132kV Above															
1	17/12/2022	02:09 hrs	17/12/2022	02:16 hrs	0	75.86	400/220kV ICT	Jigmeling Substation	87T tripped						

Annexure- II

**Western Grid Outages
January 2022**



Transmission System Performance Report 2022

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
(B) 66/33/11 kV Phuntsholing Substation													
1	06.01.2022	09:24	06.01.2022	11:16	1	0.66	SMVA TRF 66/11kV	SMVA TRF 66/11kV	BUCH Trip	OLTC BUCH Trip, Tripping relay B6	Substation	Tripped on Fault	At 09:19hrs SMVA transformer (66/11kV) got tripped on OLTC BUCH. Couldn't reset the relay and informed to Kinchen Zangmo, Sr.Engineer regarding above fault. Issued shutdown with work permit no.339 for carrying out physical inspection. Released gas and cleaned contact parts. At 11:16hrs normalised the transformer.
(D) 66/33/11kV Lobesa Substation													
66kV LSA - Basochu feeder													
1	28.01.2022	12:32hrs	28.01.2022	12:49hrs	0	-21.580	66kV LSA - Basochu feeder			86 relay operated			66kV LSA - Basochu feeder got tripped at 12:32hrs and charged the line as per BPSO at 12:49hrs and breaker towards hand tripped as per BPSO at 12:48hrs.
2	28.01.2022	13:03hrs	28.01.2022	13:11hrs	0	-6.840	66kV LSA - Basochu feeder			NA			66kV LSA - Basochu feeder got tripped at 13:03hrs without any relay & breaker operation at our end and supply resumed at 13:11hrs from Basochu and supply extended to Daocula at 13:14hrs as per BPSO.
66kV LSA - Dochula feeder													
1	28.01.2022	12:48hrs	28.01.2022	13:14hrs	0	15.190	66kV LSA - Dochula feeder			NA			66kV LSA - Dochula feeder hand tripped as per BPSO at 12:48hrs and charged the feeder at 13:14hrs.
(G) 66/33/11kV Dechencholing substation													
1	26.01.2022	14:40hrs	26.01.2022	14:44hrs	0	-33.98	66kV Semtokha IC	whole s/s fdr.	Supply failed from source.				
2	28.01.2022	12:36hrs	28.01.2022	12:50hrs	0	-33.54	-do-	whole s/s fdr.	Supply failed from source.				
3	29.01.2022	07:58hrs	29.01.2022	08:18hrs	0	3.642	66kV Damji line	Damji line	Transced fault	86A, 86B, Dist trip, 3phase, Zone-1 & SoftTor trip.	Distance not shown	tripped	
(H) 66/11kV Haas Substation													
1	27.01.2022	9:20hrs					66/11kV SMVA transformer - II	66/11kV SMVA transformer - II	Oil leakage from the 11kV terminal box of Y phase.	Blukor relay	Haas ss		Blukor relay was operated due to low oil level in the conservator tank of 66/11kV SMVA transformer - 4 and also oil leakage from the terminal box of LV line of transformer. The same was referred to maintenance head SMD, Semtokha for necessary action. due to lockdown the work couldn't be proceeded further, till then the supply was fed from SMVA transformer - 1.
(I) 220kV Substation Semtokha													
1	28.01.2022	12:34hrs	28.01.2022	12:49hrs		-63.150	220kV Sem-CHP	Semtokha Substation	CB tripped at CHP end while doing test charge			Transient	
2	28.01.2022		28.01.2022		25	-63.48	220kV Sem-BHP	220kV SEM-BHP Line	Main-1&2 Trip, fault loop- Fmtr Loop= L1-NL, L1-NV (I=2.39KA, I=222.5A, I=110.1A)		Distance=5.2KM	Permanent	
3	25.01.2022	12:08hrs	25.01.2022	12:22hrs		34.69	66kV Sem-Ding Line	66kV Sem-Ding Line	Broken Conductor	Distance Ptn. Optd. BRC Tr		Transient	
4	26.01.2022	14:39hrs	26.01.2022	14:44hrs		34.69	66kV Sem-Ding Line	66kV Sem-Ding Line	Broken Conductor	Distance Ptn. Optd. BRC Tr		Transient	
(K) 66/33kV Changidaphu Substation													
1	28.01.2022	12:34hrs	28.01.2022	13:03hrs		-3.95	66kV Changidaphu - Olakhaline	66kV Changidaphu - Olakhaline	Grid failed	Dist. Protm. Optd. Zone-1, Rph trip		Transient	
(L) 66/33kV Damji Substation													
1	25.01.2022	12:07 hrs	25.01.2022	12:13 hrs	0	-3.24	66 kV Incoming Line	Whole Substation	Trip	NA			Line trip from Semtokha Substation
2	26.01.2022	14:40 hrs	26.01.2022	14:45 hrs	0	-1.19	66 kV Incoming Line	Whole Substation	Trip	NA			Line trip from Semtokha Substation
3	29.01.2022	07:53 hrs	29.01.2022	08:19 hrs	0	-3.01	66 kV Incoming Line	Whole Substation	Trip	NA			Line trip from Dechencholing Substation
(M) 66/11kV Dochula Substation													
1	28/1/2022	12.36	28/1/2022	12.53	0		86 relay	Source Fail from Chukha & Basochu	Line fault between semtokha to Rurichu	Temporary fault			While charging the Rurichu line from semtokha Chukha got tripped due to the line fault in between Semtokha to Rurichu.
2	28/1/2022	12.36	28/1/2022	12.58	0		86 relay	Source Fail from Chukha & Basochu	Line fault between semtokha to Rurichu	Temporary fault			



Transmission System Performance Report 2022

February 2022

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
(A) 400/220/66/11 kV Malbase Substation													
66kV & Above													
1	01.02.2022	16:59	01.02.2022	17:05	0	48	220kV Chukha Feeder	Malbase Substation	overcurrent on R phase.	Distance Zone 1, AR operated.	9.4929 km	Overcurrent Outage	IL1=5.566kA,IL2=311A,IL3=386.9A
2	01.02.2022	16:59	01.02.2022	17:12	0	22	30MVA Transformer III	Malbase Substation		Differential Start, OLCB Burchals Trip, Differential Trip.	-	-	IL1=89.97A<126.94 deg, IL2=79.88A<-178.9 deg, IL3=130.9A< 129.26 deg.
3	10.02.2022	15:37	10.02.2022	15:55	0	27	66kV Pasakha Feeder I	Industrial Site		Operated,General Trip.	-	-	IL1=228.08A<57.66 deg, IL2=209.67A<-147.73deg, IL3=148.03A<-67.51deg.
4	10.02.2022	15:37	10.02.2022	15:55	0	29	66kV Pasakha Feeder IV	Industrial Site		IEF-SON, Trip,86 Operated,General Trip.	-	-	IL1=609.62A<80.46 deg, IL2=552.45A<-115.14deg, IL3=1719.66A< 69.45deg.
5	10.02.2022	15:37	10.02.2022	15:55	0	27	66kV Pasakha Feeder II	Industrial Site		IEF-SON, Trip,86 Operated,General Trip.	-	-	IL1=0.34A<139.27 deg, IL2=702.13A<133.46deg, IL3=2369.77<-79.96deg.
6	10.02.2022	15:37	10.02.2022	15:55	0	-	66kV Bus Coupler	Malbase Substation		IEF-SON, Trip,86 Operated,General Trip.	-	-	IL1=552.12A<116.54 deg, IL2=29.01A<-116.26deg, IL3=332.77<84.69deg, Neutral current=1054.78<109.37deg.
7	20.02.2022	23:12	20.02.2022	23:24	0	28	220 kv Chukha feeder	Malbase Substation		AR Lockout Shot, Zone 1 Trip.	9.281 km	-	R phase=5.023kA, Y phase=5.039kA, Y phase=4.917kA.
(B)220/66/11 kV Singhigaon Substation													
1	10.02.2022	15:30	10.02.2022	15:40	0	10	66kV Bhutan Concast Feeder	Singhigaon Substation	Overcurrent on B phase	O/C Trip, DIR Time-trip,IE->DIR trip,IE->DIR Trip.	Druk wang Factory	Overcurrent Outage	IL1=0.35kA,IL2=0.39kA,IL3=5.13kA
(B)66/33/11 kV Phuentsholing Substation													
1	01.02.2022	16:58	01.02.2022	17:11	0	3.47	66kV Chukha feeder	66kV Chukha feeder	Overcurrent	la-373.7A, Ib-1.041kA, Ic-982.1A, VAB-11.04kV, VBC-13.88kV, VCA-10.30kV, Imm-409.5A, Ind-409.6A, VAN-5.177kV, VBN-7.972kV, VCN-7.223kV, B6 & 186	Substation	Tripped on fault	66kV Chukha-Pling feeder got tripped at both end (ie Pling & Chukha end). At 17:11hrs normalised the feeder after getting clearance from BPSO.
2	02.02.2022	08:04	02.02.2022	08:32	0	0.09	66kV Chukha feeder	66kV Chukha feeder	Overcurrent	la-37.19A, Ib-775.5A, Ic-756.6A, VAB-58.97kV, VBC-21.83kV, VCA-55.07kV, Imm-6.114A, Ind-6.078A, VAN-38.46kV, VBN-25.018kV, VCN-17.64kV, B6 & 186	Substation	Tripped on fault	66kV Chukha-Pling feeder got tripped at both end (ie Pling & Chukha end). At 08:22hrs test charge the feeder after getting clearance from BPSO with charging code 1093 but got tripped on distance relay. Informed to BPSO and at 08:32hrs normalised the feeder after opening 66kV Pling- Gedu section line isolator at Gedu end.
3	05.02.2022	05:26	05.02.2022	05:32	0	3.63	66kV Chukha feeder	66kV Chukha feeder	Overcurrent	la-35.15A, Ib-976.9A, Ic-995.1A, VAB-60.83kV, VBC-13.79kV, VCA-58.43kV, Imm-10.96A, Ind-10.85A, VAN-39.56kV, VBN-24.30kV, VCN-18.98kV, B6 & 186	Substation	Tripped on fault	66kV Chukha-Pling feeder got tripped at both end (ie Pling & Chukha end). At 05:26hrs normalised the feeder after getting clearance from BPSO.
4	20.02.2022	23:13	20.02.2022	23:25	0	-2.30	66kV Chukha feeder	66kV Chukha feeder	Distance relay	General Trip, 186 & 86	Substation	Tripped on fault	66kV Chukha-Pling feeder got tripped at both end (ie Pling & Chukha end, weather condition at Chukha heavy lightning and rain). At 23:25hrs normalised the feeder after getting clearance from BPSO.
5	21.02.2022	01:54	21.02.2022	02:22	0	-2.00	66kV Chukha feeder	66kV Chukha feeder	Distance relay	General Trip, 186 & 86	Substation	Tripped on fault	66kV Chukha-Pling feeder got tripped at both end (ie Pling & Chukha end, weather condition at Chukha heavy lightning and rain). At 02:10hrs test charged with charging code 1239 from BPSO but got tripped on same fault. At 02:22hrs as per instruction from BPSO normalised the feeder after opening line isolator of 66kV Chukha-Gedu section from Gedu end.
6	21.02.2022	15:20	21.02.2022	15:40	0	-4.90	66kV Pling Gomtu feeder	66kV Pling Gomtu feeder			Dhamdhum substation		At 15:29hrs 66kV Gomtu-Pling feeder got tripped from Gomtu end (ie from Dhamdhum substation) and causing black out at Phuentsholing. At 15:30hrs normalised 66kV Pling-Malbase feeder with closing code 1255 from BPSO. Weather condition was raining with lightning.
7	21.02.2022	15:36					66kV Pling-Malbase feeder						At 15:29hrs 66kV Gomtu-Pling feeder got tripped from Gomtu end (ie from Dhamdhum substation) and causing black out at Phuentsholing. At 15:30hrs normalised 66kV Pling-Malbase feeder with closing code 1235 from BPSO. Weather condition was raining with lightning.
8	25.02.2022	16:17	25.02.2022	16:53	0	-8.85	66kV Chukha-Pling feeder	66kV Chukha feeder	Distance relay	General Trip, 186 & 86	Substation	Tripped on fault	66kV Chukha-Pling feeder got tripped at both end (ie Pling & Chukha end and 66kV Gomtu feeder from end causing black out at Phuentsholing. At 16:20hrs charged 66kV Malbase feeder with closing code 1255 from BPSO. At 16:33hrs normalised 66kV Chukha-Pling feeder after getting clearance from BPSO. At 16:40hrs normalised 66kV Gomtu feeder with closing code 1256 from BPSO.
9	25.02.2022	16:17	25.02.2022	16:40	0	-2.75	66kV Pling Gomtu feeder	66kV Pling Gomtu feeder	Distance relay	General Trip, tmo=41sec, fault imp- 6.68, fault angle-131deg, fault I-4.09A, fault location- 45.7 and 186 & 86	Substation	Tripped on fault	
10			25.02.2022	16:20	16	idle	66kV Pling-Malbase feeder						Both 66kV feeder got tripped causing black out at Phuentsholing. At 16:20hrs charged 66kV Pling-Malbase feeder with closing code 1256 from BPSO.



Transmission System Performance Report 2022

(D) 66/33/11 kV Gedu Substation													
1	01.02.2022	16:58	01.02.2022	17:12	0	2.78	66kV Incomer	Gedu Substation	Bad weather condition		Line segment	Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Chukha end.	
2	02.02.2022	8:04	02.02.2022	8:42	0	2.8	66kV Incomer	Gedu Substation	Bad weather condition		Line segment	Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Phuntsholing end.	
3	05.02.2022	5:25	05.02.2022	5:32	0	1	66kV Incomer	Gedu Substation	Bad weather condition		Line segment	Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Chukha end.	
4	20.02.2022	23:10	20.02.2022	23:25	0	1.58	66kV Incomer	Gedu Substation	Bad weather condition		Line segment	Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Chukha end.	
5	21.02.2022	1:56	21.02.2022	2:21	0	0.93	66kV Incomer	Gedu Substation	Bad weather condition		Line segment	Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Phuntsholing end.	
6	21.02.2022	15:20	21.02.2022	15:35	0	2.33	66kV Incomer	Gedu Substation	Bad weather condition		Line segment	Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Phuntsholing end.	
7	25.02.2022	16:16	25.02.2022	16:34	0	2.9	66kV Incomer	Gedu Substation	Bad weather condition		Line segment	Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Chukha end.	
(E) 66/33/11 kV Gomtu Substation													
1	08.02.2022	18:57	09.02.2022	20:39	1	2.673	66/11kV 10MVA Transformer	Nil	Sparking occurred on LV terminal	Nil	Gomtu Substation	Shutdown	Taken shutdown for new replacement of LV cable termination by maintenance team.
2	09.02.2022	08:11	09.02.2022	08:19	0	4.15	66/11kV 5MVA Transformer.	Gomtu Substation	Over load	86 & 30AB Aux Operated	Gomtu Substation		Due to over loading of Transformer got tripped.
3	21.02.2022	15:27	21.02.2022	15:40	0	-8.42	66kV Damdum feeder	Gomtu Substation	Nil	Nil	Dhamdhum substation	Transient fault	66kV supply tripped from Damdum Substation, supply fed from P/ling at 15:40 hrs. 66kV Damdum resumed at 17:01 hrs.
(F) 220/66/33 kV Dhamdum Substation													
1	21.02.2022	15:27	21.02.2022	16:00	0	5.35	50/63MVA TRF.1 (203)	Dhamdum	Transient Fault	RET670	N/A	N/A	Fault Mag.:128.11KV and Fault angle :-7.55Deg.
2	21.02.2022	15:27	21.02.2022	15:59	0	5.32	50/63 MVA TRF 2 (205)	Dhamdum	Transient Fault	RET670	N/A	N/A	Fault Mag.:128.11KV and Fault angle :-7.55Deg.
3	21.02.2022	15:27	21.02.2022	17:01	1	8.1	66kV Gomtu fdr.	Gomtu	Transient Fault	REL670:General trip,Zone 1 trip R phase and 86 relay trip.	N/A	-	Fault value:R phase fault mag.:3408.74Amp and fault angle :-74.35 deg.
Sl. No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
(A) 66kV Chamdu switching station													
1	04.02.2022	2227hrs	05.02.2022	1435hrs	16hrs	2.92MW	66kV Pangbasa feeder	Pangbasa substation		G/trip, Y&B ph, CB open.			
2		0613hrs		0608hrs		6.22MW							
3		0114hrs		0121hrs		(-)3.99MW							
4		0212hrs		0222hrs		0.25MW	66kV Jemina feeder	Fed from 66kV Chukha feeder		G/trip, Y&B ph, CB open.			
5		0626hrs		1427hrs	7hrs	1.26MW			due to heavy snow fall		66kV transmission line	Trip	
6	05.02.2022	0625hrs	05.02.2022	0656hrs		3.02MW	66kV Paro feeder	Paro substation		G/trip, Y&B ph, CB open.			
7		0109hrs		1430hrs	13hrs	4.02MW							
8		2456hrs		0102hrs		(-)7.95MW							
9		0205hrs		0410hrs	2hrs	(-)0.15MW	66kV Chukha feeder	Paro, Pangbasa, Jemina		G/trip, Y&B ph, CB open. Dist prn optd.			
10		0734hrs	06.02.2022	1511hrs	4hrs	(-)1.23MW		Fed from 66kV Jemina feeder					
11	08.02.2022	1106hrs	08.02.2022	1243hrs	1hr	0.32MW	66kV Chukha Feeder	Fed from 66kV Jemina feeder	For jumpering out at Wtsa T-Off For re-jumpering out at Wtsa T-Off	CB open, Line& Bus isolator open, E/switch closed			
12	09.02.2022	1643hrs	09.02.2022	1739hrs		0.45MW							
13		0205hrs		0211hrs		3.88MW							
14	14.02.2022	0650hrs	14.02.2022	0655hrs		2.88MW	66kV Paro feeder	Paro substation	Transient fault	CB open, OC			
15		0705hrs		0721hrs		7.64MW							
16		2022hrs	20.02.2022	2028hrs							Chumdo end	trip	
17	20.02.2022	2100hrs	21.02.2022	1226hrs	15hrs	(-)15.75MW	66kV Chukha feeder	Fed from 66kV Jemina feeder	Trip	CB open, Dist prn optd, 3ph trip			
18		2131hrs	20.02.2022	2141hrs		3.45MW	66kV Pangbasa feeder	Pangbasa substation	Trip	G/trip, Dist prn optd, 3ph	Chumdo end	Trip	
19	21.02.2022	0846hrs	21.02.2022	0939hrs		(-)14.67MW	66kV Jemina feeder	Paro, Pangbasa Watsa	Trip	No operation at chumdo end	Changdaphu end	trip	

ID	DD	66/33kV Water Substation	01.02ha	02.08.2022	01.02ha	-480MW	66kV IC	Feb. 1 and II	Dist. Relay 21 2Bm, Class. Zone 1 on shokha end.	66kV IC	Tripped	
1	02-08-2022	00.50ha	02-08-2022	01.02ha	-480MW	66kV IC	Feb. 1 and II	Dist. Relay 21 2Bm, Class. Zone 1 on shokha end. <td>66kV IC</td> <td>Tripped</td> <td></td> <td></td>	66kV IC	Tripped		
2	02-08-2022	1.31ha	02-08-2022	1.31ha	-480MW	66kV IC	Feb. 1 and II	Dist. Relay 21 2Bm, Class. Zone 1 on shokha end. <td>66kV IC</td> <td>Tripped</td> <td></td> <td></td>	66kV IC	Tripped		
3	02-08-2022	1.81ha	02-08-2022	1.81ha	-480MW	66kV IC	Feb. 1 and II	Dist. Relay 21 2Bm, Class. Zone 1 on shokha end. <td>66kV IC</td> <td>Tripped</td> <td></td> <td></td>	66kV IC	Tripped		
4	02-08-2022	2.02ha	02-08-2022	2.02ha	-480MW	66kV IC	Feb. 1 and II	Dist. Relay 21 2Bm, Class. Zone 1 on shokha end. <td>66kV IC</td> <td>Tripped</td> <td></td> <td></td>	66kV IC	Tripped		
5	02-08-2022	3.02ha	02-08-2022	3.02ha	-480MW	66kV IC	Feb. 1 and II	Dist. Relay 21 2Bm, Class. Zone 1 on shokha end. <td>66kV IC</td> <td>Tripped</td> <td></td> <td></td>	66kV IC	Tripped		
6	02-08-2022	9.3 ha	02-08-2022	18.1 ha	10ha	-480MW	66kV IC	Feb. 1 and II	Dist. Relay 21 2Bm, Class. Zone 1 on shokha end. <td>66kV IC</td> <td>Tripped</td> <td></td>	66kV IC	Tripped	
9	16/2/2022	20.50ha	16/2/2022	20.56ha		660MW	66kV SE6 breakers	Feb. 1 and II	OC, OCH, BF and RFI	Feb. 1 Wamachha	Tripped	66kV break tripped from chassis and after opening jumper towards shokha by TMD shokha.
10	20/2/2022	20.20ha	20/2/2022	20.28ha		100MW	66kV IC	Feb. 1 and II			Tripped	Test charge test line couldn't hold and breaker changed after opening Wamachha isolator
11	20/2/2022	21.00ha	21/2/2022	12.26ha	15ha	100MW	66kV IC	Feb. 1 and II	Conductor got twisted on shokha end	Feb. 1 Wamachha	Tripped	Conductor got twisted with each other at shokha near grill. Line charged after clearing fault by TMD Wamachha
(C) 66/33kV Chokha Substation												
1	05-02-2022	01:15	05-02-2022	01:19	2.92	66kV Chokha - Changdaphu line	Chokha Substation	Dist From Relay 21 Optd	DISTANCE PROTN RELAY 21 Optd Indication 1.2 3.12 & 13. 1 General trip. 2 Distance Optd 3 Zone 1 Optd 12 LBB Optd 13 UV Optd & Trip relay. SE & distance of fault at 18.8 km (Zone 2)	Fault on 66kV Chokha - Changdaphu line	Transient Fault	Reset all the operated relay & indication. Cleared the 66kV line as per BPSO instruction given and hold normal.
2	08-02-2022	02:28	08-02-2022	02:30	0.83	66kV Chokha - Changdaphu line	Chokha Substation	Dist From Relay 21 Optd	DISTANCE PROTN RELAY 21 Optd Indication 1.2 3.12 & 13. 1 General trip. 2 Distance Optd 3 Zone 1 Optd 12 LBB Optd 13 UV Optd & Trip relay. SE & distance of fault at 3.7 km (Zone 3)	Fault on 66kV Chokha - Changdaphu line	Transient Fault	Reset all the operated relay & indication & consult with BPSO and charged the line & hold normal.
3	08-02-2022	03:00	08-02-2022	03:14	1.3	66kV Chokha - Changdaphu line	Chokha Substation	Dist From Relay 21 Optd	DISTANCE PROTN RELAY 21 Optd Indication 1.2 3.12 & 13. 1 General trip. 2 Distance Optd 3 Zone 1 Optd 12 LBB Optd 13 UV Optd & Trip relay. SE & distance of fault at 1.6 km (Zone 1)	Fault on 66kV Chokha - Changdaphu line	Transient Fault	Reset all the operated relay & indication & consult with BPSO and charged the line & hold normal.
4	05-02-2022	03:27	05-02-2022	03:32	1.3	66kV Chokha - Changdaphu line	Chokha Substation	Dist From Relay 21 Optd	DISTANCE PROTN RELAY 21 Optd Indication 1.2 3.12 & 13. 1 General trip. 2 Distance Optd 3 Zone 1 Optd 12 LBB Optd 13 UV Optd & Trip relay. SE & distance of fault at 1.8 km (Zone 1)	Fault on 66kV Chokha - Changdaphu line	Transient Fault	Reset all the operated relay & indication & consult with BPSO and charged the line & hold normal.
5	08-02-2022	04:08	08-02-2022	04:14	1.51	66kV Chokha - Chamachha line	Chokha Substation	Dist From Relay 21 Optd	DISTANCE PROTN RELAY 21 Optd Indication 1.2 3.12 & 13. 1 General trip. 2 Distance Optd 3 Zone 1 Optd 12 LBB Optd 13 UV Optd & Trip relay. SE & distance of fault at 2 km (Zone 1)	Fault on 66kV Chokha - Chamachha line	Transient Fault	Reset all the operated relay & indication & consult with BPSO and charged the line & hold normal.
6	03-02-2022	07:33	03-02-2022	07:32	1	06kV Chokha - Chamachha line	Chokha Substation	Dist From Relay 21 Optd	DISTANCE PROTN RELAY 21 Optd Indication 1.2 3.12 & 13. 1 General trip. 2 Distance Optd 3 Zone 1 Optd 12 LBB Optd 13 UV Optd & Trip relay. SE & distance of fault at 2.9 km (Zone 1)	Fault on 06kV Chokha - Chamachha line	Transient Fault	As per the BPSO instruction given 06kV Chokha - Chamachha breaker kept open due to continuous request. Again as per BPSO instruction 06kV Chokha - Chamachha breaker closed at 07:52 hrs & hold normal.
7	08-02-2022	08:50	08-02-2022	10:53	2	66kV Chokha - Changdaphu line	Chokha Substation	Dist From Relay 21 Optd	DISTANCE PROTN RELAY 21 Optd Indication 1.2 3.12 & 13. 1 General trip. 2 Distance Optd 3 Zone 1 Optd 12 LBB Optd 13 UV Optd & Trip relay. SE & distance of fault at 1.8 km (Zone 1)	Fault on 66kV Chokha - Changdaphu line	Transient Fault	As per the BPSO instruction given 66kV Chokha - Changdaphu breaker closed at 8:58 hrs but it couldn't stand as Distance relay allow to 8.2 km, an alarm 1. Thereby 66kV breaker of Changdaphu was kept open as per BPSO instruction. After instructions 66kV Chokha - Changdaphu breaker closed/cleared at 10:53 hrs as per BPSO instruction and hold normal.
9	05-02-2022	14:45	05-02-2022	14:50	0.0	66kV Chokha - Changdaphu line	Chokha Substation	Earth Fault and Over Current Operated	DISTANCE PROTN RELAY 21 Optd Indication 1.12 & 13. General Trip. 13 LBB Optd. 13 UV Optd & Trip relay. SE	Line Segments	Due to Continuous Over Fault	Reset all the operated relay & indication and after consult with BPSO and charged the line & hold normal.
10	05-02-2022	15:16	05-02-2022	15:16	4.1	66kV Chokha - Changdaphu line	Chokha Substation	Earth Fault and Over Current Operated	DISTANCE PROTN RELAY 21 Optd Indication 1.12 & 13. General Trip. 13 LBB Optd. 13 UV Optd & Trip relay. SE	Line Segments	Due to Continuous Over Fault	Reset all the operated relay & indication and after consult with BPSO and charged the line & hold normal.
11	04-02-2022	13:26	04-02-2022	13:20	13.8	20MVA Transformer - I	All the 33kV Charging feeders was effected	Directional Over Current and Earth fault along with SE relay operated	Directional Over Current and Earth fault along with SE relay operated. Indication 1.1 & 1.2 LBB Optd. 13 UV Optd & Trip relay. SE & distance of fault at 1.8 km (Zone 1)	Line Segments	Temporary fault due to heavy snowfall	Reset the relays and test. Cleared the Transformer and hold normal.
12	08-02-2022	13:26	08-02-2022	13:20	19.7	20MVA Transformer - II	All the 33kV Charging feeders was effected	Directional Over Current and Earth fault along with Breaker operated	Directional Over Current and Earth fault along with Breaker operated. Indication 1.1 & 1.2 LBB Optd. 13 UV Optd & Trip relay. SE & distance of fault at 1.8 km (Zone 1)	Line Segments	Temporary fault due to heavy snowfall	Reset the relays and test. Cleared the Transformer and hold normal.
14	08-02-2022	13:08	08-02-2022	13:09	14.7	The 33kV outgoing was not effected as the feeders was fed from 20MVA Transformer II	Directional Over Current and Earth fault along with SE relay operated. Indication 1.1 & 1.2 LBB Optd. 13 UV Optd & Trip relay. SE & distance of fault at 1.8 km (Zone 1)	Directional Over Current and Earth fault along with SE relay operated. Indication 1.1 & 1.2 LBB Optd. 13 UV Optd & Trip relay. SE & distance of fault at 1.8 km (Zone 1)	Line Segments	Temporary fault due to heavy snowfall	Reset the relays and test. Cleared the Transformer and hold normal.	
14	08-02-2022	14:45	08-02-2022	14:50	15.9	20MVA Transformer - I	Due to Tripping of 66kV Changdaphu feeders, 20MVA Transformer I was effected	Only Relay SE was operated	Only Relay SE was operated	Line Segments	Temporary fault due to heavy snowfall	Reset the relays and test. Cleared the Transformer and hold normal.
14	08-02-2022	14:45	08-02-2022	14:50		66kV Bus Coupler	The 33kV outgoing was not effected as the feeders was fed from 20MVA Transformer II	Over Current and Earth fault along with SE relay operated. Indication 1.1 & 1.2 LBB Optd. 13 UV Optd & Trip relay. SE & distance of fault at 1.8 km (Zone 1)	Over Current and Earth fault along with SE relay operated. Indication 1.1 & 1.2 LBB Optd. 13 UV Optd & Trip relay. SE & distance of fault at 1.8 km (Zone 1)	Line Segments	Temporary fault due to heavy snowfall	Reset the relays and test. Cleared the 66kV Bus and hold normal.
16	05-02-2022	15:10	05-02-2022	15:18	8.5	20MVA Transformer - I	The 33kV outgoing was not effected as the feeders was fed from 20MVA Transformer II	Over Current and Earth fault along with SE relay operated. Indication 1.1 & 1.2 LBB Optd. 13 UV Optd & Trip relay. SE & distance of fault at 1.8 km (Zone 1)	Over Current and Earth fault along with SE relay operated. Indication 1.1 & 1.2 LBB Optd. 13 UV Optd & Trip relay. SE & distance of fault at 1.8 km (Zone 1)	Line Segments	Temporary fault due to heavy snowfall	Reset the relays and test. Cleared the Transformer and hold normal.
17	03-02-2022	13:10	03-02-2022	13:18		06kV Bus Coupler	The 33kV outgoing was not effected as the feeders was fed from 20MVA Transformer II	Over Current and Earth fault along with SE relay operated. Indication 1.1 & 1.2 LBB Optd. 13 UV Optd & Trip relay. SE & distance of fault at 1.8 km (Zone 1)	Over Current and Earth fault along with SE relay operated. Indication 1.1 & 1.2 LBB Optd. 13 UV Optd & Trip relay. SE & distance of fault at 1.8 km (Zone 1)	Line Segments	Temporary fault due to heavy snowfall	Reset the relays and test. Cleared the 06kV Bus and hold normal.
18	21-02-2022	08:48	21-02-2022	08:52	19.91	06kV Chokha - Changdaphu line	Chokha Substation	Dist From Relay 21 Optd	DISTANCE PROTN RELAY 21 Optd Indication 1.2 3.12 & 13. 1 General trip. 2 Distance Optd 3 Zone 1 Optd 12 LBB Optd 13 UV Optd & Trip relay. SE & distance of fault at 11.7 km (Zone 1)	Fault on 66kV Chokha - Changdaphu line	Transient Fault	Reset all the operated relay & indication and after consult with BPSO and charged the line & hold normal.



Transmission System Performance Report 2022

(D) 66/33/11kV Lobeysa Substation													
66kV LSA - Basochu feeder													
1	05.02.2022	11:12hrs	05.02.2022	11:20hrs	0	-1.180	66kV LSA - Basochu feeder	66/33/11kV Lobeysa substation	NA	66kV LSA - Basochu feeder tripped at 11:12hrs and charged the line as per BPSO at 11:20hrs from Gewathang substation.			
66kV LSA - Dochula feeder													
1	05.02.2022	01:43hrs	05.02.2022	01:49hrs	0	12.020	66kV LSA - Dochula feeder	NA	Dist & 86 relay operated	66kV LSA - Dochula feeder tripped at 01:43hrs and informed to BPSO and charged at 01:49hrs as per BPSO.			
2	05.02.2022	02:13hrs	05.02.2022	02:29hrs	0	2.439	66kV LSA - Dochula feeder	NA	Dist & 86 relay operated	66kV LSA - Dochula feeder tripped at 02:13hrs and informed to BPSO and charged at 02:29hrs as per BPSO with charging code 1212.			
3	05.02.2022	09:13hrs	05.02.2022	09:31hrs	0		66kV LSA - Dochula feeder	NA	Dist & 86 relay operated	66kV LSA - Dochula feeder tripped at 09:13hrs and informed to BPSO and charged at 09:31hrs as per BPSO.			
4	05.02.2022	09:39hrs	05.02.2022	10:04hrs	0		66kV LSA - Dochula feeder	NA	Dist & 86 relay operated	66kV LSA - Dochula feeder tripped at 09:39hrs and informed to BPSO and charged at 10:04hrs as per BPSO.			
5	05.02.2022	10:58hrs	05.02.2022	23:26hrs	12	5.000	66kV LSA - Dochula feeder	NA	Dist & 86 relay operated	66kV LSA - Dochula feeder tripped at 10:58hrs and informed to BPSO and charged at 23:26hrs as per BPSO with the closing code 1225.			
6	15.02.2022	15:58hrs	15.02.2022	16:11hrs	0	-8.010	66kV LSA - Dochula feeder	66/33/11kV Lobeysa substation	NA	66kV LSA - Dochula feeder tripped at 15:58hrs and informed to BPSO and charged at 16:11hrs, at that time supply was feeded from Dochula to Gewathang end since their was line problem between Gewathang to Basochu (One phase conductor snapped).			
7	15.02.2022	18:28hrs	16.02.2022	17:57hrs	23	-7.990	66kV LSA - Dochula feeder	66/33/11kV Lobeysa substation	Dist & 86 relay operated	66kV LSA - Dochula feeder tripped at 18:28hrs and informed to BPSO kept the feeder trip and the supply was remained from Basochu at 19:03hrs and Dochula supply synchronized at 17:57hrs on 16.02.2022 after rejumping at tower No.31 with the closing code 1821.			
(E) 66/33/11 kV Paro Substation													
1	05.02.2022	00:25hrs 01:09hrs	05.02.2022	00:56hrs 04:30hrs			66kV Haa line 66kV Haa line						
2	05.02.2022	24:56hrs 02:05hrs	01.03hrs 04:10hrs	2	6 5		66kV chumde line	Paro ss	Due to heavy snow fall No relay operation	Long			
3	14.02.2022	06:50hrs 07:05hrs	06:53hrs 07:21hrs	5 18	6 5		66kV chumde line	Paro ss	Tripped from changedaphu No relay operation	transient			
4	21.02.2022	08:46hrs	21.02.2022	09:39hrs			66kV chumde line	Paro ss	Tripped from changedaphu No relay operation	transient			
(F) 66/33/11kV Jemina Substation													
1	05.02.2022	00:07	05.02.2022	14:14	21	4.62	Both 66kV feeder chumde and changedaphu	Blackout	O/C	186 & 86	line segment	Upon test charging at 14:14 Hrs, line stood normal (66kV olakha via changedaphu fdr. Jumping out at IT park area.)	
2	21.02.2022	08:48	21.02.2022	09:39	0		66kV Changedaphu feeder	66kV Changedaphu feeder	No relay operation at jemina end.	line segment	66kV supply fail from changedaphu end and resumed at 09:39hrs.		
(G) 66/33/11kV Dechencholing substation													
1	01.02.2022	16:58hrs	01.02.2022	17:05hrs	0	-37.17	66KV Sesmtocha IC	whole s/s fdr	Supply failed from source. According to the Sesmtocha operator line tripped due to under voltage.				
2	05.02.2022	00:00hrs	05.02.2022	00:05hrs	0	0.747	66KV Damji Fdr.	Damji line	Tripped on dist relay optd.	Dist relay, 86A, 86B Zone-1	not known	Tripped	Test charged the fdr after getting closing code, 1205 from BPSO fdr stand normal.
3	05.02.2022	01:35hrs	09.02.2022	10:46hrs	105hrs	0	66KV Damji Fdr.	Damji line	Tripped on dist relay & O/C relay.	Dist relay, 86A, 86B Zone-1, 4.661KM, LA 5 530A, IB 1.819A, IC 1.820A		It is confirmed that line has fault and issued the work permit to Olakha TMD for line pestrolling. later they have found that two conductor was snapped and they re-stringing the conductor and brought back line to normal on dt 09.02.2022 at 10:46hrs.	
4	05.02.2022	09:13hrs	05.02.2022	09:20hrs	0	-4.528	66KV Sesmtocha IC	whole s/s fdr	Supply failed from Source.				
5	05.02.2022	09:39hrs	05.02.2022	09:43hrs	0	-4.528	-do-	whole s/s fdr	Supply failed from Source.				
6	05.02.2022	10:58hrs	05.02.2022	11:04hrs	0	-5.439	-do-	whole s/s fdr	Supply failed from Source.				
7	15.02.2022	13:58hrs	15.02.2022	16:07	0	-37.38	66KV Sesmtocha IC	whole s/s fdr	Tripped on 86 relay optd	86 relay optd.		Tripped	Test charged the fdr as per the instruction BPSO officials since there will be back out.
(H) 66/11kV Haa Substation													
1	04.02.2022	20:19	04.02.2022	20:27	0	-2.81	66kV Incomer	All the feeders	unknown	O/C	Pangbesa	Supply failed from Pangbesa substation on operating over current. The same was normalised from their end.	
2	04.02.2022	20:54	04.02.2022	21:04	0	-2.81	66kV Incomer	All the feeders	unknown	O/C on three phases	Chumdo	Supply failed from Pangbesa substation on operating over current. The same was normalised from their end.	
3	04.02.2022	22:06	05.02.2022	15:19	18hrs	-2.81	66kV Incomer	All the feeders	conductor twisted	O/C on three phases	Chapcha	Supply failed from Chumdo substation on operating over current. The same was normalised from their end.	
4	20.02.2022	21:51	20.02.2022	21:41	0	-2.7	66kV Incomer	All the feeders	unknown	O/C on three phases	Chumdo end	Supply failed from Chumdo substation on operating over current on all the phases. The same was normalised from their end.	
5	21.02.2022	08:48	21.02.2022	10:00	0	-2.5	66kV Incomer	All the feeders	unknown	O/C on three phases	Chumdo end	Supply failed from Chumdo substation on operating over current on all the phases. The same was normalised from their end.	



Transmission System Performance Report 2022

(D) 220kV Substation Sentsokha												
66kV and above Tripping												
1	06.02.2022	10:13hrs	06.02.2022	10:25hrs		-59.020	220kV Sem-BHP	Sentsokha Substation	Phase to Phase Fault	Main-1 Zone 1 Trip, fault loop- L2-L2	Distance= 11.3KM	Transient
2	05.02.2022	01:43hrs	05.02.2022	01:46hrs		43.09	66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L1-L2	Dist. EF Fault, fault loop- L1-N R, Y Bph Trip	Distance=0.5KM	Transient
3	05.02.2022	02:12hrs	05.02.2022	02:16hrs		1.55	66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L1-L2	Dist. Prot. Optd, fault loop- L1-L2	Distance=0.5KM	Transient
4	05.02.2022	09:13hrs	05.02.2022	09:20hrs		51.46	66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L1-L2	Dist. Prot. Optd, I>2 Trip, Y&Bph Trip, Fault loop=L1-L2	Distance=0.00KM	Transient
5	05.02.2022	09:39hrs	05.02.2022	09:46hrs		5.45	66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L1-L2	Dist. Prot. Optd, I>2 Trip, Y&Bph Trip, Fault loop=L1-L2	Distance=0.00KM	Transient
6	05.02.2022	10:38hrs	05.02.2022	10:40hrs		0.42	66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L1-L2	Dist. Prot. Optd, I>2 Trip, Y&Bph Trip, Fault loop=L1-L2	Distance=0.00KM	Transient
7	05.02.2022	10:58hrs	05.02.2022	11:32hrs		0.42	66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L1-L2	Dist. Prot. Optd, I>2 Trip, Y&Bph Trip, Fault loop=L1-L2	Distance=0.00KM	Transient
8	05.02.2022	11:45hrs	05.02.2022	22:44hrs	11	0.42	66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L1-L2	Dist. Prot. Optd, I>2 Trip, Y&Bph Trip, Fault loop=L1-L2	Distance=0.00KM	Transient
9	15.02.2022	15:57hrs	15.02.2022	16:11hrs		64.62	66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L1-L2	Dist. Prot. Optd, fault loop- L1-L2, (Ia= 536.5A, Ib=525.8A, Ic=538.0A)	Distance=0.00KM	Transient
10	15.02.2022	18:27hrs	15.02.2022	18:39hrs			66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L1-L2	Dist. Prot. Optd, fault loop- L1-L2	Distance=12.00KM	Transient
11	15.02.2022	18:46hrs	15.02.2022	18:59hrs			66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L2-N	Dist. Prot. Optd, Yph Trip, fault loop- L2-N	Distance=8.7KM	Transient
12	05.02.2022	02:29hrs	05.02.2022	02:33hrs		9.32	66kV Sem-Olakhia Line	Olakhia Substation	Overcurrent Trip	Back Up Relay Optd, I>> Trip, Y&Bph Trip		Transient
13	05.02.2022	03:10hrs	05.02.2022	03:14hrs		8	66kV Sem-Olakhia Line	Olakhia Substation	Overcurrent Trip	Back Up Relay Optd, I>> Trip, Y&Bph Trip		Transient
14	05.02.2022	3:28hrs	05.02.2022	03:31hrs		8	66kV Sem-Olakhia Line	Olakhia Substation	Overcurrent Trip	Back Up Relay Optd, I>> Trip, Y&Bph Trip		Transient
15	05.02.2022	04:09hrs	05.02.2022	04:13hrs		6.11	66kV Sem-Olakhia Line	Olakhia Substation	Overcurrent Trip	Back Up Relay Optd, I>> Trip, Y&Bph Trip		Transient
16	05.02.2022	05:54hrs	05.02.2022	05:56hrs		7.72	66kV Sem-Olakhia Line	Olakhia Substation	Overcurrent Trip	Back Up Relay Optd, I>> Trip, Y&Bph Trip		Transient
17	05.02.2022	08:52hrs	05.02.2022	08:55hrs		15.17	66kV Sem-Olakhia Line	Olakhia Substation	Overcurrent Trip	Back Up Relay Optd, I>> Trip, Y&Bph Trip		Transient
18	01.02.2022	16:59hrs	01.02.2022	17:06hrs		19.05	66kV Sem-Dechencholing Line	Dechencholing Substation	Under Voltage	Dist. Prot Optd, Rph Under Voltage Trip		Transient
19	05.02.2022	01:43hrs	05.02.2022	01:45hrs			66kV Sem-Dechencholing Line	Dechencholing Substation	Overcurrent Trip	Dist. Prot Optd, Over current Trip		Transient
20	05.02.2022	02:12hrs	05.02.2022	02:14hrs		4.78	66kV Sem-Dechencholing Line	Dechencholing Substation	Overcurrent Trip	Dist. Prot Optd, Over current Trip		Transient
21	05.02.2022	09:39hrs	05.02.2022	09:43hrs		4.78	66kV Sem-Dechencholing Line	Dechencholing Substation	Under Voltage	Dist. Prot Optd, Under Voltage Trip		Transient
22	05.02.2022	10:38hrs	05.02.2022	10:39hrs		5.21	66kV Sem-Dechencholing Line	Dechencholing Substation	Under Voltage	Dist. Prot Optd, Under Voltage Trip		Transient
23	05.02.2022	10:58hrs	05.02.2022	10:04hrs		5.51	66kV Sem-Dechencholing Line	Dechencholing Substation	Under Voltage	Dist. Prot Optd, Under Voltage Trip		Transient
24	05.02.2022	11:45hrs	05.02.2022	11:48hrs		5.51	66kV Sem-Dechencholing Line	Dechencholing Substation	Under Voltage	Dist. Prot Optd, Under Voltage Trip		Transient
25	05.02.2022	18:41hrs	05.02.2022	18:49hrs		5.51	66kV Sem-Dechencholing Line	Dechencholing Substation	Under Voltage	Dist. Prot Optd, Under Voltage Trip		Transient
26	05.02.2022	15:58hrs	05.02.2022	16:06hrs		33.3	66kV Sem-Dechencholing Line	Dechencholing Substation	Broken Conductor	Dist. Prot Optd, Broken conductor Trip		Transient



Transmission System Performance Report 2022

D) 66/33/11kV Pangbesa substation												
1	04.02.2022	20.15hrs	04.02.2022	20.29hrs	0	2.25	Haa line out	Haa substation	Due to heavy snow fall	Distance		transient
2	04.02.2022	20.55hrs	04.02.2022	21.06hrs	0	2.18	Haa line out	Haa substation	Due to heavy snow fall	Distance		transient
3	04.02.2022	22.27hrs	05.02.2022	14.35hrs	16		66kV chumdo line	Pangbasa /Haa substation	Due to heavy snow fall	No relay operation		Long
4	05.02.2022	22.27hrs	05.02.2022	14.35hrs	16		66kV chumdo line	Pangbasa /Haa substation	Due to heavy snow fall	No relay operation		Long
5	05.02.2022	24.56hrs 02.05hrs	05.02.2022	01.02hrs 04.10hrs	0		66kV chumdo line	Pangbasa /Haa substation	Due to heavy snow fall	No relay operation		Long
6	20.02.2022	21.31hrs	20.02.2022	21.41hrs			66kV chumdo line	Pangbasa /Haa substation	Tripped from chumdo			transient
7	21.02.2022	21.31hrs	20.02.2022	21.41hrs			66kV chumdo line	Pangbasa /Haa substation	Tripped from changedaphu	No relay operation		transient
(K) 66/33kV Changidaphu Substation												
1	05.02.2022	04:11hrs	05.02.2022	06:01hrs	1		66kV Changidaphu - Jemina Line	Changidaphu, Jemina, Chumdu, Paro and Haa Substation	Grid failed	CB hand tripped from Jemina end as per BPSO advice		Transient
2	21.02.2022	08:49hrs	21.02.2022	09:38hrs		19.31	66kV Changidaphu - Jemina Line	Changidaphu	Grid failed	Dist. Prtn trip, Zone 1 Y&Bph trip.		Transient
3	05.02.2022	06:00hrs	05.02.2022	08:19hrs	2		66kV Changidaphu - Olakha Line	Olakha, Changidaphu, Jemina, Chumdu, Paro and Haa Substation	Over Current	Dist. Prtn trip, Zone 1 RY&Bph trip. Over Current trip		Transient
(L) 66/33kV Damji Substation												
1	01.02.2022	1658 hrs	01.02.2022	1707 hrs	0	-4.45	66 kV Incoming Line	Whole Substation	Trip	NA		Line trip from Semtokha Substation due to under voltage
2	05.02.2022	0001 hrs	11.02.2022	1115 hrs	6 days & 11 hrs	-2.72	66 kV Incoming Line	Whole Substation	Trip	NA		66 kV Line Fault between Ding & Damji Substation, kept feeder open
3	15.02.2022	1559 hrs	15.02.2022	1607 hrs	0	-3.67	66 kV Incoming Line	Whole Substation	Trip	NA		Line trip from Semtokha Substation
(M) 66/11kV Dochula Substation												
1	16/2/2022	14:40	16/2/2022	18:07	3	50.07MW		Shut down taken to connect jumpering at Dochula Tower location SW31 with opening code 0365 and closing code 1281		Tower location SW31	Connection of jumper	



Transmission System Performance Report 2022

March 2022

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/Lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
(A) 600/220/66/11 kV Malbase Substation													
66kV & Above													
1	13.03.2022	23:08	14.03.2022	13:05	13		66kV Pasakha feeder IV	Malbase s/s	Overcurrent & Earthfault	51N-startIOC-50-start,50 optd,general trip,IEF-50N trip			R phase=1916.55A<-166.86 deg, Y phase=101.55A<-4.6deg, B phase=67.021A<-61.93deg, N=1916.55<-166.06deg.
2	13.03.2022	23:00	13.03.2022	23:23	0		66kV Pasakha feeder I	Malbase s/s	Overcurrent & Earthfault	51N-startIOC-50-start,50 optd,general trip.			R phase=2552.36A<-162.73 deg, Y phase=54.6A<-154.5deg, B phase=61.34A<-179.5deg, N=2606.11A<-17.02deg.
3	13.03.2022	23:08	13.03.2022	23:23	0		66kV Pasakha feeder II	Malbase s/s	Overcurrent & Earthfault	51N-startIOC-50-start,50 optd,general trip.			R phase=2306.81A<-170.6deg, Y phase=591.24A<-93.34deg, B phase=546.46A<-47.67deg, N=2306.01A<-170.6deg.
4	13.03.2022	23:00	13.03.2022	23:23	0		66kV Bus coupler	Malbase s/s	Overcurrent & Earthfault	50N trip			R phase=544.2A<-10.02deg, Y phase=110.63A<-18.33deg, B phase=110.63A<-32.1deg, N=772.63A<-21.75deg.
(B) 220/66/11 kV Singhiyeon Substation													
1	13.03.2022	23:08	14.03.2022	13:04	18	-3	66kV Bhutan Concept Feeder	Singhiyeon substation	overcurrent	IE-> DIR trip, I-> DIR trip, Directional time o/e trip			IL1=50.16kA, IL2=0.4kA, IL3=0.3kA.
(C) 66/11/11 kV Gedu Substation													
1	01.02.2022	16:58	01.02.2022	17:12	0	2.78	66kV Income	Gedu Substation	Bad weather condition		Line segment		Tripped on both the 66kV Chikha and Phantsholing end. Charged from Chikha end.
2	02.02.2022	8:04	02.02.2022	8:42	0	2.8	66kV Income	Gedu Substation	Bad weather condition		Line segment		Tripped on both the 66kV Chikha and Phantsholing end. Charged from Phantsholing end.
3	08.02.2022	8:28	08.02.2022	8:52	0	3	66kV Income	Gedu Substation	Bad weather condition		Line segment		Tripped on both the 66kV Chikha and Phantsholing end. Charged from Chikha end.
4	20.02.2022	23:10	20.02.2022	23:25	0	1.58	66kV Income	Gedu Substation	Bad weather condition		Line segment		Tripped on both the 66kV Chikha and Phantsholing end. Charged from Chikha end.
5	21.02.2022	1:56	21.02.2022	2:21	0	0.93	66kV Income	Gedu Substation	Bad weather condition		Line segment		Tripped on both the 66kV Chikha and Phantsholing end. Charged from Phantsholing end.
6	21.02.2022	13:20	21.02.2022	13:53	0	2.33	66kV Income	Gedu Substation	Bad weather condition		Line segment		Tripped on both the 66kV Chikha and Phantsholing end. Charged from Phantsholing end.
7	25.02.2022	16:16	25.02.2022	16:34	0	2.4	66kV Income	Gedu Substation	Bad weather condition		Line segment		Tripped on both the 66kV Chikha and Phantsholing end. Charged from Chikha end.
(D) 220/66/33 kV Dhamchung Substation													
1	21.02.2022	15:27	21.02.2022	16:00	0	5.35	50/43MVA TIE# 1 (2002)	Dhamchung	Treatment Fault	RET670	N/A	N/A	Fault Mag:128.11kV and Fault angle :-7.55Deg.
2	21.02.2022	15:27	21.02.2022	15:59	0	5.32	50/63 MVA TIE# 2 (2005)	Dhamchung	Treatment Fault	RET670	N/A	N/A	Fault Mag:120.11kV and Fault angle :-7.35Deg.
3	21.02.2022	15:27	21.02.2022	17:01	1	0.1	66kV Gomtu fir.	Gomtu	Treatment Fault	RET670,General trip,Zone 1 trip, R phase and Bc relay trip.	N/A	-	Fault value:R phase fault mag:3499.74Ams and fault angle :-74.35 deg.
Tripping Report for the month of MARCH 2022													
Sl. No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/Lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
(A) 66kV Chomdu switching station													
1	07.03.2022	12:44hrs	07.03.2022	13:03hrs	19	1.38MW	66kV Jemina feeder	Fed from 66kV Chikha	Trip	O's, 3ph, CB open	Chomdu	Trip	
(B) 66/33kV Wangi Substation													
1	15/3/2022	14:33hrs	15/3/2022	14:36hrs	3	2600MW	66kV SF6 breaker	Fdr I and II	OC, OCH, EF and EFT on ABC phase	OC, OCH, EF and EFT on ABC phase	66kV SF6 breaker	Tripped	LT line cutoff and touches HT line at longi chapcha as per IESD Chapcha
(C) 66/33/11kV Lohyeya Substation													
66kV LSA - Basochu feeder													
1	07.03.2022	12:53hrs	07.03.2022	13:04hrs	0	-18.960	66kV LSA - Basochu feeder	66/33/11kV Lohyeya substation		NA			66kV LSA - Basochu feeder tripped at 12:53hrs and charged the line as per BPSO at 13:04hrs (CBd ftd)
66kV LSA - Dochula feeder													
1	07.03.2022	12:53hrs	07.03.2022	13:04hrs	0	14.000	66kV LSA - Dochula feeder	66/33/11kV Lohyeya substation		NA			66kV LSA - Dochula feeder tripped at 12:53hrs and charged the line as per BPSO at 13:04hrs (CBd ftd)
(D) 66/33/11kV Dechencholing substation													
1	07.03.2022	12:53hrs	07.03.2022	13:03hrs	0	-30.71	66kV Samsatokha IC	whole s/s fdr	Supply failed from source				
2	20.03.2022	14:56hrs	20.03.2022	15:05hrs	0	26.28	66kV Samsatokha IC	whole s/s fdr	Supply failed from source				
3	20.03.2022	14:25hrs	20.03.2022	22:09hrs	10hrs	1.942	66kV Dampi Fdr	Tripped at Samsatokha IC	While test charging fdr was not hold, then Chikha TMD team had started doing line patrolling about three days, however TMD didn't find the fault, later fault was at Substation side, then supply failed from source.				
4	20.03.2022	24:43hrs	20.03.2022	22:50hrs	0	19.48	66kV Samsatokha IC	whole s/s fdr	Supply failed from source				
5	25.03.2022	20:25hrs	28.03.2022	16:51hrs	66hrs	3.957	66kV Dampi Fdr.	Dampi line	Tripped on over current & Earthfault relay optd.	O-C & E-F relay, 86A, 86B	Dampi S/S	Tripped	Operator observed heavy sparks in Y phase Cable joint at Dampi and it took few days to repair the cable and charging the fdr.
66kV side shut down													
1	09.03.2022	11:08hrs	09.03.2022	13:07hrs	2hrs	4.081	66kV Dampi Fdr.	Dampi line	Shut down taken by Lohyeya TMD team to cleared the ROW of Dampi line toward Gasa site.				
(E) 66/11kV Haas Substation													
1	19.03.2022	12:35	19.03.2	12:44	0	-2.01	All the feeders	unknown	O/C	Chomdu			Supply failed from Chomdu substation on operating over current. The same was normalised from their end. Supply failed from Panjyera substation on operating over current. The same was normalised from their end.
(F) 220kV Substation Samsatokha													
1	20.03.2022	14:26hrs	09.03.2022	14:33hrs	29	020	66kV Sem-Dechencholing Line	Dechencholing Substation	Earth Fault	Dist. Trip, Icc-> trip		Transient	
2	20.03.2022	14:33hrs	20.03.2022	14:40hrs	29	020	66kV Sem-Dechencholing Line	Dechencholing Substation	Earth Fault	Dist. Trip, Icc-> trip		Transient	
3	20.03.2022	14:58hrs	20.03.2022	15:04hrs	14	120	66kV Sem-Dechencholing Line	Dechencholing Substation	Earth Fault	Dist. Trip, Icc-> trip		Transient	
4	23.03.2022	25:40hrs	23.03.2022	22:50hrs	12	360	66kV Sem-Dechencholing Line	Dechencholing Substation	Earth Fault	Dist. Trip, Icc-> trip		Transient	
D66/33/11kV Pangyera substation													
1	19.03.2022	12:35hrs	19.03.2022	12:35hrs	0	1.45	Haas line cut	Haas substation	O-C	Distances		Transient	Stormy weather
(G) 66/33kV Dampi Substation													
1	07.03.2022	12:55 hrs	07.03.2022	13:06 hrs	0	-3.93	66 kV Incoming Line	Whole Substation		NA			Line tripped from Samsatokha Substation
2	09.03.2022	11:09	09.03.2022	13:07 hrs	2	-3.97	66 kV Incoming Line	Whole Substation		NA			Shutdown avail by Mr. Kemu Wamda TMD/ ILOyey for RoW clearing
3	20.03.2022	14:25 hrs	21.03.2022	22:09 hrs	127	-3.9	66 kV Incoming Line	Whole Substation		NA			66 kV Line Fault due to cable termination for failure at Gantry of Dampi Substation. Used Inconcrete II cable.
4	25.03.2022	20:25 hrs	28.03.2022	16:53 hrs	92	-3.9	66 kV Incoming Line	Whole Substation		NA			66 kV Line Fault due to cable termination for failure at Gantry of Dampi Substation. Restore incoming I cable. Cleared CD of 66 kV bus at 18:24 hrs.



Transmission System Performance Report 2022

April 2022

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Remarks
(A) 400/220/66/11 kV Malbase Substation												
66kV & Above												
1	10.04.2022	13:02	10.04.2022	13:07	0	7	220kV samtse feeder	Malbase s/s		O/C trip, I >> trip		IL1= 44.48A<234.8deg, IL2=90.3A<235.5deg, IL3=7301A<42.27 deg IL4=7149A<42.78deg
2	10.04.2022	13:02	10.04.2022	13:10	0	25	50/63MVA transformer 3	Malbase s/s		Diff trip		IR=327.52A<-65.89deg, IY=298.26A<173.79deg, IB=25.9A<95.63deg IN=292.13A<-124.45deg
3	14.04.2022	18:22	14.04.2022	18:25	0	-	220kV Bus Coupler	220kV samtse and singhigoan feeder and Malbase s/s		I0>trip, 86A and 50/50N trip		Earthfault
4	14.04.2022	18:22	14.04.2022	18:54	0	8	220kV samtse feeder	220kV Bus Coupler		Diff start L3 86 relay optd		IL1=2924A<269.2deg, IL2=87.22A<182.2deg, IL3=2847A<53.11deg IL4=1800A<337.8deg
5	14.04.2022	18:22	14.04.2022	18:27	0	26	50MVA transformer III(HV/LV) side	220kV buscoupler and Samtse feeder		Diff start L3 86 relay optd, Diff alarm b/k	malbase Substation	I1=55.56A< 89.49deg, I2=57.63A<-35.36deg,I3=60.02A<162.8deg,I4=10.87A155.22deg.
6	15.04.2022	01:34	15.04.2022	01:44	0	-186	400kV Tala feeder	Malbase s/s	O/C Y&B phase(Transient fault)	Air lockout shot, zone 1 trip, FL=18.57kM	18.57kM	IL1=186.5A, IL2=4.072kA, IL3=4.273KA
7	15.04.2022	14:00	15.04.2022	14:05	0	28	66kV Pasakha feeder 4	Malbase S/s	O/C on B phase	Relay 86 optd, general trip IEF 50N trip		IL1=137.27A<-5.27.8deg, IL2=311.69A<-134.17deg,IL3=2029.25A<72.98deg
8	16.04.2022	19:15	16.04.2022	19:24	0	7	220kV samtse feeder	Malbase S/s	Earthfault	Main I trip, Zone 1 trip	L3-L1 Dist=40.2kM	IL1=2995A<273.8deg, IL2=68.79A<186.2deg,IL3=2035A<51.5deg,IL4=2001A<314.6deg
9	19.04.2022	17:13	19.04.2022	18:08	0	8	220kV samtse feeder	Malbase S/s		O/C on 3phase	22.1km	I1=3778A<285.2deg,I2=4005A<164.9deg,I3=5084A<37.26deg,I4=1283A<26.58deg
10	27.04.2022	11:03	27.04.2022	11:22	0	9.1	220kV samtse feeder	Malbase S/s	O/C & E/F trip	Main I trip, Zone 1 trip, Trip Y B, B/U trip	fault loop L1-N=2.8km	IL1=8343A<285.9deg,IL2=39.17A<113.4deg,IL3=94.11A<110.8deg,IL4=7931A<293.5deg
11	27.04.2022	11:03	27.04.2022	11:17	0	23	50/63MVA transformer 1	Malbase S/s		LBBtrip, general trip, relay86 optd		IL1=73.68A<-18.22deg,IL2=82.54A<-64.24deg,IL3=154.98A<-1.72deg
12	27.04.2022	11:03	27.04.2022	11:19	0	25	50/63MVA transformer 3	Malbase S/s		Diff trip, 27trip and B/U trip		IL1=108.55A<115.19deg,IL2=96.4A<170.17deg,IL3=74.83A<121.3deg,IL4=342.73A<129.47deg
13	29.04.2022	08:11	29.04.2022	08:16	0	97	200MVA ICT	Malbase S/s		Diff Y phase,67 O/C, 86 opted		IL1=33.08A<139.7deg,IL2=34.71A<15.76deg,IL3=32.8A<-108.3deg
14	30.04.2022	12:45	30.04.2022	12:48	0	67	200MVA ICT	Malbase S/s		Diff trip, diff B phase,M & TI CB open, 86 opt		IL1=81.84A<103.3deg,IL2=113.9A<-13.39deg,IL3=113.4A<-172.1deg
(B)220/66/11 kV Singhigoan Substation												
1	14.04.2022	18:22	14.04.2022	23:19	4	1.9	220kV Singhi-samtse feeder	Singhi S/s	O/C	86 opted,O/C relay	line	I1=2140A, I2=84.91A, I3=2513A, I4=1454A
2	16.04.2022	14:00	16.04.2022	15:08	1	35	66kV BFAL feeder	Singhi S/s	O/C on B phase	General trip, O/C trip, Dir Time O/C trip, IE >> DIR trip, I>> Dir trip, IEP DIR TRIP		IL1=1.18kA,IL2=1.24kA,IL3=11.74kA



Transmission System Performance Report 2022

(B) 66/33/11 kV Phuntsholing Substation												
1			01.04.2022	10:18	10	idle	66kV Pling-Malbase feeder				At 10:18hrs charged 66kV Pling-Malbase feeder which was under idle charged condition with closing code 1376 from BPSO, since there was shutdown on 66kV Chukha-Pling (Chukha-Gedu section for RoW clearing and replacement of disc insulators at PC 135 & 136. At 17:35hrs 66kV Pling-Malbase feeder kept under idle condition with opening code 0475 from BPSO (CB opened at our end).	
2			01.04.2022	10:30	10	idle	66kV Pling-Malbase feeder				At 10:38hrs charged 66kV Pling-Malbase feeder which was under idle charged condition with closing code 1382 from BPSO, since there was shutdown on 66kV Pling-Gomtu feeder for carrying out re-alignment of isolators, checking of control circuit and arresting of oil seepage from PT. At 20:38hrs 66kV Pling-Malbase feeder kept under idle condition with opening code 0484 from BPSO. (CB opened at our end).	
##	04.04.2022	04:02	04.04.2022	04:05	0		66kV Chukha and 66kV Gomtu feeder	66kV Chukha and 66kV Gomtu feeder	Tripped at their end	Nil	Tripped at their end	Phuentsholing got black out, since both 66kV Chukha and 66kV Gomtu feeder got tripped from their end.
##			07.04.2022	13:00	13	idle	66kV Pling-Malbase feeder					At 13:08hrs charged 66kV Pling-Malbase feeder which was under idle charged condition with closing code 1420 from BPSO, since there was shutdown on 66kV Pling-Gomtu feeder for rectification of Bus Isolator of 5MVA transformer at Gomtu end. At 20:59hrs 66kV Pling-Malbase feeder kept under idle condition with opening code 0508 from BPSO. (CB opened at our end).
##			10.04.2022	16:56	16	idle	66kV Pling-Malbase feeder					At 16:56hrs charged 66kV Pling-Malbase feeder which was under idle charged condition with closing code 1444 from BPSO, since there was shutdown on 66kV Pling-Gomtu feeder for carrying out maintenance on 66kV Bus Isolator of 5MVA transformer at Gomtu end. At 19:08hrs 66kV Pling-Malbase feeder kept under idle condition with opening code 0517 from BPSO. (CB opened at our end).
##	14.04.2022	18:20	14.04.2022	18:28	0		66kV Chukha and 66kV Gomtu feeder	66kV Chukha and 66kV Gomtu feeder	Tripped at their end	Nil	Tripped at their end	Phuentsholing got black out, since both 66kV Chukha and 66kV Gomtu feeder got tripped from their end.
##	16.04.2022	15:32	16.04.2022	15:45	0	-1.87	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder	Tripped at both end	Dist Optd, 106 & 86	Substation	The cause of tripping was due to transient fault.
##	16.04.2022	20:25	16.04.2022	20:30	0	-1.50	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder	Overcurrent	I>>, Ia-1.055kA, Ib-1.037kA, Ic-51.26A Vab-11.89kV, Vbc-56.37kV, Vca-57.98kV In measured-7.003A In derived-7.182A, Van-20.24kV, Vbv-18.67kV, Vcn-38.38kV & 86	Tripped at their end	The cause of tripping was due to transient fault.
##	29.04.2022	08:11	29.04.2022	08:18	0	-1.98	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder	Tripped at both end	Dist Optd, 106 & 86	Tripped at both end	The cause of tripping was due to transient fault.
(D) 66/33/11 kV Gedu Substation												
1	01.04.2022	10:25	01.04.2022	17:08	6	2.023	66kV Chukha -Gedu section	Nil	Critical tree falling within the ROW and replacement of disc insulators at PC-135 and 136.		Line segment	Shutdown taken by TMD BPC Olakha for Critical tree falling within the ROW and replacement of disc insulators at PC-135 and 136.
2	04.04.2022	4:00	04.04.2022	4:05	0	2	66kV Chukha-Pling Supply tripped.	Blackout	Bad weather		Line segment	Charged from Chukha
3	14.04.2022	18:20	14.04.2022	18:30	0	2.045	66kV Chukha-Pling Supply tripped.	Blackout	Bad weather		Line segment	Charged from Chukha
4	16.04.2022	15:34	16.04.2022	15:43	0	0.88	66kV Chukha-Pling Supply tripped.	Blackout	Bad weather		Line segment	Charged from Chukha
5	16.04.2022	20:22	16.04.2022	20:31	0	1.68	66kV Chukha-Pling Supply tripped.	Blackout	Bad weather		Line segment	Charged from Chukha



Transmission System Performance Report 2022

(E) 66/33/11 kV Gomtu Substation												
1	03.04.2022	10:44	03.04.2022	12:49	2	3.06	66/11kV 5MVA Transformer	Nil	For sealing bus PT leakage	Nil	Gomtu Substation	Shutdown for sealing bus PT leakage against work permit NO. 12
2	03.04.2022	10:44	03.04.2022	20:25	9	3.06	66kV Pling feeder	Nil	Maintenance	Nil	Gomtu Substation	Avalled shutdown by SMG for sealing Bus PT leakage, fix line isolator alignment and CT and breaker testing. Against work permit NO. 12
3	04.04.2022	03:37	04.04.2022	04:10	0	-2.068	66kV Dhamdhum feeder	Nil	General trip	Zone 1, Z-Com & Y PH fault	Damdum Substation	Supply failed from Dhamdhum end
4	04.04.2022	04:02	04.04.2022	04:05	0	-2.06	66kV Pling feeder	Gomtu	General trip	Nil	Line Segment	Grid failed
##	14.04.2022	18:23	14.04.2022	19:01	0	-7.137	66kV Dhamdhum feeder	Gomtu	Grid failed	Nil	Line Segment	Grid failed and supply resumed at 19:01 hrs.
##	14.04.2022	18:23	14.04.2022	18:28	0	3.58	66kV Pling feeder	Gomtu	Grid failed	Nil	Line Segment	Grid failed and supply resumed at 18:28 hrs.
##	16.04.2022	19:22	16.04.2022	19:39	0	-6.184	66kV Dhamdhum feeder	Nil	General trip	Nil	Line Segment	Charged against charging code no.1021 provided by BPSO and charge withstand
##	25.04.2022	14:25	25.04.2022	16:25	2	0.01	66/33/11kV 5MVA Transformer	Nil	Oil leakage	Nil	Gomtu Substation	Avalled shutdown by Substation Head against Work Permit No. 031 for sealing oil leakage form OLTC tank
##	27.04.2022	11:25	27.04.2022	11:41	0	-8.268	66kV Pling feeder	Nil	Transient fault	Nil	Gomtu Substation	Charged the line after informing BPSO and charge withstand. Charging code 1083
(F) 220/66/33 kV Dhamdum Substation												
1	14.04.2022	18:32	14.04.2022	18:58	0	-8.35	220KV Malbase	Dhamdum	heavy rain with thunder storm and wind	REL 670 trip	NA	Line tripped due to O/C on R&B0, Zone: 1(General trip)
2	14.04.2022	18:32	15.04.2022	10:48	16	-1.66	Singeygoan	Dhamdum	heavy rain with thunder storm and wind	REL 670 trip	NA	Line tripped due to O/C on R&B0, Zone: 1(General trip) Fdr charged against charging code no 1007 from Karma Yangden from BPSO.
3	16.04.2022	19:14	16.04.2022	19:21	0	-1.76	220kV Singeygoan	Dhamdum	heavy rain with thunder storm and windy	REL 670 trip	NA	Line tripped due to O/C on R&B0, Zone: 1(General trip) Fdr charged against charging code no 1020 from Karma Yangden from BPSO.
4	16.04.2022	19:22	16.04.2022	19:30	0	-8.42	220KV Malbase	Dhamdum	heavy rain with thunder storm and wind	REL 670 trip	NA	Line tripped due to (General trip) Over voltage OPTD Fdr charged against charging code no 1019 from Karma Yangden from BPSO.
5	16.04.2022	19:22	16.04.2022	19:38	0	6.65	66KV Gomtu feeder	Dhamdum	heavy rain with thunder storm and wind	REL 670 trip	NA	Line tripped due to 86 tc faulty and CB trouble Fdr charged against charging code no 1021 from Karma Yangden from BPSO.
6	19.04.2022	17:13	19.04.2022	17:25	0	-3.65	Singeygoan Feeder	Dhamdum	heavy rain with thunder storm and wind	REL 670 trip	NA	Line tripped due to O/C on R&Y0, Zone: 1(General trip) and over voltage OPTD.Fdr charged against charging code no : Nil from BPSO T/Phu.
7	19.04.2022	17:18	19.04.2022	18:07	0	-9.82	220KV Malbase feeder	Dhamdum	heavy rain with thunder storm and wind	REL 670 trip	NA	Line tripped due to General trip, zone1 trip, RYB Phase trip and Over voltage OPTD. Fdr charged against charging code no: 1031 from BPSO.
8	04.03.2022	03:37	04.03.2022	04:10	0	2.46	66KV Gomtu feeder	Gomtu substation	Trip	General trip,zone1 trip,R and Y phase fault	NA	Heavy lightning and thunder ,The feeder was triped at 3:37hrs, test charge at 3:47hrs with the charging code from BPSO 1391 but the feeder could not stand so as informed to BPSO and suggested us to charge after weather improves since there is no power interruption in Gomtu substation as power supply is from Phuntsholing substation. As weather improved, so 66kv Gomtu feeder was charged at 4:10hrs with charging code 1392 from BPSO
9	14.04.2022	18:32	14.04.2022	18:59	0	7.13	66KV Gomtu feeder	Gomtu substation	Trip	N/A	N/A	Line tripped due to O/C on R&Y0(General trip)
10	14.04.2022	22:55	14.04.2022	23:10	0	3.65	66KV Gomtu feeder	Gomtu substation	Trip	General trip,zone1 trip,R and Y phase fault	NA	Heavy lightning and thunder ,The feeder was triped at 22:55hrs, test charge at 23:10hrs



Transmission System Performance Report 2022

Sl. No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/Lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
(A) 66kV Chundu switching station													
1	19.04.2022	14:33hrs	19.04.2022	15:03hrs		5.0MW	66kV Paro Feeder	Paro SS	transient fault	3ph. CB open	Chando	Trip	
(B) 66/33kV Watsa Substation													
1	26/4/2022	14:54hrs	26/4/2022	15:08hrs		4365/W	66KV SF6 breaker	Fdr: I and II	OC, OCH/EF and EFH on ABC phase	OC, OCH/EF and EFH on ABC phase	Fdr: I Wazakha		33KV line snapped at betkha as per ESD betkha
3	29/4/2022	16:14hrs	29/4/2022	16:16hrs		2.49	66KV SF6 breaker	Fdr: I and II	Over current	Over Current relay operated		Tripped	As the CT ratio is set to full load and when the load reach max. got tripped. After finding the relay setting is not changed after changing CT ratio. Line charged after increasing Over current relay set.
(C) 66/33kV Olakha Substation													
5	06.04.2022	12:25	06.04.2022	12:27		-20.95	66kV Olakha-Senatoka Line	Olakha SS	While testing	NA	Olakha SS	Testing	66kV Olakha-Senatoka line got tripped while testing of 20MVA-transformer-1 SF6 Breaker when CT primary injection was carried out.
8	12.04.2022	12:06	12.04.2022	12:13		No record at SCADA	66KV Bus coupler	Olakha Substation	While doing SF relays connection and wiring by TCCD	Trip CKT-1 SUP Relay 195, Trip CKT-2 SUP. Relay 295 & Trip relay SUP Relay 86-95	Substation	Transient	Reset all the operated relays & charged the line, hold normal
9	14-04-2022	12:30	14-04-2022	12:32		9.9	20MVA Transformer -1	Olakha Substation		DIR, O.C & E F PROTIN Relay-67 Operated. Indication: 1 & 5, General Trip, 5 Over Current & Earth Fault Operated along with relay 86	Lungtengpho SS	33kV line Lungtengpho feeder	As per verbal message received from Ugyen Lepcha (Lungtengpho Substation Incharge) said that 33kV Incomer tripped at their end & simultaneously tripped 20 MVA transformer -1 at our end, reset all the operated relays & indications & charged. hold normal
10	14-04-2022	12:42	14-04-2022	12:44		9.9	20MVA Transformer -1	Olakha Substation		DIR, O.C & E F PROTIN Relay-67 Operated. Indication: 1 & 5, General Trip, 5 Over Current & Earth Fault Operated along with relay 86	Lungtengpho SS	33kV line Lungtengpho feeder	As per verbal message received from Ugyen Lepcha (Lungtengpho Substation Incharge) said that 33kV Incomer tripped at their end & simultaneously tripped 20 MVA transformer -1 at our end, reset all the operated relays & indications & charged. hold normal
(D) 66/33/11kV Lobeysa Substation													
66kV LSA - Gewathang feeder													
1	15.04.2022	20:09hrs	15.04.2022	20:18hrs	0	-19.440	66kV LSA - Gewathang feeder	NA		Dist relay operated (A-107, 2A, B-145 2A&IC-138 9A)			66kV LSA - Gewathang feeder tripped at 20:09hrs and charged the line as per BPSO at 20:18hrs. Supply no interruption was feeded from Dochula end.
2	19.04.2022	00:37hrs	19.04.2022	00:42hrs	0	-14.920	66kV LSA - Gewathang feeder	66/33/11kV Lobeysa substation		Dist relay operated			66kV LSA - Gewathang feeder tripped at 00:37hrs and charged the line as per BPSO at 00:42hrs
3	22.04.2022	21:14hrs	22.04.2022	21:28hrs	0	-17.220	66kV LSA - Gewathang feeder	66/33/11kV Lobeysa substation		Dist relay operated			66kV LSA - Gewathang feeder tripped at 21:14hrs and charged the line as per BPSO at 21:29hrs
4	27.04.2022	23:02hrs	28.04.2022	00:07hrs	1	-14.180	66kV LSA - Gewathang feeder	NA		Dist relay operated (A-11.61A, B-104 8A&IC-85.43A)			66kV LSA - Gewathang feeder tripped at 23:02hrs and informed to BPSO. At 23:09hrs BPSO side to detect the breaker but contact hold and again charged at 23:27hrs contact hold. After opening breaker at Gewathang end and closed the breaker at Lobeysa end with closing code 1094, line stand at 00:07hrs and breaker closed at Gewathang end at 00:11hrs
66kV LSA - Dochula feeder													
1	19.04.2022	00:37hrs	19.04.2022	00:51hrs	0	12.340	66kV LSA - Dochula feeder	NA		Dist relay operated			66kV LSA - Dochula feeder tripped at 00:37hrs and charged the line as per BPSO at 00:51hrs with closing code 1029
2	22.04.2022	21:14hrs	22.04.2022	21:29hrs	0	12.020	66kV LSA - Dochula feeder	66/33/11kV Lobeysa substation		Dist relay operated			66kV LSA - Gewathang feeder tripped at 21:14hrs and charged the line as per BPSO at 21:29hrs
(E) 66/33/11 kV Paro Substation													
1	19.4.2022	14:46	19.4.2022	15:01	0		66kV Chando Line IN	Paro substation and its out goings	IDMT E/F & OC from chando end				



Transmission System Performance Report 2022

(F) 66/33/11kV Jemina Substation													
Nil													
(G) 66/33/11kV Dechencholing substation													
1	22.04.2022	21:34hrs	22.04.2022	21:16hrs	0	-23.61	66KV Szentokha IC	whole s/s fdr.	Incinerer tripped on broken conductor	Distance relay and 86relay.	Not known	tripped	Test charged the line found healthy.
2	27.04.2022	23:04hrs	27.04.2022	23:07hrs	0	-25.31	66KV Szentokha IC	whole s/s fdr.	Incinerer tripped on broken conductor	Distance relay and 86relay.	Not known	tripped	Test charged the line found healthy.
(H) 66/11kV Haas Substation													
Nil													
(I) 220kV Substation Szentokha													
1	22.04.2022	21:15hrs	22.04.2022	21:19hrs			66KV Szentokha-Dochula Line	Dochula substation		Distance relay optd, Zone-1 trip (Ia=599A, Ib=4980A, Ic=4643A)	Distance=0.00km	Transient	
2	29.04.2022	10:08hrs	29.04.2022	11:33hrs	1.00	-60.190	No Interruption	Shutdown avoided by BHP for testing energy meter at BHP end				Transient	
(J) 66/33/11kV Pangbesa substation													
Nil													
(K) 66/33kV Changdaphu Substation													
Nil													
(L) 66/33kV Damji Substation													
1	15.04.2022	13:46 hrs	16.04.2022	13:54 hrs	0	-4.14	66 kV Incoming Line	Whole Substation	Tripp	NA			Line tripped from Szentokha Substation
2	22.04.2022	21:15 hrs	22.04.2022	21:18 hrs	0	-4.33	66 kV Incoming Line	Whole Substation	Tripp	NA			Line tripped from Szentokha Substation
3	27.04.2022	23:04 hrs	27.04.2022	23:09 hrs	0	-1.22	66 kV Incoming Line	Whole Substation	Tripp	NA			Line tripped from Dechencholing Substation
(M) 66/11kV Dochula Substation													
1	22.04.2022	21:16	22.04.2022	21:21	0	-31.74	Szentokha	All 15c5MVA and 1x2.5MVA Transformer	Under Voltage	86 Relay	Dochula, Lobesa and sentokha all end breaker open	Temporary fault	
2	27.04.2022	15:08	27.04.2022	15:14	0	-31.75	Szentokha		Under Voltage	86 Relay	Dochula end breaker open	Temporary fault	
3	22.04.2022	21:16	22.04.2022	21:30	0	-30.18	Lobesa		Under Voltage	86 Relay	Dochula, Lobesa and sentokha all end breaker open	Temporary fault	
4	27.04.2022	15:08	27.04.2022	15:26	0	-30.07	Lobesa		Under Voltage	86 Relay	Dochula end & Lobesa end breaker open	Temporary fault	All DFH Farm House

May 2022

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/Lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
(A) 400/220/66/11 kV Malbase Substation													
66kV & Above													
1	17/5/2022	12:03	17/5/2022	12:10	0	24	66kV Pasakha feeder I	Mlabase Ss	O/C & E/F	General trip O/C & E/F			IL1=2319.32 /52.57deg,IL2=228A/88.26deg,IL3=198.06A/94.03deg,IL4=2332.57A/ 126.94deg
2	17/5/2022	12:03	17/5/2022	12:10	0	24	66kV Pasakha feeder II	Mlabase Ss	O/C & E/F	General trip O/C & E/F			IL1=0.11A/107.34deg,IL2=1144.25A/86.83deg,IL3=680.86A/106.94deg,IL4=0.11A/107.34deg
3	21-05-2022	02:14	21-05-2022	02:45	0	106.18	400kV Malbase- Siliguri fdr.	Mlabase Ss	transient fault	General trip,186(RYB) optd			IL1=290.7A/51.77deg,IL2=119.4A/331.7deg,IL3=1364A/65.23deg,IL4=1646A/58.34 deg.
(B) 66/33kV Watsa Substation													
1	05-08-2022	11:59hrs	05-08-2022	12:26hrs		5.230MW	66KV SF6 breaker	Fdr. I and II	WTI tripped	WTI tripped	8MVA transformer	Tripped	WTI tripped and reset the temperature to 75 with consultation with Mtc. Head SMD, and the line charged.
(C) 66/33kV Olakha Substation													
Nil													
(D) 66/33/11kV Lobesa Substation													
66kV LSA - Gewathang feeder													
1	10.05.2022	15:11hrs	10.05.2022	15:18hrs	0	-14.040	66kV LSA - Gewathang feeder	66/33/11kV Lobesa substation		OC & EF relay operated			66kV LSA - Gewathang feeder tripped at 15:11hrs and supply resumed at 15:18hrs.
2	11.05.2022	20:33hrs	11.05.2022	20:38hrs	0	-18.280	66kV LSA - Gewathang feeder	66/33/11kV Lobesa substation		OC & EF relay operated			66kV LSA - Gewathang feeder tripped at 20:33hrs informed to BPSO and line charged at 20:38hrs from Gewathang ss and line extended to Dochula at 20:41hrs.
3	15.05.2022	14:20hrs	15.05.2022	14:55hrs	0	-17.240	66kV LSA - Gewathang feeder	66/33/11kV Lobesa substation		OC & EF relay operated			66kV LSA - Gewathang feeder tripped at 14:20hrs and charged the line as per BPSO at 14:55hrs.



Transmission System Performance Report 2022

66kV LSA - Dochula feeder													
1	10.05.2022	15:11hrs	10.05.2022	15:18hrs	0	10.470	66kV LSA - Dochula feeder	NA		OC & EF relay operated	66kV LSA - Dochula feeder tripped at 15:11hrs and supply resumed at 15:18hrs.		
2	11.05.2022	20:33hrs	11.05.2022	20:38hrs	0	-18.280	66kV LSA - Dochula feeder	NA		OC & EF relay operated	66kV LSA - Dochula feeder tripped at 20:33hrs informed to BPSO and line charged at 20:38hrs from Gewathang ss and line extended to Dochula at 20:41hrs.		
3	29.05.2022	22:08hrs	29.05.2022	22:36hrs	0	12.200	66kV LSA - Dochula feeder	NA		Dist. relay operated (IA-6.543.IB-979.5A & 976.4A)	66kV LSA - Dochula feeder tripped at 22:08hrs informed to BPSO and line charged at 22:10hrs from Gewathang ss and line extended to Dochula at 22:36hrs.		
66/33kV.5MVA Transformer-4(All 33kV OG feeders connected together)													
1	10.05.2022	15:21hrs	10.05.2022	16:08hrs	0	1.380	33kV O/G-1	33kV O/G-1	Line fault	IDMT- E/F (IA-168.1A IB-272.8A IC-130.8A IN-217.9A)	NA	Line fault	66/33kV Transformer -4 feeder trip on IDMT E/F at 15:11hrs and test charged at 15:12hrs could not stand and informed to ESD Punakha regarding the line fault and line charged at 16:08hrs and line stand thereafter after opening GO at Punakha area
2	14.05.2022	05:02hrs	14.05.2022	05:37hrs	0	0.800	33kV O/G-2	33kV O/G-2	Line fault	IDMT- E/F & O/C	NA	Line fault	66/33kV Transformer -4 feeder trip on IDMT E/F & OC at 05:36hrs and test charged at 05:37hrs could not stand and informed to ESD Wangdue regarding the line fault and line charged at 05:37hrs and line stand thereafter
3	14.05.2022	11:53hrs	14.05.2022	12:09hrs	0	1.170	33kV O/G-2	33kV O/G-2	Line fault	IDMT- E/F & O/C	NA	Line fault	66/33kV Transformer -4 feeder trip on IDMT E/F & OC at 11:53hrs and test charged at 11:54hrs could not stand and informed to ESD Wangdue regarding the line fault and line charged at 12:09hrs and line stand thereafter
(L) 66/33kV Damji Substation													
1	11.05.2022	20:33 hrs	11.05.2022	20:38 hrs	0	-4.17	66 kV Incoming Line	Whole Substation	Trip	NA			Grid Failure
2	15.05.2022	14:20 hrs	15.05.2022	14:25 hrs	0	-4.17	66 kV Incoming Line	Whole Substation	Trip	NA			Line tripped from Semtokha Substation
3	19.05.2022	10:35 hrs	19.05.2022	10:40 hrs	0	-4.13	66 kV Incoming Line	Whole Substation	Trip	NA			Line tripped from Dechencholing Substation/Grid Failure
(M) 66/11kV Dochula Substation													
1	10-05-2022	15:11	05-10-2022	15:21	0	-32.3	Semtokha	All Farm House	Under voltage	86			Under voltage and 86 relay operated at Dochula end. Supply fail from Semtokha.
2	11-05-2022	20:33	05-11-2022	20:58	0	-32.33	Semtokha	All Farm House	Under voltage	86			Under voltage and 86 relay operated at Dochula end. Supply fail from Semtokha.
3	15/5/2022	14:19	15/5/2022	14:32	0	-30.36	Semtokha	All Farm House	Under voltage	86			Under voltage and 86 relay operated at Dochula end. Supply fail from Semtokha
4	29/5/2022	22:09	29/5/2022	22:23	0	-32.1	Semtokha	All Farm House	Under voltage	86			Under voltage and 86 relay operated at Dochula end. Supply fail from Semtokha
5	10-05-2022	15:11	05-10-2022	15:31		-30.41	Lobesa	All Farm House	Under voltage	86			Under voltage and 86 relay operated at Dochula end. Supply fail from Semtokha
6	11-05-2022	20:33	05-11-2022	20:45	0	-30.42	Lobesa	All Farm House	Under voltage	86			Under voltage and 86 relay operated at Dochula end. Supply fail from Semtokha and lobesya.
7	15/5/2022	14:19	15/5/2022	14:37	0	-28.25	Lobesa	All Farm House	Under voltage	86			Under voltage and 86 relay operated at Dochula end. Supply fail from Semtokha and lobesya.
8	29/5/2023	22:09	29/5/2023	22:39	0	-30.17	Lobesa	All Farm House	Under voltage	86			Under voltage and 86 relay operated at Dochula end. Supply fail from Semtokha and lobesya.



Transmission System Performance Report 2022

July 2022

Sl No.	Date of Tripping	Time of outages	Date of Normalizati on	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
66kV & Above													
(A) 400/220/66/11 kV Malbase Substation													
1	01.07.22	07:46	01.07.22	08:06	0	551.27	400kV Malbase- Siliguri fdr.	Malbase Ss	O/C & E/F	Main I trip, Main II CAR-RCV, 2M3 trip, fuse fail	193km		IL1=1672A<303.7deg,IL2=748.2A<255.3deg,IL3=718.4A<133.1deg,IL4=1599A<278.9deg
2	03.07.22	17:20	03.07.22	17:27	0	151.9	200kV Malbase - Chukha feeder	Malbase Ss	O/C & E/F	Zone 1 trip, AR lock out shut	Zone 1= 8.001km		IA=3.679kA, I2=3.967kA, I3=3.732kA
##	18.07.22	03:06	18.07.22	04:35	1	5.6	200kV Malbase - Samtse feeder	Dhamdum Ss	O/C on B phase	86 optd			IL1=75.95A<220.7deg,IL2=116.5A<235.2deg,IL3=2538A<41.95deg,IL4=2347A<41.59deg.
##	20.07.22	08:20	20.07.22	09:09	0	226	400kV Malbase- Siliguri fdr.	Malbase Ss & Siliguri Ss	O/C on Y & B phase	Zone 1 trip	38.55km		IL1=750A, I2= 3939A, I3=3623A
##	23.07.22	17:11	23.07.22	17:23	0		66kV Bus Coupler	Malbase Ss	O/C				R=13737.24A, Y=11481.82A, B=14715.29A
##	23.07.22	17:11	23.07.22	17:25	0	22	66kV Pasakha feeder I	Malbase Ss	O/C				R=129.11A<-103.18deg, Y=1796.66A<139.38deg, B=1230.16A<17.55A
##	23.07.22	17:11	23.07.22	18:24	1	0	66kV pling feeder	Malbase Ss	O/C				R=11.26kA, Y=11.72kA, B=1.32kA
##	28.07.22	11:38	28.07.22	13:55	2	20	66kV Pasakha feeder I	Malbase Ss		IEF 50N_trip, 86 optd, general trip			IL1=210.56A<-82.05deg, IL2=925.15A<19.83deg, IL3=279.19A<90.05deg, IL4=976.52A<-156.85 deg
##	28.07.22	11:38	28.07.22	23:47	12	21	66kV Pasakha feeder II	Malbase Ss		51 Trip, 86 optd, General trip			IL1=0.19A< 0.05deg, IL2=656.02A<-156.39deg, IL3=662.70A<23.20deg, IL4=0.19A< 0.9 deg
##	28.07.22	11:38	28.07.22	23:47	12	23	66kV Pasakha feeder IV	Malbase Ss		IEF 50N_trip, 86 optd, general trip			IL1=809.15< 14.74deg, IL2=1657.84A<17.40deg, IL3=208.51A<53.29deg, IL4=809.15A< 14.74 deg
##	28.07.22	11:38	28.07.22	23:47	12		66kV Bus Coupler	Malbase Ss		IEF 50N_trip, 86 optd, general trip, IEF_50_trip			IL1=648.57A<-115.40deg,IL2=12463.04A< -131.23deg,IL3=236.83A<98.24deg,IL4=12947.29A< -131.26deg
##	28.07.22	11:38					66kV pling feeder	Malbase Ss	O/C	Trip phase N, Earth Fault 1, Trip IN1>3			IL1= 8.397A, IL2= 9.697kA, IL3= 3.560kA, IL4= 9.690kA, The feeder still under breakdown due to 400kV Tala feeder I conductor got snapped and touched on transmission line of said feeder.
(B)220/66/11 kV Singhigoan Substation													
1	17.07.22	03:32	17.07.22	03:45	0	0.897	220kV Singhi-Samtse Feeder	Singyegoan ss					couldnt download fault due to Digsi software communication problem.
##	28.07.22	23:39	28.07.22	23:44	0	4	66kV B/Concast feeder	Singyegoan ss					IL1=113.84kA, IL2= 58.93kA, IL3= 95.53kA
(B)66/33/11 kV Phuntsholing Substation													
1	03.07.2022	17:19	03.07.2022	17:26	0	-3.70	66kV Chukha-Pling feeder	66kV Chukha-Pling fdr		DSTN OPTD, 186&86		Tripped at both end	At 17:19hrs 66kV Chukha-Pling feeder got tripped from both end. At 17:26hrs normalised the above feeder after getting clearance from BPSO with charging code 1652.
##	12.07.2022	06:30	12.07.2022	06:34	0	1.15	10MVA Voltamps TRF (66/33kV)	10MVA Voltamps TRF (66/33kV)	Tripped			Substation	10 MVA Transformer and 33kV Incomer II got tripped due to fault on 33kV fdr IV,Serina Bosokha.
##	14.07.2022	17:09	14.07.2022	17:24	0	-3.27	66kV Chukha-Pling feeder and 66kV Pling-Gomtu feeder	Black out at Pling ss	Tripped at their end	Nil		Tripped at their end	66kV Chukha-Pling and 66kV Pling-Gomtu feeder got tripped at their end, no breaker operation at our end. At 17:24hrs normalised 66kV Chukha-Pling feeder from Chukha and at 17:27hrs normalised 66kV Gomtu feeder from Gomtu end.
##	15.07.2022	15:42	15.07.2022	15:44	0	1.93	10MVA Voltamps TRF (66/33kV)	10MVA Voltamps TRF (66/33kV)	Tripped	Nil		Substation	10 MVA Transformer and 33kV Incomer II got tripped due to fault on 33kV fdr IV,Serina Bosokha.
(D) 66/33/11 kV Gedu Substation													
1	03.07.2022	17:20	03.07.2022	17:28	0	1.72	66kV Gedu- Chukha	Blackout	Bad weather			Line segment	66kV supply failed from CHP. At 17:27hrs 66kV supply charged from Phuntsholing Substation.
	06.07.2022	9:02	06.07.2022	9:45	0	1.33	66/11kV 5MVA Tr- 1	Nil	Tighten transformer NCT			Substation	Work permit no 78 issued to Substation Head for NCT tightening work.
2	16.07.2022	18:58	16.07.2022	19:10	0	1.69	66kV Gedu- Chukha	Blackout				Line segment	66kV supply failed from CHP. At 19:10hrs 66kV supply restored from Chukha.
3	31.07.2022	9:12	31.07.2022	9:27	0	1.5	66kV Gedu-Phuntsholing	Nil	Emergency shutdown at Phuntsholing end			Line segment	Emergency shutdown taken at Phuntsholing substation to rectify the hissing sound from line isolator.



Transmission System Performance Report 2022

(E) 66/33/11 kV Gomtu Substation																
1	11.07.2022	17:30	12.07.2022	10:50	17	0.01	66/33kV 5 MVA Transformer	Nil	over current	O/C with IDMT highest 50y and trip relay 86	Gomtu ss	Fault	Punctured bus insulator			
2	14.07.2022	17:09	14.07.2022	17:29	0	-4.824	66kV Dhamdhum feeder	Gomtu Substation	Transient fault	Distance Relay Operated	Line segment	Transient fault	Charged the feeder as per the instruction given by BPSO			
2	14.07.2022	17:09	14.07.2022	17:27	0	2.66	66kV Phuentsholing feeder	Gomtu Substation	Earth fault	IDMT EP operated	Line segment	Transient fault	Charged the feeder as per the instruction given by BPSO			
3	16.07.2022	19:01	16.07.2022	19:11	0	-5.362	66kV Dhamdhum feeder	Gomtu Substation	Tripped from Dhamdhum end	Nil	Line segment	Transient fault	Tripped from Dhamdhum end and supply resumed at 19:11hrs			
3	16.07.2022	19:01	16.07.2022	19:14	0	3.61	66kV Phuentsholing feeder	Phuentsholing substation	Earth fault	E/F 57NX	Line segment	Transient fault	Tripped on earthfault and charged the line as requested by BPSO and charge withstand			
4	19.07.2022	09:15	19.07.2022	10:35	1	2.82	66kV Phuentsholing feeder	Nil	Spark on R phase CB terminal	Nil	Gomtu substation	Emergency Shutdown	Availed emergency shutdown by SubStation Head against Work Permit No. 074, opening code 6868 and closing code 1751 from BPSO.			
4	28.07.2022	18:56	28.07.2022	18:56	0	-7.634	66kV Dhamdhum feeder	Nil	B-Phase fault	Distance Relay Operated & A/R Operated, General trip, Zone One, trip, Z-Com trip & B-Phase fault	Line segment	Transient fault	Auto recloser operated and charged from Dhamdhum end at 19:09hrs of date 28.07.2022 against closing code 1854 from BPSO			
(F) 220/66/33 kV Dhamdum Substation																
1	14.7.2022	17:10	14.7.2022	17:29	0	5.09	66kV Gomtu fdr	Gomtu	Heavy thundering, lightning, windy and raining at Gomtu area.	General trip, Zone 2 trip, Y phase faulty, vt fuse fail.	Heavy thundering, lightning, windy and raining at Gomtu area.	line fault	Feeder test after stopping the weather at gomtu area and consult with BOSO for test charging.			
2	28.07.2022	18:56	28.07.2022	19:09	0	7.41	66kV Gomtu fdr	Gomtu	thundering, lightning, windy and raining at Samtse	General trip, Zone 1 trip, Y phase faulty	NA	line fault	REP670: General trip Zone 1, O/C on Y0 Abs Dist: 2.39 Re I Dist: 15.92% Fault loop - L2N # Charged the feeder based upon the charging Code: 1854, BPSO T/phu, moreover after normalization of rain fall			
Sl. No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks			
(A) 66kV Chumdu switching station																
1	01.07.2022	1838hrs	01.07.2022	1843hrs		(-) 11.1MW	66kV Chukha Feeder	Paro substation	E/fault	Due to E/F IA 151.4A IB 881.8A IC 157.5A	66kV Transmission Line	Trip				
2							66kV Pangbasa Feeder	Pangbasa Substation	Transient fault					3Ph and General trip	66kV Transmission Line	Trip
3							66kV Jemina Feeder	Paro and Pangbasa	Transient fault					3Ph and General trip	66kV Transmission Line	Trip
4	26.07.2022	1658hrs	26.07.2022	1551hrs	4hrs	(-) 12.1MW	66kV Jemina Feeder	Fed from 66kV Chukha Feeder	S/down	CB open, Line & Bus isolator open, E switch closed	Jemina substation	S/down	S/down by CNPD for checking the operation of Line abd Bus isolators electrically as SCADA installation is in process at Jemina.			
(B) 66/33kV Watsa Substation																
1	07-01-2022	189.38hrs	07-01-2022	18.43hrs		620MW	66KV IC	Fdr. I and II	66KV IC tripped at chukha end	66KV IC tripped at chukha end	66KV IC tripped at chukha end	Tripped	WTI tripped and reset the temperature to 75 with consultation with Mtr. Head SMD, and the line charged.			
(C) 66/33kV Olakha Substation																
1	21-07-2022	17:15	21-07-2022	17:35	0	6.19	66/33kV 20MVA, Transformer I	Only 66/33kV 20MVA, Transformer I was effected	Over current and earth fault	Earth Fault Over Current Operated	Line Segment	Taken Shut down	The 66kV Olakha-Changidaphu was taken shut down by Manager Chumdu Gyentshen of TMD, with work permit no 2507 and also with the shutdown approval from BPSO Thangphu for removal of flag pole installed at the line near Dago Ex hynpo area with breaker opening code 0820. The line was charged after completion of the work with closing code 1617 at 17:38hrs and stood normal			



Transmission System Performance Report 2022

(D) 66/33/11kV Lobeysa Substation													
66kV LSA - Gewathang feeder													
1	07.07.2022	06:15hrs	07.07.2022	06:20hrs	0	-20.620	66kV LSA - Gewathang feeder	66/33/11kV Lobeysa substation		NA	66kV LSA - Gewathang feeder tripped at 06:15hrs and supply resumed at 06:20hrs and at the time of tripping No breaker or relay operated at Lobeysa end		
2	08.07.2022	19:49hrs	08.07.2022	19:50hrs	0	-17.970	66kV LSA - Gewathang feeder	66/33/11kV Lobeysa substation		NA	66kV LSA - Gewathang feeder tripped at 19:49hrs informed to BPSO and line charged at 19:50hrs from Gewathang ss and line extended to Dochula at 19:53hrs		
3	09.07.2022	02:18hrs	09.07.2022	02:18hrs	0	-18.720	66kV LSA - Gewathang feeder	66/33/11kV Lobeysa substation		Dist relay operated (Zone 3 optd)	66kV LSA - Gewathang feeder tripped at 02:18hrs informed to BPSO and line charged at 02:19hrs from Gewathang ss and line extended to Dochula at 02:33hrs		
4	09.07.2022	12:23hrs	09.07.2022	12:24hrs	0	-20.240	66kV LSA - Gewathang feeder	66/33/11kV Lobeysa substation		Dist relay operated (Zone 3 optd)	66kV LSA - Gewathang feeder tripped at 12:23hrs informed to BPSO and line charged at 12:24hrs from Gewathang ss and line extended to Dochula at 12:30hrs		
5	20.07.2022	19:53hrs	20.07.2022	19:56hrs	0	-23.050	66kV LSA - Gewathang feeder	66/33/11kV Lobeysa substation		Dist relay operated (Trip B & C Zone 3 optd, IA-119.8A, IB-815.3, IC-686.1A)	66kV LSA - Gewathang feeder tripped at 19:53hrs informed to BPSO and line charged at 19:56hrs from Gewathang ss and line extended to Dochula at 20:01hrs		
					0								
66kV LSA - Dochula feeder													
1	07.07.2022	06:15hrs	07.07.2022	06:20hrs	0	15.470	66kV LSA - Dochula feeder			NA	66kV LSA - Dochula feeder tripped at 06:15hrs and supply resumed at 06:20hrs and at the time of tripping No breaker or relay operated at Lobeysa end		
2	08.07.2022	19:49hrs	08.07.2022	19:53hrs	0	15.840	66kV LSA - Dochula feeder			NA	66kV LSA - Dochula feeder tripped at 19:49hrs informed to BPSO and line charged at 19:50hrs from Gewathang ss and line extended to Dochula at 19:53hrs		
3	09.07.2022	02:18hrs	09.07.2022	02:18hrs	0	16.120	66kV LSA - Dochula feeder			NA	66kV LSA - Dochula feeder tripped at 02:18hrs informed to BPSO and line charged at 02:19hrs from Gewathang ss and line extended to Dochula at 02:33hrs		
4	09.07.2022	12:23hrs	09.07.2022	12:24hrs	0	-20.240	66kV LSA - Dochula feeder			NA	66kV LSA - Dochula feeder tripped at 12:23hrs informed to BPSO and line charged at 12:24hrs from Gewathang ss and line extended to Dochula at 12:30hrs		
5	20.07.2022	06:42hrs	20.07.2022	06:51hrs	0	14.850	66kV LSA - Dochula feeder			Dist Trip B & Dist Trip C, Zone 3 optd	Supply was resumed from Gewathang ss at 06:47hrs. 66kV LSA - Dochula feeder tripped at 06:42hrs informed to BPSO and line extended at 06:51hrs		
6	20.07.2022	12:42hrs	20.07.2022	12:51hrs	0	14.850	66kV LSA - Dochula feeder			Dist Trip B & Dist Trip C, Zone 3 optd	Supply was resumed from Gewathang ss at 06:47hrs. 66kV LSA - Dochula feeder tripped at 06:42hrs informed to BPSO and line extended at 06:51hrs		
7	21.07.2022	17:16hrs	21.07.2022	17:20hrs	0	17.200	66kV LSA - Dochula feeder			Dist Trip B & Dist Trip C, Zone 3 optd	66kV LSA - Dochula feeder tripped at 17:16hrs informed to BPSO and supply was extended from Gewathang at 17:17hrs and line extended at 17:20hrs towards Dchula		
(E) 66/33/11 kV Paro Substation													
Nil													
(F) 66/33/11kV Jemina Substation													
66 kV side Tripping													
1	01.07.2022	18:39	01.07.2022	18:45	0	-3.870	66 kV Changedaphu	Black out	Earth fault	Non directional E/F operated	Line Segment	Transient	
2	01.07.2022	18:39	01.07.2022	19:26	0	1.950	66 kV Chumdo	Black out	Earth fault	Non directional E/F operated	Line Segment	Transient	Weather lightning at Chumdo end as per the BPSO personnel
(G) 66/33/11kV Dechenchoing substation													
1	01.07.2022	18:20Hrs	01.07.2022	18:37hrs	0	-21.48	66KV IC	All whole ss	Supply failed from source				
2	20.07.2022	00:42Hrs	20.07.2022	00:48hrs	0	-21.29	65KV IC	All whole ss	Supply failed from source				
(H) 66/11kV Haa Substation													
1	01-07-2022	18:36	01.07.2022	18:48	0	-1.68	All	unknown	O/C	pangbesa	Tripped from Pangbesa end		
2	14-07-2022	00:44	14-07-2022	00:59	0	-0.66	All	unknown	O/C	pangbesa	Tripped from Pangbesa end		
3	14-07-2022	03:37	14-07-2022	04:23	0	-0.56	All	unknown	O/C	pangbesa	Tripped from Pangbesa end		
4	15-07-2022	01:57	15-07-2022	03:10	1hr	-0.63	All	unknown	O/C	pangbesa	Tripped from Pangbesa end		
5	18-07-2022	03:55	18-07-2022	04:12	0	-0.51	All	unknown	O/C	pangbesa	Tripped from Pangbesa end		



Transmission System Performance Report 2022

(I) 220kV Substation Semtokha													
1	01-07-2022	18:21hrs	01-07-2022	18:26hrs			66/33kV 20MVA-1 transformer	Semtokha Substation	REF Trip	REF Trip	Transient fault	Transient	
2	01-07-2022	18:21hrs	01-07-2022	18:37hrs	21.81		66kv Semtokha- Dechencholing Line	Dechencholing and Danji Substation	Distance protection Optd., Zone 1, Trip B	Distance protection Optd., Zone 1, Trip B	Transient fault	Transient	
3	07-07-2022	06:15hrs	07-07-2022	06:21hrs	49.05		66kv Semtokha-Dochula Line	Dochula s/s	Directional earth fault protection operated	OC/EF Optd. IN<<2 trip	Transient fault		
4	07-07-2022	06:15hrs	07-07-2022	06:21hrs	49.05		66kv Semtokha- Dechencholing Line	Dechencholing and Danji Substation	Broken Conductor	Distance protection Optd., BRC Trip	Transient fault		
5	08-07-2022	19:49hrs	08-07-2022	19:52hrs	45.95		66kv Semtokha-Dochula Line	Dochula s/s	Y & Bph OC Trip	Backup OC/EF relay optd., Y&Bph I>2 Trip	Transient fault		
6	09-07-2022	02:19hrs	09-07-2022	02:26hrs	47.18		66kv Semtokha-Dochula Line	Dochula s/s	Y & Bph OC Trip	Backup OC/EF relay optd., Y&Bph I>2 Trip	Transient fault		
7	09-07-2022	12:23hrs	09-07-2022	12:25hrs	45.81		66kv Semtokha-Dochula Line	Dochula s/s	Y & Bph OC Trip	Backup OC/EF relay optd., Y&Bph I>2 Trip	Transient fault		
8	20-07-2022	00:44hrs	20-07-2022	00:50hrs			66kv Semtokha-Dochula Line	Dochula s/s	Y & Bph OC Trip	Backup OC/EF relay optd., Y&Bph I>2 Trip, fault Current Ia=225.9A, Ib=5.745kA, Ic=5.574kA, In=17.49	Transient fault		
9	20-07-2022	00:44hrs	20-07-2022	00:53hrs			66kv Semtokha- Dechencholing Line	Dechencholing and Danji Substation	Broken Conductor	Tripped on Broken Conductor, Fault Current I=131.3A, Ib=69.83A, Ic=84.01A			
10	20-07-2022	19:53hrs	20-07-2022	19:58hrs			66kv Semtokha-Dochula Line	Dochula s/s	Y & Bph OC Trip	Backup OC/EF relay optd., Y&Bph I>2 Trip, fault Current Ia=6.926A, Ib=5.734kA, Ic=5.544kA, In=0.00	Transient fault		
11	21-07-2022	17:16hrs	21-07-2022	17:31hrs			66kv Semtokha-Dochula Line	Dochula s/s	Y & Bph OC Trip	Backup OC/EF relay optd., Y&Bph I>2 Trip, fault Current Ia=151.7A, Ib=5.761kA, Ic=5.683kA, In=0.00	Transient fault		
(J) 66/33/11kV Pangbesa substation													
1	01.07.2022	18:36Hrs	01.07.2022	18:48Hrs	0		Haa Line	Haa	Shutdown	Tripped on E/F & O/C	Pan-Haa	Transient	Replacement of HT Fuse
2	14.07.2022	00:44Hrs	14.07.2022	1:00Hrs	0	0.7	Haa Line	Haa	Tripping	Dr O/C	Pan-Haa	Transient	Cloudy
3	14.07.2022	3:58Hrs	14.07.2022	4:13Hrs	0	0.7	Haa Line	Haa	Tripping	Dr O/C	Pan-Haa	Transient	Cloudy
4	14.07.2022	4:16Hrs	14.07.2022	4:22Hrs	0		Haa Line	Haa	Tripping	Dr O/C	Pan-Haa	Transient	Cloudy
5	15.07.2022	1:56Hrs	15.07.2022	2:10Hrs	0		Haa Line	Haa	Tripping	Dr O/C	Pan-Haa	Transient	Cloudy, Charged did not again
6	15.07.2022	2:10Hrs	15.07.2022	2:17Hrs	0		Haa Line	Haa	Tripping	Dr O/C	Pan-Haa	Transient	Cloudy, Charged again did not stand
7	15.07.2022	2:19Hrs	15.07.2022	2:39Hrs	0		Haa Line	Haa	Tripping	Dr O/C	Pan-Haa	Transient	Cloudy, Charged again did not stand
8	15.07.2022	2:39Hrs	15.07.2022	2:49Hrs	0		Haa Line	Haa	Tripping	Dr O/C	Pan-Haa	Transient	Cloudy, Charged again did not stand
9	15.07.2022	2:56Hrs	15.07.2022	3:08Hrs	0		Haa Line	Haa	Tripping	Dr O/C	Pan-Haa	Transient	Cloudy, Charged Fault from Haa 11kV fd.
10	18.07.2022	3:58Hrs	18.07.2022	4:07Hrs	0		Haa Line	Haa	Tripping	Dr O/C	Pan-Haa	Transient	Cloudy



Transmission System Performance Report 2022

(L) 66/33kV Damji Substation													
1	01.07.2022	1821 hrs	01.07.2022	1851 hrs	0	-4	66 kV Incoming Line	Whole Substation	Trip	NA	Transmission Line tripped from Semtokha Substation (B Phase Tripped)		
2	07.07.2022	0615 hrs	07.07.2022	0621 hrs	0	-4.13	66 kV Incoming Line	Whole Substation	Trip	NA	Transmission Line tripped from Semtokha Substation		
3	08.07.2022	1113 hrs	08.07.2022	1114 hrs	0	-4.02	66 kV Incoming Line	Whole Substation	Trip	NA	Transmission Line tripped from Dechencholing Substation due to installation of starter		
4	20.07.2022	0044 hrs	20.07.2022	0048 hrs	0	-4.05	66 kV Incoming Line	Whole Substation	Trip	NA	Transmission Line tripped from Semtokha Substation		
(M) 66/11kV Dochula Substation													
1	07-07-2022	06:15	07-07-2022	06:23		-31.83	66kV Semtokha	Semtokha - Dochula	Transit fault	under voltage and 86 relay	Semtokha	Temporary	DHI
2	07-07-2022	06:15	07-07-2022	06:27		-30.24	66kV lobeysha	Lobeysha - Dochula	Transit fault	under voltage and 86 relay	Lobeysha	Temporary	DHI
3	09-07-2022	19:48	09-07-2022	19:57		-31.16	66kV Semtokha	Semtokha - Dochula	Transit fault	under voltage and 86 relay	Semtokha	Temporary	DHI
4	09-07-2022	19:48	09-07-2022	20:00		-29.55	66kV Lobeysha	Lobeysha - Dochula	Transit fault	under voltage and 86 relay	Lobeysha	Temporary	DHI
5	09-07-2022	02:20	09-07-2022	02:35		-31.92	66kV Semtokha	Semtokha - Dochula	Transit fault	under voltage and 86 relay	Semtokha	Temporary	DHI
6	09-07-2022	02:20	09-07-2022	02:47		-30.34	66kV lobeysha	Lobeysha - Dochula	Transit fault	under voltage and 86 relay	Lobeysha	Temporary	DHI
7	09-07-2022	12:23	09-07-2022	12:27		-31.88	66kV Semtokha	Semtokha - Dochula	Transit fault	under voltage and 86 relay	Semtokha	Temporary	DHI
8	09-07-2022	12:23	09-07-2022	12:35		-30.17	66kV lobeysha	Lobeysha - Dochula	Transit fault	under voltage and 86 relay	Lobeysha	Temporary	DHI
9	20-07-2022	0:43	20-07-2022	0:53		-29.67	66kV lobeysha	Lobeysha - Dochula	Transit fault	under voltage and 86 relay	Lobeysha	Temporary	DHI
10	20-07-2022	0:43	20-07-2022	0:55		-31.42	66kV Semtokha	Semtokha - Dochula	Transit fault	under voltage and 86 relay	Semtokha	Temporary	DHI
11	20-07-2022	19:53	20-07-2022	20:06		-29.96	66kV lobeysha	Lobeysha - Dochula	Transit fault	under voltage and 86 relay	Lobeysha	Temporary	DHI
12	20-07-2022	19:53	20-07-2022	19:59		-31.61	66kV Semtokha	Semtokha - Dochula	Transit fault	under voltage and 86 relay	Semtokha	Temporary	DHI
13	21-07-2022	17:16	21-07-2022	17:22		-30.28	66kV lobeysha	Lobeysha - Dochula	Transit fault	under voltage and 86 relay	Lobeysha	Temporary	DHI
14	21-07-2022	17:16	21-07-2022	17:32		-31.84	66kV Semtokha	Semtokha - Dochula	Transit fault	under voltage and 86 relay	Semtokha	Temporary	DHI

August 2022

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
66kV & Above													
(A) 400/220/66/11 kV Malbase Substation													
1	01.08.2022	19:07	01.08.2022	21:05	1	139	200MVA ICT	Malbase Ss	PRD OPTD	PRD Y-Phase, 86 OPTD			IL1=276.3A,IL2=259.4A,IL3=231.3
2	08.08.2022	07:23	08.08.2022	07:29	0	25	66kV Pasakha I	Malbase Ss	O/C on R-phase	86 OPTD, General trip IEF-50N trip	line		IL1=1825.53A<-13.31, I2=219.37A<-130.54, I3=505.41A<151.16, IL4=1176.84a<164.80
3	08.08.2022	07:23	08.08.2022	07:30	0	26	66kV Pasakha II	Malbase Ss	O/C on Y-phase	86 OPTD, General trip IEF-50N trip	line		IL1=.20A<132.92, I2=742.124<-55.73, I3=228.20A<-106.15
4	08.08.2022	07:23	08.08.2022	07:30	0	5.6	66kV Pasakha IV	Malbase Ss	O/C on R-phase	86 OPTD, General trip IEF-50N trip	line		IL1=2315.03A<-50.57, I2=292.37A<-98.58,IL3=180.51A<38.88
5	18.08.2022	14:57	18.08.2022	15:17	0	22	50/63 MVA Transformer I	Malbase Ss		86 OPTD,LBB-Trip,general Trip			IL1=110.88A<114.2 IL2=75.28A<174.65,IL3=313.80A<-52.28
6	18.08.2022	14:57	18.08.2022	01:12	10	23	50/63 MVA Transformer III	Malbase Ss		OLTCC BUCH Trip,DIFF Trip,86 OPTD			IL1=140.56A,119.04,IL2=104.47A,166.39,IL3=189.88<120.21
7	18.08.2022	14:57	26.08.2022	16:59	194	59.2	220kV Malbase- Birpara fdr	Malbase Ss& Birpara SS		Zone 1 trip, AR OPTD	1.533KM		IL1=7.602KA, I2= 919.3A, I3=571.2A
8	18.08.2022	14:57	26.08.2022	17:12	194	70	220kV Malbase- Singhigoen fdr	Malbase Ss& Birpara SS		Dis Pickup I3 ON, Loop L3-Ef	.7Km		IL1=.00kA,IL2=0.01KA,IL3=7.76KA
9	18.08.2022	14:57	18.08.2022	15:17	0	22	66kV LV 606	Malbase Ss		51N START	S/S		R=171.26A<97.6, Y=182A<-130, B=310A<119, N=408.93A<127.99
10	19.08.2022	06:35	19.08.2022	06:50	0	64	200MVA ICT	Malbase Ss	Temporary fault	86 OPTD	S/S		IL1=.131A,IL2=.004A,IL3=.095A



Transmission System Performance Report 2022

11	19.08.2022	06:35	19.08.2022	07:51	1	11	220kVMalbase-Samtse fdr	Malbase Ss-Samtse	Temporary fault	87 OPTD	line		IL1=58.774A<69.27,IL2=36.41A<254.4,IL3=59.17A<187.2,IL4=50.52A<167.3
12	19.08.2022	06:35	19.08.2022	10:26	3	-79	220kVMalbase-Chukha fdr	Malbase Ss- ChukhaS/S	Strart R-phase,	87 OPTD	line		IL1=764.2A<249.9,IL2=223.4A<57.86<57.86,IL3=568A<38.75,IL4=50.52A<33.0.3
13	19.08.2022	06:35	19.08.2022	07:59	1	44	50/63 MVA Transformer I	Malbase Ss		86 OPTD,BBP OPTD	S/S		IL1=.01A<249.9,IL2=.06A<91.03,IL3=.03A<140.11,IL4=.00A<173.34
14	19.08.2022	06:35	19.08.2022	07:32	0	42	66kV Pasakha feeder I	Malbase Ss	O/C, E/F	IOC 50 Trip,IEF50N Trip,General Trip,86 OPTD	line		IL1=54.74A<48.83,IL2=316.74A<120.62,IL3=5859.39A<74.71,IN=5157.57A<166.02
15	19.08.2022	06:35	19.08.2022	06:45	0			Malbase Ss	O/C, E/F	IEF 50N trip, 86 optd, general trip, IEF_50_trip			IL1=6420.49A<54.29,IL2=639.18A<128.62,IL3=6485.32A<109.52,IN=7519.76A<113.68
16	20.08.2022	01:45	20.08.2022	05:03	3	184	220kVMalbase-Samtse fdr	Malbase Ss-Samtse	E/F	M1 Trip, R phase Trip,Zone 1 Trip, B/U Trip	30.3 KM		IL1=184.6A,IL2=3503A,IL3=102.2A,IN=3286A
17	21.08.2022	05:32	21.08.2022	05:42	0	17	220kVMalbase-Samtse fdr	Malbase Ss-Samtse	O/C on R phase and Y -phase	M1 Trip, Zone 1 Trip,			IL1=6883A,IL2=6477A,IL=1314A,IN=5197A
18	21.08.2022	05:32	21.08.2022	05:40	0	66	200MVA ICT	Malbase Ss	Temporary fault	87 OPTD			IL1=199.3A<38.98,IL2=185.6A<84.24,IL3=158.1A<155.3
19	21.08.2022	11:09				41	50/63 MVA Transformer I	Malbase Ss	LBB & PRD operated did not charged, kept under shutdown	LBB Trip, 86POTD	S/S		LI1=289.54A<2.17,LI2=280.11A<24.48,IL3=314.28A<110.06
20	21.08.2022	11:09	21.08.2022	14:17	3		66kV Bus Coupler	Malbase Ss	O/C on R,Y& B Phase	51 Trip, 86OPTD	S/S		IL1=1762.53A,IL2=1743.75A<119.75,IL3=1772.81<120.53,IL4=1753A<90.38
21	21.08.2022	11:09	21.08.2022	14:19	3	50	66kV pasakha IV	Malbase Ss	O/C	51 Trip, 86OPTD	line		IL1=786.4A,IL2=789.53A<120.42,IL3=790.83A<120.11
22	21.08.2022	11:09	21.08.2022	14:18	3	44	66kV pasakha II	Malbase Ss	O/C	51 Trip, 86OPTD	line		IL1=.32A<.00,IL2=577.20A<75.72,IL3=602.78A<102.18
23	21.08.2022	18:10	21.08.2022	18:16	0	24	200MVA ICT	Malbase Ss	Temporary fault	86 OPTD	c		IL1=.073A<192.4,IL2=.047A<72.17,IL3=.357A<134.3
24	21.08.2022	11:29	21.08.2022	15:21	3	-12.65	66kV malbase- Phuntsholing	Malbase Ss-Phuntsholing S/S	O/C	O/C Trip I>1,E/f 1	line		IA=530.4A,IB=505A,IC=503.2A,IN=4467A
25	21.08.2022	18:10	21.08.2022	18:32	0	-31	220kVMalbase-Chukha fdr	Malbase Ss- ChukhaS/S	Temporary fault	86 optd>	line		IL1=80.05A<145.1,IL2=65.89A<21.98,IL3=67.44A<276,IL4=5887A<70.5
26	21.08.2022	18:10	21.08.2022	18:30	0	15	66kV Pasakha IV	Malbase Ss	O/C	IEF-50N-ON-trip,General trip,86trip	line		IL1=2345.55A<32.88deg,IL2=372.63A<73.8deg,IL3=233.33A<147deg
27	21.08.2022	18:10	21.08.2022	18:19	0	23	50/63 MVA Transformer III	Malbase Ss	Temporary fault	BBP optd,Differential opted.	S/S		IL1=26A<11.32deg,IL2=218.14A<120deg,IL3=203.78A<118.97deg
28	21.08.2022	18:10	21.08.2022	18:33	0	13	220kVMalbase-Samtse fdr	Malbase Ss-Samtse	Temporary fault	B/B Trip	line		IL1=52.76A<71.65deg,IL2=32.99A<262.8deg,IL3=44.16A<139.2deg,IL4=51.50A<114.8deg
29	23.08.2022	14:32	23.08.2022	14:35	0	31	50/63 MVA Transformer III	Malbase Ss	Temporary fault	86 optd,Differential opted.	S/S		IL1=183.68A<6.41deg,IL2=72.46A<20.01deg,IL3=102.60A<81.95deg,IL4=282.29A<20.16deg
30	23.08.2022	14:32	23.08.2022	14:47	0	3	220kVMalbase-Samtse fdr	Malbase Ss-Samtse	O/C on y phase and with E/F	Main-1 protection trip<O/C relay trip<Loop- L2-N	line		IL1=92.18A<350.7deg,IL2=3733A<160.8deg,IL3=33.3A<14.36deg,IL4=3603A<161.5deg
31	23.08.2022	14:48	23.08.2022	16:18	1	3	220kVMalbase-Samtse fdr	Malbase Ss-Samtse	O/C on Y & B phase and with E/F	General trip<Main-1 trip	line		IL1=56.29A<323.8deg,IL2=4350A<171.9deg,IL3=4075A<34.8deg,IL4=3153A<102.6deg
32	26.08.2022	18:35	26.08.2022	18:47	0	33	50/63 MVA Transformer III	Malbase Ss	Temporary fault	86OPTD, 027 Trip, Diff Trip,	S/S		IL1=40.63A<59.53 deg, IL2=364.11A<52.67 deg, IL3=279.86A<170.42 deg, IL4= 300.45A<96.03 deg
33	26.08.2022	18:35	27.08.2022	14:47	20	26.08	220kV Malbase- Birpara fdr	Malbase Ss& Birpara SS	Birpara line LA got punctured.	Phase ABC, Distance zone 1 tripped, AR Lockout , Fault location= 589.3m.	line		IA= 772.5A, IB= 639.9A, IC= 7.441kA
34					0								
35					0								



Transmission System Performance Report 2022

B/220/66/11 kV Singhigoan Substation												
1	17.07.22	03:32	17.07.22	03:45	0	0.897	220kV Singhi-Samtse Feeder	Singyegoan ss				couldnt download fault due to Digi software communication problem.
2	18.07.22	12:00	18.07.22	13:56	1	0.02	11kV Feeder 1	Singyegoan ss				IL1= 8.05kA, IL2= 7.87kA, IL3= 1.73kA
3	18.07.22	17:50	18.07.22	20:35	2	3226	11kV feeder 8	Singyegoan ss				IL1= 8.03kA, IL2= 7.95kA, IL3= 0.05kA
4	19.07.22	10:40	19.07.22	10:42	0	0.13	11kV Feeder 1	Singyegoan ss		Transit Fault		IL1= 01kA, IL2= 0.01kA, IL3= 0.19kA
5	23.07.22	16:59	23.07.22	17:31	0	0.122	11kV Feeder 1	Singyegoan ss				IL1= 1.08kA, IL2= 0.01kA, IL3= 1.16kA
6	24.07.22	09:09	24.07.22	09:10	0	0.057	11kV feeder I	Singyegoan ss	o/c & E/F,IEF Trip, General trip			IL1=0.29kA, IL2= 0.01kA, IL3= 0.01kA
7	26.07.22	20:50	26.07.22	21:13	0	0.953	11kV feeder II	Singyegoan ss		Tripped on O/C Y&B Phase		IL1= 0.07kA, IL2= 3.54kA, IL3= 3.11kA
8	28.07.22	23:39	28.07.22	23:44	0	4	66kV B/Concat feeder	Singyegoan ss				IL1=113.84kA, IL2= 58.93kA, IL3= 95.53kA
B/66/33/11 kV Phuntsholing Substation												
1	13.08.2022	18:36	13.08.2022	18:40	0	-4.77	66kV Chukha-Pling feeder	Black out at Pling ss			Tripped at chukha end	At 18:36hrs 66kV Chukha-Pling feeder got tripped from chukha end and 66kV Pling-Gomtu feeder got tripped at our end causing black out at Pling. At 18:40hrs normalised the 66kV Chukha-Pling from Chukha end and at 18:45hrs normalised 66kV Pling-Gomtu feeder after getting clearance from BPSO.
2	13.08.2022	18:36	13.08.2022	18:45	0	-1.04	66kV Pling-Gomtu fdr	Black out at Pling ss	Overcurrent	Ia- 995.7A, Ib-1.036kA, Ic- 51.71kV, VAB- 4.56kV, VBC- 54.00kV, VCA- 57.51kV, INM-11.72A IND-12.38A	Tripped at our end	
3	14.08.2022		14.08.2022	14:24			66kV Pling-Malbase fdr	66kV Pling-Malbase fdr				At 18:24hrs charged 66kV Pling-Malbase feeder which was under idle charge condition with closing code 111 from BPSO. At 18:59hrs opened CB of above fdr with opening code 0943 from BPSO and said feeder kept under idle charged condition.
4	14.08.2022	14:26	14.08.2022	18:56	4	-1.57	66kV Pling-Gomtu fdr	66kV Pling-Gomtu fdr	Shutdown	Nil	Line	At 14:26hrs 66kV Pling-Gomtu feeder taken shut down by TMD, Pling against work permit no 004 with opening code 0941 from BPSO for RoW clearing between location PP# 2 to PP# 3. At 18:56hrs normalized with closing code 114 from BPSO.
5	18.08.2022	15:25	18.08.2022	15:32	0	-2.97	66kV Chukha-Pling feeder	Black out at Pling ss	Tripped at their end	Nil	Tripped at their end	Tripped at Chukha end.
6	18.08.2022	15:25	18.08.2022	15:45	0	-3.15	66kV Pling-Gomtu fdr	Black out at Pling ss	Earthfault	In>>>, Ia- 54.61A, Ib- 1.026kA, Ic- 1.052kA, VAB- 48.31kV, VBC- 9.162kV, VCA- 44.53kV, INM- 638.4A IND- 638.1A, Van- 31.37kV, Vbn- 17.13kV, Vcn- -13.69kV	Substation	Tripped at our end. At 15:45hrs test charged after getting clearance from BPSO and stood normal.
7	18.08.2022		18.08.2022	15:28			66kV Pling-Malbase fdr	66kV Pling-Malbase fdr				At 15:28hrs charged 66kV Pling-Malbase feeder which was under idle charge condition with closing code 134 from BPSO, since 66kV Chukha-Pling supply fail from Chukha end and 66kV Pling-Gomtu tripped at our end. At 15:57hrs opened CB of above fdr with opening code 0954 from BPSO and said feeder kept under idle charged condition.
8	19.08.2022		19.08.2022	09:34			66kV Pling-Malbase fdr	66kV Pling-Malbase fdr				At 09:34hrs as per instruction from BPSO charged 66kV Pling-Malbase feeder which was under idle charge condition with closing code 134 from BPSO due to voltage fluctuation. On dated 21.08.2022 at 11:39hrs opened CB of 66kV Pling-Malbase feeder with opening code 0961 from BPSO and feeder kept under idle charged condition.
9	21.08.2022	11:09	21.08.2022	11:29	0	-8.87	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder		DSTN OPTD, 186&86		Test charged as per instruction from BPSO with charging code 156 but didn't withstand. Informed to BPSO. At 11:29hrs test charged with same charging code as per instruction from BPSO and stood normal.
10	21.08.2022	11:09	21.08.2022	11:16	0	-8.97	66kV Pling-Gomtu fdr	66kV Pling-Gomtu fdr		operated only 186 & 86		At 11:16hrs test charged as per instruction from BPSO with charging code 157 and stood normal.
11	21.08.2022		21.08.2022	15:24			66kV Pling-Malbase fdr	66kV Pling-Malbase fdr				At 15:24hrs as per instruction from BPSO charged 66kV Pling-Malbase feeder which was under idle charge condition with closing code 160 from BPSO. At 17:13hrs opened CB of 66kV Pling-Malbase feeder with opening code 0962 as per instruction from BPSO and feeder was put back to idle charged condition.
12	25.08.2022		25.08.2022	16:05			66kV Pling-Malbase fdr	66kV Pling-Malbase fdr				At 16:05hrs as per instruction from BPSO charged 66kV Pling-Malbase feeder which was under idle charge condition with closing code 190 from BPSO. At 16:11hrs opened CB of 66kV Pling-Malbase feeder with opening code 09684 as per instruction from BPSO and feeder was put back to idle charged condition. The operation was carried out to build up the voltage.
13	26.08.2022		26.08.2022	09:51			66kV Pling-Malbase fdr	66kV Pling-Malbase fdr				At 09:51 66 kV Pling -Malbase feeder charged from our end with charging code 196 from BPSO due to high rise in winding temperature of 50/63MVA transformer II & III at Malbase end. At 17:31hrs opened CB of 66kV Pling-Malbase feeder with opening code 0986 from BPSO and said feeder was put back to idle charged condition.



Transmission System Performance Report 2022

D) 66/33/11 kV Gedu Substation												
1	13.08.2022	18:35	13.08.2022	18:40	0	1.3	66kV Gedu-Chukha Feeder.	Black out	Tripped from Chukha end.		Line segment	66kV supply restored from Chukha end.
2	18.08.2022	15:26	18.08.2022	15:32	0	1.53	66kV Gedu-Chukha Feeder.	Black out	Tripped from Chukha end.		Line segment	66kV supply restored from Chukha end.
E) 66/33/11 kV Gomtu Substation												
1	13.08.2022	18:35	13.08.2022	18:44	0	-9.279	66kV Dhamdum feeder	Whole Gomtu	Grid failed	Nil	Chukha	tripped from Dhamdum end
2	13.08.2022	18:35	13.08.2022	18:45	0	0.96	66kV Gomtu-Phuntsholing	Whole Gomtu	Grid failed	Nil	Chukha	Tripped from pling end
##	18.08.2022	15:25	18.08.2022	15:37	0	-7.784	66kV Dhamdum Line	Gomtu	Tripped	General tripped.	Gomtu SS	Tripped
F) 220/66/33 kV Dhamdum Substation												
1	18.08.2022	14:56	24.08.2022	18:02	3	-3.16	Singeygoan	Dhamdum	heavy rain with wind	REL 670 trip	NA	Line tripped due to E/F on B0 faulty, Zone: 1(General trip) 400KV conductor snap and fall on 220KV line. So Fdr. Kept under shut down.
2	23.08.2022	14:33	23.08.2022	14:47	0	-13.12	220kV Malbase feeder	Dhamdum	heavy rain with wind	REL 670 trip	NA	Feeder tripped due to, Zone 1(General trip)R,Y,B Fault and VT fuse fail but only Breaker trip from Malbase end
3	23.08.2022	14:48	23.08.2022	16:18	1	-13.12	220kV Malbase feeder	Dhamdum	heavy rain with wind	REL 670 trip	NA	Feeder tripped from Malbase end.Relay indicated; Zone: 1(General trip),R,Y,B Fault and VT fuse fail only
4	24.08.2022	15:15	25.08.2022	13:34	22	6.74	50/63MVA Transformer II	Dhamdum	sunny	shut down	NA	50/63MVA transformer II taken emergency shut down due to abnormal sound produced from the Circuit breaker R0 against work permit No:1598. BPSO shutdown code no. 0965
5	13.08.2022	18:35	13.08.2022	18:44	0	9.24	Gomtu	-	Transient fault	REC670	NA	Tripped on O/C.Fault current value 1) L1 : 2.250A 2) L2: 2.424A 3) L3: 2.318A 4) I0: 0.001A
6	18.08.2022	15:43	18.08.2022	15:53	0	8.2	Gomtu	-	Transient fault	REC670	NA	Tripped on O/C.Fault current value(Y & B0) 1) L1 = 0.294A 2) L2 =1.998A 3) L3 = 1.965A 4) I0: 0.001A
7	23.08.2022	14:02	23.08.2022	14:05	0	9.2	66kV Gomtu feeder	-	Transient fault	REL 670 General trip,Zone2 trip,Bphase fault.	NA	Fault current value(B0) I1= Fault mag.=162.22A, Fault angle=14.75deg. I2= Fault mag= 42.19A,Fault angle=145.01deg. I3=1882.45A,Fault angle= 43.65deg.
8	23.08.2023	14:02	23.08.2023	14:12	0	0	66kV Bus coupler	-	Transient fault	no relay operation	NA	Trip same time with Gomtu feeder.
B) 66/33kV Watsa Substation												
1	08-01-2022	9:46hrs	08-01-2022	10:06hrs		5.630MW	66/33KV, 8MVA transformer	Fdr. I and II	WTI tripped	WTI tripped	8MVA WTI tripped	Tripped
2	08-02-2022	7:19hrs	08-02-2022	7:50hrs		5.900MW	66/33KV, 8MVA transformer	Fdr. I and II	WTI tripped	WTI tripped	8MVA WTI tripped	Tripped
3	08-02-2022	10:49hrs	08-02-2022	11:15hrs		5.555MW	66/33KV, 8MVA transformer	Fdr. I and II	WTI tripped	WTI tripped	8MVA WTI tripped	Tripped
4	08-03-2022	13:04hrs	08-03-2022	13:22hrs		5.304MW	66/33KV, 8MVA transformer	Fdr. I and II	WTI tripped	WTI tripped	8MVA WTI tripped	Tripped
5	08-03-2022	19:40hrs	08-03-2022	19:52hrs		5.810MW	66/33KV, 8MVA transformer	Fdr. I and II	WTI tripped	WTI tripped	8MVA WTI tripped	Tripped
6	08-05-2022	8:19hrs	08-05-2022	8:40hrs		5.380MW	66/33KV, 8MVA transformer	Fdr. I and II	WTI tripped	WTI tripped	8MVA WTI tripped	Tripped
7	08-05-2022	9:39hrs	08-05-2022	10:02hrs		5.280MW	66/33KV, 8MVA transformer	Fdr. I and II	WTI tripped	WTI tripped	8MVA WTI tripped	Tripped
8	08-05-2022	10:56hrs	08-05-2022	11:22hrs		5.280MW	66/33KV, 8MVA transformer	Fdr. I and II	WTI tripped	WTI tripped	8MVA WTI tripped	Tripped
9	13/8/2022	17:50hrs	13/8/2022	17:56hrs		4.50MW	66KV SF6 breaker	Fdr. I and II	Earth fault on Y phase	Earth fault on Y phase	Fdr. II Chapcha	Tripped
10	26/8/2022	8:45hrs	26/8/2022	8:50hrs		8.50MW	66KV SF6 breaker	Fdr. I and II	Earth Fault	EF relay operated	Fdr. I Chazhi	Tripped
11	28/8/2022	00:20hrs	28/8/2022	00:30hrs		2.45MW	66KV SF6 breaker	Fdr. I and II	OC and EF on ABC phase	OC and EF on ABC phase	Fdr. II Chapcha	Tripped



Transmission System Performance Report 2022

(C) 66/33kV Olakha Substation													
1	03-08-2022	2:33	03-08-2022	2:42	0	2.86	66/33kV 20MVA, Transformer I	All the 33kV was effected as the 20MVA Transformer I & II was tripped	Over current and earth fault	Earth Fault Over Current Operated	Distribution line	Transient fault	Reset the relays and test charged the feeders and stood normal.
2	03-08-2022	2:33	03-08-2022	2:42	0	2.86	66/33kV 20MVA, Transformer II	All the 33kV was effected as the 20MVA Transformer I & II was tripped	Over current and earth fault	Earth Fault Over Current Operated	Distribution line	Transient fault	Reset the relays and test charged the feeders and stood normal.
3	04-08-2022	5:04	04-08-2022	5:25	0	3.15	66/33kV 20MVA, Transformer I	All the 33kV was effected as the 20MVA Transformer I & II was tripped	Over current and earth fault	Earth Fault Over Current Operated	Distribution line	Transient fault	Reset the relays and test charged the feeders and stood normal.
4	04-08-2022	5:04	04-08-2022	5:25	0	3.13	66/33kV 20MVA, Transformer II	All the 33kV was effected as the 20MVA Transformer I & II was tripped	Over current and earth fault	Earth Fault Over Current Operated	Distribution line	Transient fault	Reset the relays and test charged the feeders and stood normal.
(G) 66/33/11kV Dechencholing substation													
1	23.08.2022	08:46Hrs	23.08.2022	09:56Hrs	0	4.213	66KV Damji line	only Damji line	Tripped on Distance relay.	Dist relay: IA-44.02A, IB-1.55KA, & IC 1.515KA, Fault resistance -2.049G	Fault location: 29.23KM /Zone-1	Tripped	charged the fdr as per the BPSO charging code No.163 and hold the fdr normally.
(H) 66/11kV Haa Substation													
1	21.08.2022	15:35	21.08.2022	15:46	0	-0.91	66kV incomer	All	unknown	O/C	Pangbesa	The supply was normalised after resetting the relay.	
2	26.08.2022	06:06	26.08.2022	06:22	0	-0.81	66kV incomer	All	unknown	O/C & E/F	Pangbesa	The supply was normalised after resetting the relay.	
(I) 220kV Substation Semtokha													
1	01-08-2022	16:21hrs	01-08-2022	16:23hrs		46.46	66kv Semtokha-Dochnula Line	Dochnula s/s	Y & Bph OC Trip	Backup OC/EF relay optd., Y&Bph D-2 Trip IA=240.3A,IB=5.768kA, IC=5.605kA&IN=17.39A		Transient	
2	04-08-2022	05:03hrs	04-08-2022	05:10:00hrs		46.46	66kv Semtokha-Dochnula Line	Dochnula s/s	Y & Bph OC Trip	Backup OC/EF relay optd., Y&Bph D-2 Trip IA=211.7A,IB=5.740kA, IC=5.614kA&IN=16.88A		Transient	
3	16-08-2022	07:31hrs	16-08-2022	07:34hrs		46.63	66kv Semtokha-Dochnula Line	Dochnula s/s	Y & Bph OC Trip	Backup OC/EF relay optd., Y&Bph D-2 Trip IA=275A,7A,IB=5.712kA,IC=5.522kA&IN=17.99A		Transient	
4	21-08-2025	05:32hrs	21-08-2022	05:47hrs		47.31	66kv Semtokha-Dochnula Line	Dochnula s/s	Y & Bph OC Trip	Backup OC/EF relay optd., Y&Bph D-2 Trip IA=303.5A,7A,IB=5.68kA,IC=5.43kA&IN=17.11A		Transient	
5	26-08-2022	18:34hrs	21-08-2022	18:40hrs		45.25	66kv Semtokha-Dochnula Line	Dochnula s/s	Y & Bph OC Trip	Backup OC/EF relay optd., Y&Bph D-2 Trip O/C IA=263.2A,IB=5.799kA, IC=5.605kA		Transient	



Transmission System Performance Report 2022

(K) 66/33kV Changidaphu Substation													
1	26-08-2022	18:34hrs	26-08-2022	18:50hrs		-5.05	66kV Cangidaphu-Olakha Line	66kV Cangidaphu-Olakha Line		Distance Protectoin, Zone 2 Yph Trip, R=120.162, Y=566.002, B=625.669	Trasient		
(L) 66/33kV Damji Substation													
1	23.08.2022	0844 hrs	23.08.2022	0858 hrs	0	-3.83	66 kV Incoming Line	Whole Substation	Trip	NA		Transmission Line tripped from Dechencholing Substation	
(M) 66/11kV Dochula Substation													
1	01-08-2022	16:21	01-08-2022	16:25		-32.06	66kV Sentokha	Sentokha - Dochula	Transit fault	Under voltage and \$6 relay	Sentokha	Temporary	1
2	01-08-2022	17:21	01-08-2022	16:31		-30.45	66kV Lobeyisa	Lobeyisa - Dochula	Transit fault	Under voltage and \$6 relay	Lobeyisa	Temporary	1
3	04-08-2022	05:05	04-08-2022	05:15		-31.76	66kV Sentokha	Sentokha - Dochula	Transit fault	Under voltage and \$6 relay	Sentokha	Temporary	1
4	04-08-2022	05:05	04-08-2022	05:18		-30.24	66kV Lobeyisa	Lobeyisa - Dochula	Transit fault	Under voltage and \$6 relay	Lobeyisa	Temporary	1
5	16-08-2022	7:31	16-08-22	7:35		-32.04	66kV Sentokha	Sentokha - Dochula	Transit fault	Under voltage and \$6 relay	Sentokha	Temporary	1
6	16-08-2022	7:31	16-08-2022	7:37		-30.45	66kV Lobeyisa	Lobeyisa - Dochula	Transit fault	Under voltage and \$6 relay	Lobeyisa	Temporary	1
7	21-08-2022	05:32	21-08-2022	05:49		-32.89	66kV Sentokha	Sentokha - Dochula	Transit fault	Under voltage and \$6 relay	Sentokha	Temporary	1
8	21-08-2022	05:32	21-08-2022	05:52		-30.29	66kV Lobeyisa	Lobeyisa - Dochula	Transit fault	Under voltage and \$6 relay	Lobeyisa	Temporary	1
9	26-08-2022	18:34	26-08-2022	18:48		-29.64	66kV Sentokha	Sentokha - Dochula	Transit fault	Under voltage and \$6 relay	Sentokha	Temporary	1
10	26-08-2022	18:34	26-08-2022	18:42		-27.98	66kV Lobeyisa	Lobeyisa - Dochula	Transit fault	Under voltage and \$6 relay	Lobeyisa	Temporary	1



September 2022

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
66kV & Above													
(A) 400/220/66/11 kV Malbase Substation													
1	06-09-2022	00:08	06-09-2022	00:12	0	33	50 MVA transformer III	Malbase Substation	Tripping	86optd, Diff Harm Blk			IL1= 85.52<167.70deg , IL2= 152.33A<64.93deg,IL3= 317.11A,-61.26deg,IL4= 178.63,-41.14deg, Transformer charged with charging code 252/BPSO
2	06-09-2022	00:08	06-09-2022	00:22	0	-134	220kV Chukha feeder III	Malbase Substation	Tripping	MICOM Relay, START BN, Tripped Phase,ABC,Start Element Distance, Distance trip Zone ,AR lockout shot ,system frequency 49.93, fault duration:53.41ms, Relay time :81.78ms,	11.42 km		IA= 488.8A ,IB=5.40kA,IC=267.1A, Charged with Code 251/BPSO .
3	07-09-2022	15:51	07-09-2022	15:59	0	-	66kV Bus Coupler	Malbase Substation	Tripping	86 optd ,IEF, 50N Trip,IOC, 50-TRIP,GENERAL TRIP			IL1=11.2928A/-59.91deg,IL2=125.07A/-61.57deg,IL3=13239.57A/82.06deg, IL4= 9495.09A/20.76deg
4	07-09-2022	15:51	07-09-2022	15:59	0	17	66kV Pasakha fdr no I	Malbase Substation	Tripping	86 optd ,IEF, 50N Trip,IOC, 50-TRIP,GENERAL TRIP			IL1=1101.08A/107.54deg,IL2=65.25A/-61.16deg, IL3=1079.85A/-93.43deg, IL4= 373.73A/13.4deg
5	15-09-2022	22:41	15-09-2022	22:46	0	10	220kV Malbase-Samtse	Malbase Substation	Tripping	M1 trip,Zone1 trip	10.3km		I1=24.26A<232.2, I2=56.69A<238.3, I3=2208A<39.58, I4=2134A<38.78
6	15-09-2022	22:38	15-09-2022	22:44	0		220kV bus coupler	Malbase Substation	Tripping	86OPTD,			
7	15-09-2022	22:41	15-09-2022	22:48	0	34	50 MVA transformer III	Malbase Substation	Tripping	OLTc trip,Diff Restrain,Diff Trip,Diff,WARM,Diff WAVM Trip			IL1=91.66A<27.36,IL2=151.47A<-120.59,IL3=65.52A<-126.91,IL4=227.62<-98.85
8	16-09-2022	23:28	16-09-2022	23:47	0	-119	220kV Chukha feeder III	Malbase Substation	Tripping	86 optd, Zone 1 Tripped			IA =463.3A,IB =419.9A,IC=4.718kA
9	16-09-2022	23:28	16-09-2022	23:49	0	27	50 MVA transformer III	Malbase Substation	Tripping	DIFF. TRIP,27 TRIP,86 Optd			IL1 =91.99 A< -41.12 DEG,IL2 =151.66 A< 112.19 DEG,IL3=63.07A <-119.95DEG,IL4=56.3A<-94.36DEG
10	16-09-2022	10:28	16-09-2022	10:31	0		50 MVA transformer III	Malbase Substation	Tripping	EXT. TRIP, 86 OPTD.			IL1 = 106.82 A, IL2= 423.8 A, IL3= 284.97A,IL4= 217.19A
11	16-09-2022	19:34	16-09-2022	19:50	0	10.4	220kV Malbase-Samtse	Malbase Substation	Tripping	B/U Trip			LI=3031A,<270.4,L2=100.8A<182.3,I3=2961A<51.30,L4=1909A<337.9
12	16-09-2022	19:34	16-09-2022	19:39	0	26	50 MVA transformer III	Malbase Substation	Tripping	EXT TRIP, BUCH Trip			I1=13.15A<-47.12=111.5A<-132.39 I3=67.55A<144.37
13	16-09-2022	22:28	16-09-2022	22:31	0	28	50 MVA transformer III	Malbase Substation	Tripping	EXT. TRIP, 86 OPTD. OLTc, BUCH trip			IL1 = 106.82 A, IL2= 423.8 A, IL3= 284.97A,IL4= 217.19A
14	20-09-2022	08:31	20-09-2022	08:34	0	0	220 kV Bus coupler	Malbase Substation	Tripping	86 optd.			No data displayed
15	22-09-2022	02:55	22-09-2022	03:00	0	115	220kV Chukha feeder III	Malbase Substation	Tripping	O/C,Zone 1 trip , R,Y,B phase Trip, fault location :9.157Km,	fault location 9.157Km,Fd=80.02ms		IL1=10.94A,IL2=7.15KA,IL3=6.471KA
16	22-09-2022	02:55	22-09-2022	03:01	0	28	50 MVA transformer III	Malbase Substation	Tripping	Diff trip, 86 optd			IL1=153.55A<-19.74,IL2=96.02A<-34.56,IL3=76.86A,<-41.48,IL4=322.34A,<-29.22
17	22-09-2022	02:55	22-09-2022	03:00	0	-	220kV bus coupler	Malbase Substation	Tripping	CBFP			IA=11.6A,IB=6846A, IC=5810A,IE=5393AE/F IDMT IE=5393A.
18	22-09-2022	03:04	22-09-2022	03:06	0	-	220kV bus coupler	Malbase Substation	Tripping	CBFP			-
19	22-09-2022	03:04	22-09-2022	03:08	0	28	50 MVA transformer III	Malbase Substation	Tripping	DIFF. TRIP,86 Optd			IL1=404.32A<95.28deg,IL2=176.33A,<-30.73deg,IL3=142.81A<-134.32deg,IL4=210.83A<86.04deg
20	22-09-2022	03:04	22-09-2022	04:04	1	-111	220kV Chukha feeder III	Malbase Substation	Tripping	Zone 1 trip,86 optd	Zone 1 trip, fault location =11.59Km,		IA=10.56A,IB=7.023kA,IC=5.829kA
21	22-09-2022	04:04	22-09-2022	04:12	0	-115	220kV Malbase-Samtse	Malbase Substation	Tripping	M1--trip,zone1 trip,	Fault loop=L1-L2,distance 6.2kM		M1--trip,zone1 trip,Fault loop=L1-L2, distance 6.2kM,IL1=4972A>284.6deg,IL2=6654A>164.7deg,IL3=4900A>38.75deg,IL4=994.7A>165.7deg
22	22-09-2022	04:04	22-09-2022	04:11	0	66	400/220kV, 200MVA ICT	Malbase Substation	Tripping	Buchholz=trip			IL1=177.4A>40.06deg,IL2=181.4A>164.9deg,IL3=159.1A>66.65deg.
23	23-09-2022	01:57	23-09-2022	02:07	0	19	66kV Pasakha fdr no II	Malbase Substation	Tripping	67_Trip, 86 OPTD, General Trip, 67N_Trip			IL1= 0.63A>15.65deg, IL2= 166.43A>-14.28deg,IL3= 165.86A>162.62deg, IL4=0.52A>15.65deg



Transmission System Performance Report 2022

24	23-09-2022	01:57	23-09-2022	02:06	0	19	66kV Pasakha fdr no IV	Malbase Substation	Tripping	67N Trip, General Trip			IL1= 519.61A>-96.07deg,IL2= 666.2A>-124.6deg. IL3=2509.85A>81.22deg, IL4=519.61A>-96.07deg
25	23-09-2022	01:57	23-09-2022	02:05	0	-	66kV Bus Coupler	Malbase Substation	Tripping	General Trip, 67 Trip, 67_ST2L3			IL1=919.04A>80.79deg, IL2=487.09A>125.7deg, IL3=4758.81A>66.65deg,IL4=5948.01A>72.8deg
26	23-09-2022	17:27	23-09-2022	17:35	0	73	400/220kV, 200MVA ICT	Malbase Substation	Tripping				
27	23-09-2022	17:27	23-09-2022	17:37	0	-	220 kV Bus coupler	Malbase Substation	Tripping				
28	23-09-2022	17:27	23-09-2022	17:45	0	27	50 MVA transformer II	Malbase Substation	Tripping				IL1=711.85A-2.71deg,IL2=734.69A -124.06deg,IL3=704.74A .97deg
29	23-09-2022	17:27	24-09-2022	17:46	24	19	66kV Pasakha fdr no II	Malbase Substation	Tripping				"IL1=0.29A/-1.11deg,IL2=806.11 A/18.89deg,IL3=829.52 A/-162.02deg. Test charge done at 18:25hrs. date 23/09/2022 but could not hold and kept on open condition. Taken shutdown for OPG wire resting by TMD/pling (work permit number 288) on 24/09/2022 at 8:45 hours and Test charged at 24/09/2022 @13:39 but could not hold. Test charge done @ 14:45 hold in Idle charge with no load given"
30	23-09-2022	17:27	24-09-2022	17:46	24	20	66kV Pasakha fdr no IV	Malbase Substation	Tripping				"IL1=814.97A/149.39deg,IL2=573.27A /-156.57deg IL3=2202.32A/87.25deg. Test charge done at 18:25hrs @ 23/09/2022. but could not hold and kept on open condition.Taken shutdown for OPG wire resting by TMD/pling (work permit number 288) on 24/09/2022 at 8:45 hour and test charged at 24/09/2022 @13:40 but could not hold - Test charged hold @14:45 on 24/09/2022 in Idle Charge condition"
31	23-09-2022	17:27	24-09-2022	17:46	24	19	66kV Pasakha fdr no I	Malbase Substation	hand tripped				"Handtripped during charging of 220/66kV 50 MVA Transformer 2, test charged at 20:48 on 23/09/2022 but could not hold in ring system with 66kV bhutan Concast.Taken shutdown for OPG wire resting by TMD/pling (work permit number 288)on 24/09/2022 at 8:45 hour and test charged & hold at 24/09/2022 13:39 dated 24/09/2022 but hand tripped at 14:00 hrs dated 24/09/2022 due to missing Y phase current and is currently being attended by TMD pling (Work Permit Number 290 issued to TMD p/ling) at 15:35 hrs. and at 17:30 hrs Work permit no 290 was returned by TMD PLING and all 66kV out going feeder Charged at 17:45 hrs."
32	23-09-2022	17:27	24-09-2022	18:23	24	-7.2	66kV Phuntsholing fdr.	Malbase Substation	Tripping	N1-trip,86opted			IL1=1.233klI2=197.5k,IL3=1.222klN=2.031k.Kept in oped condition.
33	23-09-2022	20:48	23-09-2022	20:53	0	-	220 kV Bus coupler	Malbase Substation	Tripping	86 optd.	line		No data displayed
34	23-09-2022	20:48	23-09-2022	20:55	0	59	400/220kV, 200MVA ICT	Malbase Substation	Tripping	86 optd.	line		IL1=0.058A/35.35DEG,IL2=0.160A/28.57DEG,IL3=0.005A/173.4DEG.tripped due to test charge of 66kV feeder Tripped while doing test charge on 66kV Pasakha I and 66kV bhutan Concast fdr..
35	23-09-2022	20:48	23-09-2022	20:58	0	0.42	50 MVA transformer II	Malbase Substation	Tripping	86 optd.	line		IA=0.06A, IB=0.03A, IC=0.02A(no load 66kV feeders out Tripped while doing test charge on 66kV Pasakha I and 66kV bhutan Concast fdr.)
36	23-09-2022	21:42	23-09-2022	22:38	0	88	220kV Birpara feeder	Malbase Substation	Tripping	O/C on R&B phase,general trip,zone 3 trip.	fault location Distance=55.54KM.		IA=2.157kA, IB=170.6A, IC=2.650kA
38	28-09-2022	18:40	28-09-2022	18:44	0	-108	220kV Chukha feeder III	Malbase Ss	Tripping		line		General Trip, Zone-1 Trip, Fault loop=L3-N, Dist.= 9.00 Km. Trip value IL1=378.8A/200.1deg, IL2=132.9A/71.22deg, IL3=5504A/44.84deg, IL4=5284A/47.38deg
39	28-09-2022	18:40	28-09-2022	18:45	0	25	50MVA Transformer III	Malbase Ss	Tripping				027 TRIP, DIFF TRIP, Tripped value IL1=76.52A/-61.44deg, IL2=139.94A/-119.29deg,IL3=86.52A/-123.68deg, IL4=273.19A/-107.0deg
40	30-09-2022	12:32	30-09-2022	12:39	0	-117.44	220kV Malbase-Chhukha	Malbase Ss	Tripping				tripped (BB protection)
41	30-09-2022	12:32	30-09-2022	12:37	0	70	400/220kV, 200MVA ICT	Malbase Ss	Tripping				tripped (BB protection)
42	30-09-2022	12:32	30-09-2022	12:41	0	14.56	220kV Malbase-Samtse	Malbase Ss	Tripping				tripped (BB protection)
43	30-09-2022	12:32	30-09-2022	13:26	0	30.08	220kV Malbase-Birpara.	Malbase Ss	Tripping				tripped (BB protection)
44	30-09-2022	12:32	30-09-2022	12:38	0		220 kV Bus coupler	Malbase Ss	Tripping				
45	30-09-2022	13:05	30-09-2022	13:12	0	36	400/220kV, 200MVA ICT	Malbase Ss	Tripping				tripped (BB protection)
46	30-09-2022	13:05	30-09-2022	13:17	0		220 kV Bus coupler	Malbase Ss	Tripping				tripped (BB protection)
47	30-09-2022	13:05	30-09-2022	13:18	0	-75.84	220kV Malbase-Chhukha	Malbase Ss	Tripping				BB trip,IL1=91.72A<204deg,IL2=113A<79.85deg,IL3=101.32A,312.1deg,IL4=6.067A<353.4deg.
48	30-09-2022	13:05	30-09-2022	13:22	0	9.9	220kV Malbase-Samtse	Malbase Ss	Tripping				BB trip,IL1=27.72A<28.63def,IL2=28.26A<296.4deg,IL3=28.82A,144.5deg,IL4=82A<52deg.



Transmission System Performance Report 2022

(B)220/66/11 kV Singhigaon Substation													
##	07.09.2022	15:51	7.9.22	15:54	0	32	66kV Bhutan Concast fdr.	Singhigaon Ss	O/C	Direction Time O/C trip,IE>>DIRECTIONAL TRIP,GENERAL TRIP, 86 OPTD.	line		IL1=1.14kA,IL2=0.26kA,IL3=0.34kA
##	07.09.2022	15:51	7.9.22	15:54	0	-	66kV Bus I	Singhigaon Ss	-	86 optd., IEP trip	-		-
##	16.9.22	19:34	16.9.22	20:58	1	3	220kV Singhigaon- Samtse	Singhigaon Ss	tripped	zone 1 trip fault loop I3-N 14.6Km	line		I1=41.31A<194.2,I2=45.02A<248.1,I3=1358A<4085,I4=1284A<40.84
##	16.9.22	22:28	16.9.22	22:36	0	0.1	220kV Singhigaon- Samtse	Singhigaon Ss	tripped	General Trip, Zone 1 Trip, F/L-II N, Distance=33Km	line		I1=2091A<203.6deg,I2=86.15A<96.50deg,I3=80.81A<11.7deg,I4=2714A,203.6deg.
##	17.9.22	22:16	17.9.22	22:17	0	0.067	11kV feeder no I	Singhigaon Ss	O/C	General trip,Time O/C trip, IEP trip	line		IL1=1.38KA, IL2=1.45KA, IL3=1.39KA
##	18.9.22	16:46	18.9.22	16:48	0	0.06	11kV feeder no I	Singhigaon Ss	O/C	General trip, O/C trip, IEP trip	line		IL1=1.08kA IL2=0.01kA IL3=0.01kA
##	18.9.22	21:01	19.9.22	10:10	13	0.361	11KV Feeder III	Singhigaon Ss	O/C	IEP,time over current trip	line		Fault Current IL1=0.02kA, IL2=0.02kA, IL3=0.39kA
##	20.9.22	14:53	20.9.22	17:29	2	1.25	11KV Feeder III	Singhigaon Ss	O/C	IEP,time over current trip	line		IL1=0.02kA, IL2=0.02kA, IL3=0.39kA
##	21.9.22	02:04	21.9.22	11:52	9	0.458	11KV Feeder III	Singhigaon Ss	O/C	General trip, O/C trip, IEP trip	line		IL1=0.01kA, IL2=0.01kA, IL3=0.39kA
##	21.9.22	11:45	21.9.22	16:51	#NUM!	0.58	11KV Feeder III	Singhigaon Ss	O/C	General trip, O/C trip, IEP trip	line		IL1=0.06kA,IL2=0.07kA,IL3=0.44kA
##	22.9.22	00:56	22.9.22	13:46	12	0.643	11KV Feeder III	Singhigaon Ss	O/C	General trip, O/C trip, IEP trip	line		IL1=0.05kA,IL2=0.05kA,IL3=0.43kA
##	22.9.22	04:04	22.9.22	04:32	0	2.09	220kV Singhigaon- Samtse	Singhigaon Ss	tripped	-	line		IL1=525.1A<159.3deg,IL2=2342A<277.5deg,IL3=2308<46.32deg,IL4=1475A<341.7deg.
##	23.9.22	01:57	23.9.22	02:06	0	27.5	66kV Bhutan Concast fdr.	Singhigaon Ss	tripped	directional time OC trip, IE>>Directional trip, I>> Directional Trip, General trip.	line		IL1=0.46kA, IL2=1.14kA, IL3=5.62kA
##	23.9.22	17:27	24.9.22	13:47	20	26	66kV Bhutan Concast fdr.	Singhigaon Ss	tripped	Diff,time O/C trip, IE>>diff-trip, I>>diff. trip.	line		I1=4.35kA, I2=0.08kA, I3=6.30kA test charge at 20:49 hrs but could not hold and kept on open condition.
##	25.9.22	10:03	25.9.22	10:21	0	0.779	11KV Feeder II	Singhigaon Ss	O/C	General trip, Time O/C trip, IEP>> trip	line		IL1=0.05kA,IL2=0.04kA,IL3=1.54kA

(B)66/33/11 kV Phuntsholing Substation													
1	07.09.2022	18:23	07.09.2022	18:28	0	-3.45	66kV Chukha-Pling feeder	Black out at Pling ss			Tripped at chukha end		At 18:36hrs 66kV Chukha-Pling feeder got tripped from chukha end and 66kV Pling-Gomtu feeder got tripped at Gomtu end (ie 66kV Dhamdhum-Gomtu feeder got tripped at Gomtu end) causing black out at Pling. At 18:29hrs normalised the 66kV Chukha-Pling from Chukha end and at 18:32hrs normalised 66kV Dhamdhum-Gomtu feeder from Gomtu feeder.
2	07.09.2022	18:23	07.09.2022	18:32	0	-2.07	66kV Pling-Gomtu fdr	Black out at Pling ss			66kV Dhamdhum-Gomtu fdr tripped from Dhamdhum Ss		
3	11.09.2022	20:35	11.09.2022	20:43	0	-3.09	66kV Chukha-Pling feeder	Black out at Pling ss			Tripped at chukha end		At 20:35hrs 66kV Chukha-Pling feeder got tripped from chukha end and 66kV Pling-Gomtu feeder got tripped at Gomtu end (ie 66kV Dhamdhum-Gomtu feeder got tripped at Gomtu end) causing black out at Pling. At 20:43hrs normalised the 66kV Chukha-Pling from Chukha end and at 20:42hrs normalised 66kV Dhamdhum-Gomtu feeder from Gomtu feeder.
4	11.09.2022	20:35	11.09.2022	20:42	0	-3.05	66kV Pling-Gomtu fdr	Black out at Pling ss			66kV Dhamdhum-Gomtu fdr tripped from Dhamdhum Ss		
5			11.09.2022	20:38	20	idle charge	66kV Pling-Malbase fdr	66kV Pling-Malbase fdr					At 20:38hrs charged 66kV Pling-Malbase feeder which was under idle charge condition with closing code 271 from BPSO. At 20:45hrs opened CB of above fdr with opening code 1015 from BPSO and said feeder kept under idla charged condition after normalising 66kV Chukha and Gomtu feeder.



Transmission System Performance Report 2022

6	15.09.2022	22:15	15.09.2022	22:22	0	-3.67	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder	Tripped at both end	DSTN OPTD, 186&85	Tripped at both end	Tripped on fault	The cause of tripping was due to transient fault. At 22:22hrs normalised with charging code 287 from BPSO.
7	15.09.2022	22:38	15.09.2022	23:07	0	-1.58	66kV Pling-Gomtu fdr	Black out at Pling ss	Tripped at both end	DSTN OPTD, 186&86	Tripped at both end	Tripped on fault	Tripped at both end. At 23:07hrs test charged after getting clearance from BPSO and stood normal.
8	15.09.2022	22:38	15.09.2022	22:46	0	-3.67	66kV Chukha-Pling feeder	Black out at Pling ss	Tripped at chukha end		Tripped at chukha end		At 22:38hrs 66kV Chukha-Pling feeder got tripped from chukha end and 66kV Pling-Gomtu feeder got tripped at both end causing black out at Pling. At 22:46hrs normalised 66kV Chukha-Pling fdr from Chukha end with charging code 290
9	16.09.2022	19:33	16.09.2022	19:41	0	-1.89	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder	Tripped at chukha end		Tripped at chukha end		At 19:33hrs 66kV Chukha-Pling feeder got tripped from chukha end causing black out at Pling. At 19:41hrs normalised 66kV Chukha-Pling fdr from Chukha end.
10	16.09.2022	19:33	16.09.2022	20:02	0	-4.70	66kV Pling-Gomtu fdr	66kV Pling-Gomtu fdr	Tripped at their end		66kV Dhamdum-Gomtu fdr tripped from Dhamdhum Ss		At 19:33hrs 66kV Pling-Gomtu feeder got tripped at Gomtu end (i.e. 66kV Dhamdum-Gomtu fdr tripped at Dhamdhum end) causing black out at Pling. At 20:02hrs normalised 66kV Pling-Gomtu fdr from Dhamdhum end.
11	16.09.2022	23:28	17.09.2022	00:50	1	-4.06	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder	Tripped at chukha end		Tripped at chukha end		At 23:28hrs 66kV Chukha-Pling fdr tripped from chukha end (Pling black out) and as per instruction from BPSO opened CB for said fdr at 23:50hrs at our end. At 00:50hrs charged from our end as per instruction from BPSO with charging code 296 and stood normal.
12	16.09.2022	23:28	17.09.2022	11:04	10	-0.15	66kV Pling-Gomtu fdr	66kV Pling-Gomtu fdr	Tripped at their end		66kV Dhamdum-Gomtu fdr tripped from Dhamdhum Ss		At 23:28hrs 66kV Pling-Gomtu feeder got tripped at Gomtu end (i.e. 66kV Dhamdum-Gomtu fdr tripped at Dhamdhum end) causing black out at Pling. At 23:37hrs test charged from Gomtu end but got tripped at our end operating distance relay. As per instruction from BPSO test charged from our end but again got tripped acutating same relay. On dated 17.09.2022 at 11:04hrs as per instruction from BPSO againt closing code 300 66kV Pling-Gomtu fdr charged and stood normal.
13			16.09.2022	23:53		Idle charge	66kV Pling-Malbase fdr	66kV Pling-Malbase fdr					At 23:53hrs as per instruction from BPSO charged 66kV Pling-Malbase feeder which was under idle charged condition, since 66kV Chukha-Pling fdr and 66kV Pling-Gomtu fdr couldn't stand while test charging. On dated 17.09.2022 at 11:06hrs opened CB of 66kV Pling-Malbase feeder with opening code 1019 as per instruction from BPSO and feeder was put back to idle charged condition.
14	20.09.2022	08:31	20.09.2022	08:37	0	-3.02	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder	Tripped at chukha end		Tripped at chukha end		At 08:31hrs 66kV Chukha-Pling fdr tripped from chukha end (Pling black out) and at 08:37hrs normalised the supply from Chukha end with charging code 316.
15	20.09.2022	08:31	20.09.2022	08:41	0	-2.11	66kV Pling-Gomtu fdr	66kV Pling-Gomtu fdr	Tripped at our end	DSTN OPTD, 186&86	Tripped at our end		At 08:31hrs 66kV Pling-Gomtu feeder got tripped at our end causing black out at Pling. At 08:41hrs as per instruction from BPSO charged Pling-Gomtu fdr againt closing code 318.
16	22.09.2022	02:49	22.09.2022	03:15	0	-4.86	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder	Tripped at our end	DSTN OPTD, 186&86	Tripped at our end	Tripped on fault	At 03:15hrs test charged the feeder as per instruction from BPSO and stood normal.
17	22.09.2022	03:53	22.09.2022	09:53	6	-4.86	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder	Tripped at both end	DSTN OPTD, 186&86	Tripped at both end	Tripped on fault	66kV Pling-Chukha fdr tripped at both end. Relay OPTD Dist OPTD. As per instruction from BPSO test charged at 05:05hrs but tripped on same fault and said feeder kept under shutdown (grid fail). At 09:53hrs as per instruction from BPSO normalised the 66kV Pling-Chukha fdr.
18			22.09.2022	04:15			66kV Pling-Malbase fdr	66kV Pling-Malbase fdr					At 04:15hrs as per instruction from BPSO charged 66kV Pling-Malbase feeder which was under idle charged condition.
19	20.09.2022	12:31	20.09.2022	12:34	0	-2.23	66kV Pling-Gomtu fdr	66kV Pling-Gomtu fdr	Tripped at our end	DSTN OPTD, 186&86	Tripped at our end		The cause of tripping was due to transient fault. (Pling black out)
20	23.09.2022	01:57	23.09.2022	02:07	0	-3.01	66kV Pling-Gomtu fdr	66kV Pling-Gomtu fdr	Tripped at our end	DSTN OPTD, 186&86	Tripped at our end		The cause of tripping was due to transient fault. (Pling black out)
21	23.09.2022	01:57	23.09.2022	02:10	0	-7.43	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder	Tripped at chukha end		Tripped at chukha end		The cause of tripping was due to transient fault. (Pling black out)
22	23.09.2022	01:57	23.09.2022	02:04	0	6.12	66kV Pling-Malbase fdr	66kV Pling-Malbase fdr	Tripped at Malbase end		Tripped at Malbase end		The cause of tripping was due to transient fault. (Pling black out)
23	23.09.2022	17:27	23.09.2022	17:35	0	-7.36	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder	Tripped at chukha end		Tripped at chukha end		The cause of tripping was due to transient fault. (Pling black out)
24	23.09.2022	17:27	23.09.2022			7.20	66kV Pling-Malbase fdr	66kV Pling-Malbase fdr	Tripped at Malbase end		Tripped at Malbase end		The cause of tripping was due to transient fault. (Pling black out). As per instruction of BPSO 66kV Pling-Malbase feeder kept open at our end with opening code 033.
25	23.09.2022	17:27	23.09.2022	17:43	0	-3.94	66kV Pling-Gomtu fdr	66kV Pling-Gomtu fdr	Tripped at our end	DSTN OPTD, 186&86	Tripped at our end		The cause of tripping was due to transient fault. (Pling black out).At 17:37hrs test charged as per instruction from BPSO but couldn't withstand. At 17:43hrs again test charged as per instruction from BPSO and stood normal.



Transmission System Performance Report 2022

26	27.09.2022	07:42	27.09.2022	07:50	0	-3.00	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder	Tripped at both end		Tripped at both end		The cause of tripping was due to transient fault.
27	28.09.2022	18:42	28.09.2022	18:52	0	-2.53	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder	Tripped at both end	Tripping relay 186& 86	Tripped at both end		The cause of tripping was due to transient fault. Test charged after getting clearance from BPSO with charging code 1442.
28	28.09.2022	19:12	28.09.2022	22:46	3	-0.84	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder	Tripped at both end	Tripping relay 186& 86	Tripped at both end		As per instruction from BPSO CB kept open for 66kV Pling-at our end.
29			28.09.2022	19:16			Idle charge	66kV Pling-Malbase fdr	66kV Pling-Malbase fdr				At 19:16hrs charged 66kV Pling-Malbase with charging code 1444 since CB kept open for 66kV Pling-chukha feeder at our end as per instruction from BPSO. At 22:30hrs CB opened for said feeder with opening code 046 from BPSO and feeder kept under idle charged.
30			29.09.2022	10:23			Idle charge	66kV Pling-Malbase fdr	66kV Pling-Malbase fdr				At 10:23hrs charged 66kV Pling-Malbase with charging code 1452 as per instruction from BPSO. At 22:30hrs CB opened for said feeder with opening code 046 from BPSO and feeder kept under idle charged.
31	29.09.2022	13:30	29.09.2022	13:37	0	-6.27	66kV Pling-Gomtu fdr	66kV Pling-Gomtu fdr	Tripped at both end	186&86	Tripped at both end		The cause of tripping was due to transient fault.
32	30.09.2022	12:32	30.09.2022	12:38	0	-9.19	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder	Tripped at our end	DSTN OPTD, 186&86	Tripped at our end	Tripped on fault	Pling blackout since 66kV Pling-Malbase and Pling-Gomtu feeder got interrupted due to 220kV supply failure from Malbase end
33	30.09.2022	13:05	30.09.2022	13:18	0	-2.26	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder	Tripped at our end	DSTN OPTD, 186&86	Tripped at our end	Tripped on fault	Pling blackout since 66kV Pling-Malbase and Pling-Gomtu feeder got interrupted due to 220kV supply failure from Malbase end
34			30.09.2022	13:19		-5.07	66kV Pling-Malbase fdr	66kV Pling-Malbase fdr					At 13:19hrs CB opened for 66kV Pling-Malbase feeder with opening code 064 from BPSO and feeder kept under idle charged.
(D) 66/33/11 kV Gedu Substation													
1	15.09.2022	22:15	15.09.2022	22:22	0	1.86	66kV Chukha-P/ling	Balckout	Bad weather condition		Line segment		66kV supply charged from Chukha end.
2	15.09.2022	22:39	15.09.2022	22:46	0	1.86	66kV Chukha-P/ling	Balckout	Bad weather condition		Line segment		66kV supply charged from Chukha end.
3	16.09.2022	19:34	16.09.2022	19:42	0	2.71	66kV Chukha-P/ling	Balckout	Bad weather condition		Line segment		66kV supply charged from Chukha end.
4	16.09.2022	23:29	16.09.2022	23:47	0	1.41	66kV Chukha-P/ling	Balckout	Bad weather condition		Line segment		66kV supply charged from Chukha end.
5	22.09.2022	2:49	22.09.2022	3:15	0	1.1	66kV Chukha-P/ling	Balckout	Bad weather condition		Line segment		66kV supply charged from Chukha end.
6	22.09.2022	3:53	22.09.2022	5:13	1	1.1	66kV Chukha-P/ling	Balckout	Bad weather condition		Line segment		66kV supply charged from Chukha end.
7	23.09.2022	1:58	23.09.2022	2:05	0	1.36	66kV Chukha-P/ling	Balckout	Bad weather condition		Line segment		66kV supply charged from Chukha end.
8	28.09.2022	7:43	28.09.2022	7:47	0	2.03	66kV Chukha-P/ling	Balckout	Bad weather condition		Line segment		66kV supply charged from Chukha end.
9	28.09.2022	18:42	28.09.2022	18:52	0	1.87	66kV Chukha-P/ling	Balckout	Bad weather condition		Line segment		66kV supply charged from Chukha end.
10	28.09.2022	19:12	28.09.2022	19:24	0	1.69	66kV Chukha-P/ling	Balckout	Bad weather condition		Line segment		66kV supply charged from Chukha end.



Transmission System Performance Report 2022

(E) 66/33/11 kV Gomtu Substation													
1	07.09.2022	17:23	07.09.2022	17:28	0	2.23	66kV Phuentsholing feeder	Gomtu substation	Tripped from Chukha	Nil	Line segment	grid fail	Tripped from chukha end and supply resumed at 17:28hrs
2	07.09.2022	17:23	07.09.2022	17:32	0	-6.956	66kV Dhamdhum feeder	Gomtu substation	B-phase & Y-Phase fault	Nil	Line segment	Transient fault	Charged as per the instruction from BPSO and charge withstand
3	11.09.2022	20:35	11.09.2022	20:39	0	3.51	66kV Phuentsholing feeder	Gomtu substation	Grid failed	Nil	Line segment	grid fail	Grid failed and supply resumed at 20:39hrs
4	11.09.2022	20:35	11.09.2022	20:42	0	-9.924	66kV Dhamdhum feeder	Gomtu substation	Three Phase fault	General Trip, Zone 4 Trip, R phase Fault, Y Phase Fault, B Phase fault & Distance relay operated	Line segment	Transient fault	Charged the line as per the instruction received from BPSO and charge withstand
5	15.09.2022	22:39	15.09.2022	23:08	0	1.54	66kV Phuentsholing feeder	Nil	Over current	51 Cx and 51 Bx	Gomtu substation	Transient fault	Charged the line as per the instruction received from BPSO and charge withstand charging code 290
6	15.09.2022	22:41	15.09.2022	22:48	0	-6.54	66kV Dhamdhum feeder	Gomtu substation	Grid failed	Nil	Malbase substation	grid fail	Grid failed and supply resumed at 22:48hrs.
7	16.09.2022	23:28	16.09.2022	23:37	0	-0.22	66kV Phuentsholing feeder	Nil	Over current	51 Cx and 51 Bx	Line segment	Transient fault	Test charged the line as per the instruction of BPSO and kept breaker opened at pling end at charged on 17.09.2022 at 11:04 hrs from pling end
8	16.09.2022				0								
9	20.09.2022	8:31	20.09.2022	8:41	0	2.11	66kV Phuentsholing feeder	Gomtu substation	Grid failed	Nil	Line segment	Transient fault	Tripped from source
10	20.09.2022	8:31	20.09.2022	8:41	0	-6.225	66kV Dhamdhum feeder	Gomtu substation	Grid failed	Nil	Line segment	Transient fault	Tripped from source
11	22.09.2022	4:05	22.09.2022	4:15	0	-7.44	66kV Dhamdhum feeder	Gomtu substation	Grid failed	Nil	Malbase substation	Transient fault	Tripped from Malbase end and supply resumed at 04:15hrs.
12	22.09.2022	13:30	22.09.2022	13:33	0	2.48	66kV Phuentsholing feeder	Gomtu substation	Grid failed	Nil	Line segment	Transient fault	Tripped from pling end and supply resumed at 13:33hrs
13	22.09.2022	13:30	22.09.2022	13:38	0	-11.096	66kV Dhamdhum feeder	Gomtu substation	Y phase fault	Distance relay operated, General trip, Zone 4 trip, Y phase fault.	Line segment	Transient fault	Charged the line as per the instruction of BPSO and charge withstand.
14	23.09.2022	3:27	23.09.2022	9:05	5	0.01	66/33kV 5MVA Transformer	Nil	Over current	IDMTL 50R & 50B	Line segment	Feeder fault	Tripped along with 33kV Samtse feeder and charged the transformer after keeping 33kV feeder in trip position.
15	23.09.2022	17:27	23.09.2022	17:42	0	-10.977	66kV Dhamdhum feeder	Gomtu substation	Grid failed	Nil	Line segment	Grid Failed	Grid failed from Malbase substation.
16	23.09.2022	17:43	23.09.2022	17:45	0	4.98	66 KV Phuentsholing feeder .	Gomtu substation	Hand tripped as per BPSO	Nil	Gomtu substation	Hand tripped.	Breaker opened as per BPSO instruction , as P/Ling SS could not charge Line.
17	23.09.2022	20:35	23.09.2022	20:45	0	3.25	66 KV Phuentsholing feeder .	Gomtu substation	Grid failed	Grid failed	Line segment	Grid Failed	Grid failed from Malbase substation.
18	23.09.2022	20:35	23.09.2022	20:45	0	-8.849	66kV Dhamdhum feeder	Gomtu substation	Grid failed	Grid failed	Line segment	Grid Failed	Grid failed from Malbase substation.
19	26.09.2022	10:04	26.09.2022	11:20	1	1.55	66kV Phuentsholing feeder	Nil	Shutdown as per BPSO	Nil	Pling ss	Shutdown	Availed shutdown for arresting sparking from Y phase CT terminal pad at Phuentsholing S/S Against opening code No 044 and shutdown withdrawn at 11:20 after charging code No 1423 given from BPSO
20	30.09.2022	12:32	30.09.2022	12:38	0	-16.056	66kV Dhamdhum feeder	Gomtu substation	Grid failed	Nil	Malbasey substation	Transient fault	Tripped from Malbasey end and supply resumed at 12:38hrs.
21	30.09.2022	13:05	30.09.2022	13:17	0	-10.384	66kV Dhamdhum feeder	Gomtu substation	Grid failed	Nil	Malbasey substation	Transient fault	Tripped from Malbasey end and supply resumed at 13:17hrs.
(F) 220/66/33 kV Dhamdum Substation													
1	15.09.2022	22:41	15.09.2022	22:46	0	-8.8	Malabase	Samtse	-	-	-	-	Grid supply fail
2	16.09.2022	19:29	16.09.2022	19:50	0	-10.28	220kV Malabase fdr.	Samtse	Lightning/thunder and heavy rainfall	REL 670	Dhamdum Substation		General trip, Zone 1, Y phase fault supply failed from Malbase end.
3	16.09.2022	19:29	16.09.2022	20:03	0	-3.09	220kV Singye fdr.	Samtse	Lightning/thunder and heavy rainfall	REL 670	Dhamdum Substation		General trip, Zone 1 trip,R phase fault,supply failed from Malbase end.
4	16.09.2022	22:31	16.09.2022	22:35	0	-0.07	Singeygoan	Samtse	Lightning/thunder and heavy rainfall	REL 670	Dhamdum Substation		General trip, Zone 1, Over current on RØ
5	23.09.2022	17:27	23.09.2022	17:42	0	-11.27	malbase	Samtse			Dhamdum Substation		line tripped from malbase end.No equipment was operated from dhamdum s/s.
6	23.09.2022	20:34	23.09.2022	20:44	0	-8.82	220kV Malabase fdr.	Samtse	Cloudy				line tripped from malbase end.No equipment was operated from dhamdum s/s.
7	23.09.2023	21:34	23.09.2023	21:44	0	-4.04	220kV Singye fdr.	Samtse	Cloudy		Dhamdum Substation		line tripped from malbase end.No equipment was operated from dhamdum s/s.
8	30.09.2022	12:31	30.09.2022	12:37	0	-14.49	220Kv malbase feeder	Samtse	sunny		Dhamdum Substation		line tripped from malbase end.No equipment was operated from dhamdum s/s.
9	30.09.2022	13:05	30.09.2022	13:17	0	-10.06	220Kv malbase feeder	Samtse	sunny		Dhamdum Substation		line tripped from Malbase end.No equipment was operated from dhamdum s/s.



Transmission System Performance Report 2022

Sl. No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment / Substation]	Type of outages	Remarks
(A) 66kV Chumdu switching station													
1	16.09.2022	2328hrs	16.09.2022	2347hrs		(-) 7.83MW	66kV Chukha Feeder	Paro,Pangbasa, Jemina	Grid Fail	Auto operation at Chumdu	Generation end	Grid fail	Grid fail
2	22.09.2022	0246hrs	22.09.2022	0255hrs		(-) 7.83MW							
3	22.09.2022	0355hrs	22.09.2022	0453hrs		(-) 5.25MW							
4	24.09.2022	0815hrs	25.09.2022	1320hrs	5hrs	6.46MW	66kV Paro Feeder	Fed from Panbasa Substation	S/down	CB open Line a & Bus Isolator open, E/switch closed.	For 220kV LIL0 crossing	s/down	S/down by TPO Olakha as per the shutdown approval no.236
5	24.09.2022	1822hrs	24.09.2022	1837hrs		10.013MW	66kV Pangbasa Feeder	Pangbasa substation	Transient fault	CB open 3Ph	Chumdu	Tripped	Trip due to over
6	24.09.2022	1840hrs	24.09.2022	1847hrs		10.013MW							
7	28.09.2022	0752hrs	29.09.2022	1748hrs	9hrs	8.372MW	66kV Pangbasa Feeder	Fed from Paro Substation	S/down	CB open Line a & Bus Isolator open, E/switch closed.	For 220kV LIL0 crossing	s/down	S/down by TPO Olakha as per the shutdown approval no.236
(B) 66/33kV Watsa Substation													
1	16/9/2022	23:28hrs	16/9/2022	23:47hrs		320MW	66KV IC	Fdr. I and II	66KV IC failed from chukha end	66KV IC failed from chukha end	66KV IC failed from chukha end	Tripped	
2	22/9/2022	2:46hrs	22/9/2022	2:55hrs		250MW	66KV IC	Fdr. I and II	66KV IC failed from chukha end	66KV IC failed from chukha end	66KV IC failed from chukha end	Tripped	
3	22/9/2022	3:55hrs	22/9/2022	4:53hrs		250MW	66KV IC	Fdr. I and II	66KV IC failed from chukha end	66KV IC failed from chukha end	66KV IC failed from chukha end	Tripped	
4	28/9/2022	15:03hrs	28/9/2022	15:10hrs		1.57	66KV SF 6 breaker	Fdr. I and II	Over current on ABC phase	Over current relay operated	Fdr. II Chapcha/ Shemaganakha	Tripped	Line tripped due to tree fallen on 33KV damchu line at watsa while TMD Tsimalekha clearing 66Kv ROW



Transmission System Performance Report 2022

(C) 66/22kV Chakha Substation						
Sl. No.	Date	Time	Start Date	End Date	Duration (hrs)	Remarks
1	16-09-2022	23:28	16-09-2022	23:47	0	-7.92 66kV Chakha-Semtokha
						AR 66kV Chakha-Semtokha and 66kV Chakha-Changdaga was affected
						Circuit fail Under Voltage operated Transmission stop line Circuit fail
2	16-09-2022	23:38	16-09-2022	23:47	0	2.11 66kV Chakha-Changdaga
						AR 66kV Chakha-Semtokha and 66kV Chakha-Changdaga was affected
						Circuit fail Under Voltage operated Transmission stop line Circuit fail
3	21-09-2022	0:26	21-09-2022	0:53	0	4.39 66kV Chakha-Changdaga
						AR 66kV Chakha-Semtokha and 66kV Chakha-Changdaga was affected
						Fault 700 Transmission stop line Transmission fault
4	22-09-2022	3:29	22-09-2022	3:56	0	-5.8 66kV Chakha-Semtokha
						AR 66kV Chakha-Semtokha and 66kV Chakha-Changdaga was affected
						Circuit fail Under Voltage operated Transmission stop line Circuit fail
5	22-09-2022	3:55	22-09-2022	4:10	0	-6.34 66kV Chakha-Semtokha
						AR 66kV Chakha-Semtokha and 66kV Chakha-Changdaga was affected
						Circuit fail Under Voltage operated Transmission stop line Circuit fail
6	22-09-2022	4:27	22-09-2022	4:51	0	-0.34 66kV Chakha-Semtokha
						AR 66kV Chakha-Semtokha and 66kV Chakha-Changdaga was affected
						Circuit fail Under Voltage operated Transmission stop line Circuit fail
7	22-09-2022	2:29	22-09-2022	2:56	0	2.11 66kV Chakha-Changdaga
						AR 66kV Chakha-Semtokha and 66kV Chakha-Changdaga was affected
						Circuit fail Under Voltage operated Transmission stop line Circuit fail
8	23-09-2022	3:45	23-09-2022	4:10	0	3.45 66kV Chakha-Changdaga
						AR 66kV Chakha-Semtokha and 66kV Chakha-Changdaga was affected
						Circuit fail Under Voltage operated Transmission stop line Circuit fail
9	22-09-2022	4:27	22-09-2022	4:51	0	3.06 66kV Chakha-Changdaga
						AR 66kV Chakha-Semtokha and 66kV Chakha-Changdaga was affected
						Circuit fail Under Voltage operated Transmission stop line Circuit fail
10	23-09-2022	3:48	23-09-2022	3:51	0	2.92 66kV Chakha-Changdaga
						Only 66kV Chakha-Changdaga was affected
						Fault Under Voltage operated Transmission stop line Transmission fault
11	23-09-2022	4:56	23-09-2022	5:02	0	5.87 66kV Chakha-Changdaga
						Only 66kV Chakha-Changdaga was affected
						Fault Under Voltage operated Transmission stop line Transmission fault



Transmission System Performance Report 2022

1	16.09.2022	23:28	16.09.2022	23:47	0	2.76 & 1.86 (both imports), Changoelapla & Chando respectively	66 kV Line Changoelapla & Chando	Black out	Supply failed from source, no operation at the Substation end.	Nil	Generation source	-	Supply failed from generation source & no operation at the Substation end.	
2	22.09.2022	02:50	22.09.2022	02:57	0	1.20 & 1.68, Changoelapla & Chando respectively	66 kV Line Changoelapla & Chando	Black out	Supply failed from source, no operation at the Substation end.	Nil	Generation source	-	Supply failed from generation source & no operation at the Substation end.	
3	22.09.2022	03:56	22.09.2022	04:54	0	1.20	66 kV Line Chando	Black out	Grid fail also tripped the breakers at the Substation end.	SOTF	Grid fail	-	Supply failed from generation & also tripped the breakers at the Substation end.	
4	22.09.2022	03:56	22.09.2022	06:30	2	-1.68	66 kV Line Changoelapla	Black out till 04:54 hrs	Grid fail also tripped the breakers at the Substation end.	SOTF	Grid fail	-	Supply failed from generation & also tripped the breakers at the Substation end. As per the recommendation of DPSC, the line charged only at 06:30 Hrs.	
(G) 66/33/11kV Dechencholing substation														
1	16.09.2022	23:26Hrs	16.09.2022	23:46Hrs	0	-22.36	66kV Semtokha Incomer	Whole system blackout	Supply failed from source.					
2	22.09.2022	02:49Hrs	22.09.2022	02:54Hrs	0	-20.00	66kV Semtokha Incomer	Whole system blackout	Supply failed from source.					
3	22.09.2022	03:55Hrs	22.09.2022	04:18Hrs	0	-21.61	66kV Semtokha Incomer	Whole system blackout	Supply failed from source.					
4	22.09.2022	04:28Hrs	22.09.2022	04:52Hrs	0	-21.61	66kV Semtokha Incomer	Whole system blackout	Supply failed from source.					
(H) 66/11kV Maa Substation														
1	16.09.2022	23:28	16.09.2022	23:47	0	-0.97	66kV Incomer	All	grid fail	O/C	Chokha power house	Supply tripped from the source.		
2	18.09.2022	13:43	18.09.2022	13:50	0	-1.63	66kV Incomer	All	grid fail	O/C & E/F	Chokha power house	Supply tripped from the source.		
3	22.09.2022	03:49	22.09.2022	03:57	0	-0.68	66kV Incomer	All	grid fail	O/C & E/F	Chokha power house	Supply tripped from the source.		
4	22.09.2022	03:55	22.09.2022	04:42	0	-0.66	66kV Incomer	All	grid fail	O/C & E/F	Chokha power house	Supply tripped from the source.		
5	24.09.2022	10:10	24.09.2022	10:28	0	-1.64	66kV Incomer	All	grid fail	O/C & E/F	Chokha power house	Supply tripped from the source.		
6	24.09.2022	18:22	24.09.2022	18:40	0	-2.14	66kV Incomer	All	grid fail	O/C	Chokha power house	Supply tripped from the source.		
7	28.09.2022	07:52	28.09.2022	17:50	33	-2.23	66kV Incomer	All	220 L.L.O. crossing for Jampje substation.	Nil	Chando switching station	Supply tripped from the source.	Supply tripped from the source. Taken by TSP Okada, Thanglu for 220kV L.L.O. arranged for Jampje substation with the operating code No 714 by DPSC. The same was normalised after getting the clear instructions with a Chokha code No 1446.	



Transmission System Performance Report 2022

(J) 220kV Substation Sentsokha										
1	15.09.2022	18:10hrs	15.09.2022	18:23hrs	66kV Sentsokha-Dochula	Dochula v/s	Y & Bph OC Trip	Backup OCEF relay opnd. Y&Bph I- Trip. IA=263.2A,IB=5.799 KA,IC=5.605KA IN=17.2 SA	Transient	
2	16.09.2022	23:28hrs	16.09.2022	23:47hrs	220kV Sentsokha-Chitwa	Sentsokha v/s	Grid Failed	Chitwa Break-out R-P11 A-248.6A, Y-P11A-70.39A, B-P11-67.67A	Transient	
3	21.09.2022	06:28hrs	21.09.2022	06:48hrs	66kV Sentsokha-Dochula	Dochula v/s	Y & Bph OC Trip	Backup OCEF relay opnd. Y&Bph I- Trip. IA=263.2A,IB=5.799 KA,IC=5.605KA IN=17.2 SA	Transient	
4	22.09.2022	02:49hrs	22.09.2022	02:56hrs	220kV Sentsokha-Fuentsha	Sentsokha v/s	Grid Failed	Main-2 Opnd. RYBph trip	Transient	
5	22.09.2022	02:49hrs	22.09.2022	03:09hrs	66kV Sentsokha-Dochula	Dochula v/s	Y & Bph OC Trip	Backup OCEF relay opnd. Y&Bph I-2 Trip. O/C	Transient	
6	22.09.2022	03:59hrs	22.09.2022	04:19hrs	220kV Sentsokha-Chitwa	Sentsokha v/s	Grid Failed	Main 2, RYB opnd	Transient	
7	22.09.2022	07:48hrs	23.09.2022	03:52hrs	66kV Sentsokha-Dochula	Dochula v/s	Y & Bph OC Trip	Backup OCEF relay opnd. Y&Bph I- Trip. IA=174.2A, IB=5.749KA, IC=5.623KA, IN=17.05A	Transient	
8	23.09.2022	04:56hrs	23.09.2022	05:01hrs	66kV Sentsokha-Dochula	Dochula v/s	Y & Bph OC Trip	Backup OCEF relay opnd. Y&Bph I- Trip. IA=172.1A, IB=5.212KA, IC=5.629KA, IN=17.01A	Transient	
9	23.09.2022	21:42hrs	23.09.2022	22:01hrs	220kV Sentsokha-Fuentsha	Sentsokha v/s		Main 2 protection Opnd. RYBph trip	Transient	
10	23.09.2022	21:42hrs	23.09.2022	22:04hrs	66kV Sentsokha-Dochula	Dochula v/s	Y & Bph OC Trip	Backup OCEF relay opnd. Y&Bph I- Trip. 1	Transient	
11	24.09.2022	02:47hrs	24.09.2022	02:54hrs	66kV Sentsokha-Dochula	Dochula v/s	Y & Bph OC Trip	Backup OCEF relay opnd. Y&Bph I- Trip. 1	Transient	
12	27.09.2022	10:09hrs	27.09.2022	11:19hrs	66kV Sentsokha-Dochula	Dochula v/s	Y & Bph OC Trip	Backup OCEF relay opnd. Y&Bph I- Trip. 1	Transient	
13	28.09.2022	18:37hrs	28.09.2022	18:45hrs	66kV Sentsokha-Dochula	Dochula v/s	Y & Bph OC Trip	Backup OCEF relay opnd. Y&Bph I- Trip. 1	Transient	
(K) 66.2kV Changdaphu Substation										
1	15.09.2022	18:10hrs	15.09.2022	18:23hrs	66kV Changdaphu-Olaktia Line	66kV Changdaphu-Olaktia Line		Distance Protection, Zone 2 RYBph Trip	Transient	
2	16.09.2022	23:28hrs	16.09.2022	00:18hrs	66kV Changdaphu-Olaktia Line	66kV Changdaphu-Olaktia Line		Distance Protection, Zone 2 RYBph Trip	Transient	
3	21.09.2022	06:28hrs	21.09.2022	06:53hrs	66kV Changdaphu-Olaktia Line	66kV Changdaphu-Olaktia Line		Distance Protection, Zone 2 RYBph Trip	Transient	
4	22.09.2022	03:59hrs	22.09.2022	04:23hrs	66kV Changdaphu-Olaktia Line	66kV Changdaphu-Olaktia Line		Distance Protection, Zone 2 RYBph Trip	Transient	
5	23.09.2022	03:48hrs	23.09.2022	03:51hrs	66kV Changdaphu-Olaktia Line	66kV Changdaphu-Olaktia Line		Distance Protection, Zone 2 RYBph Trip	Transient	
6	23.09.2022	04:59hrs	23.09.2022	05:02hrs	66kV Changdaphu-Olaktia Line	66kV Changdaphu-Olaktia Line		Distance Protection, Zone 2 RYBph Trip	Transient	
7	23.09.2022	21:42hrs	23.09.2022	22:05hrs	66kV Changdaphu-Olaktia Line	66kV Changdaphu-Olaktia Line		Distance Protection, Zone 2 RYBph Trip	Transient	
8	24.09.2022	02:47hrs	24.09.2022	02:59hrs	66kV Changdaphu-Olaktia Line	66kV Changdaphu-Olaktia Line		Distance Protection, Zone 2 RYBph Trip	Transient	
9	28.09.2022	18:37hrs	28.09.2022	18:44hrs	66kV Changdaphu-Olaktia Line	66kV Changdaphu-Olaktia Line		Distance Protection, Zone 2 RYBph Trip	Transient	



Transmission System Performance Report 2022

(L) 66.33kV Damsji Substation												
1	16.09.2022	2328 hrs	16.09.2022	2346 hrs	0	-3.91	66 kV Dechencholing Damsji Line	Whole Substation	Trip	NA	NA	Tripped from Sentsikha Substation
2	19.09.2022	1008 hrs	19.09.2022	1513 hrs	5	0.01	Power Transformer I	NA	Shutdown	NA	NA	Avail shutdown by Cheki Hatches for annual maintenance of Transformer
3	21.09.2022	0945 hrs	21.09.2022	1835 hrs	8	3.84	Power Transformer II	NA	Shutdown	NA	NA	Avail shutdown by Cheki Hatches for annual maintenance of Transformers
4	22.09.2022	0249 hrs	22.09.2022	0254 hrs	0	-4.13	66 kV Dechencholing Damsji Line	Whole Substation	Trip	NA	NA	Western Grid Failure
5	22.09.2022	0356 hrs	22.09.2022	0418 hrs	0	-4.12	66 kV Dechencholing Damsji Line	Whole Substation	Trip	NA	NA	Western Grid Failure
6	22.09.2022	0936 hrs	22.09.2022	1159 hrs	2	2.19	Power Transformer I	NA	Shutdown	NA	NA	Avail shutdown by Cheki Hatches for annual maintenance of Transformers i.e. testing of transformer
7	22.09.2022	1214 hrs	22.09.2022	1720 hrs	5	2.02	Power Transformer II	NA	Shutdown	NA	NA	Avail shutdown by Cheki Hatches for annual maintenance of Transformers i.e. testing of transformer
(L) 66.33kV Damsji Substation												
1	16.09.2022	2328 hrs	16.09.2022	2346 hrs	0	-3.91	66 kV Dechencholing Damsji Line	Whole Substation	Trip	NA	NA	Tripped from Sentsikha Substation
2	19.09.2022	1008 hrs	19.09.2022	1513 hrs	5	0.01	Power Transformer I	NA	Shutdown	NA	NA	Avail shutdown by Cheki Hatches for annual maintenance of Transformer
3	21.09.2022	0945 hrs	21.09.2022	1835 hrs	8	3.84	Power Transformer II	NA	Shutdown	NA	NA	Avail shutdown by Cheki Hatches for annual maintenance of Transformers
4	22.09.2022	0249 hrs	22.09.2022	0254 hrs	0	-4.13	66 kV Dechencholing Damsji Line	Whole Substation	Trip	NA	NA	Western Grid Failure
5	22.09.2022	0356 hrs	22.09.2022	0418 hrs	0	-4.12	66 kV Dechencholing Damsji Line	Whole Substation	Trip	NA	NA	Western Grid Failure
6	22.09.2022	0936 hrs	22.09.2022	1159 hrs	2	2.19	Power Transformer I	NA	Shutdown	NA	NA	Avail shutdown by Cheki Hatches for annual maintenance of Transformers i.e. testing of transformer
7	22.09.2022	1214 hrs	22.09.2022	1720 hrs	5	2.02	Power Transformer II	NA	Shutdown	NA	NA	Avail shutdown by Cheki Hatches for annual maintenance of Transformers i.e. testing of transformer



Transmission System Performance Report 2022

October 2022

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
66kV & Above													
(A) 400/220/66/11 kV Malbase Substation													
1	07.10.2022	21:57	07.10.2022	22:53	0	9	220kV malbase-Samtse	Malbase Substation	Tripping	B/U Trip, 86optd			I1=3262A<294.5I2=3150A<149.9I3=90.7A<52.43I4=1704A<233.1
2	08.10.2022	00:05	08.10.2022	01:32	1	6	220kV malbase-Samtse	Malbase Substation	Tripping	M1-trip,zone1 trip,86optd	L2-N, 27.3KM		I1=195A<347.1I2=4273A<4273A<162.3I3=159.3A<344.4I4=3917A<162.1
(B) 220/66/11 kV Singhigao Substation													
1	7.10.22	22:26	8.10.22	00:18	1	6	220kV Singhigao-Samtse	Singhigao Ss	tripped	-	line		O/C, General trip, I1=3720A<204deg, I2=79.73A<101.7deg, I3=95.77A<114.7deg, I4=2543A<283.3deg
2	9.10.22	19:37	9.10.22	21:21	1	3.49	220kV Singhigao-Samtse	Singhigao Ss	tripped	-	line		
3	11.10.22	23:04	11.10.22	23:09	0	0.56	220kV Singhigao-Samtse	Singhigao Ss	tripped	-	line		
(B) 66/33/11 kV Phuntsholing Substation													
1	08.10.2022	00:20	08.10.2022	00:52	0	-3.51	66kV Chukha-Pling feeder	Black out at Pling ss				Tripped at chukha end	At 00:20hrs 66kV Chukha-Pling feeder got tripped from chukha end and 66kV Pling-Gomtu feeder got tripped at our end causing black out at Pling. At 00:52hrs normalised the 66kV Chukha-Pling from Chukha end. At 00:47hrs normalised the 66kV Gomtu feeder with charging code 1493 from BPSO.
2	08.10.2022	00:20	08.10.2022	00:47	0	0.20	66kV Pling-Gomtu fdr	Black out at Pling ss		DSTN OPTD, 186&86		Tripped at our end	
3			08.10.2022	00:30		idle	66kV Pling-Malbase fdr	66kV Pling-Malbase fdr					At 00:32hrs charged 66kV Pling-Malbase feeder which was under idle charge condition with closing code 1491 from BPSO. At 00:58hrs opened CB of above fdr with opening code 072 from BPSO and said feeder kept under idle charged condition after normalising 66kV Chukha and Gomtu feeder.
4	11.10.2022	00:50	11.10.2022	00:55	0	-5.66	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder	Tripped at both end	186&86		Tripped at both end	The cause of tripping was due to transient fault. Test charged after getting clearance from BPSO with charging code 1506 and stood normal.
5	23.10.2022	05:36	23.10.2022	05:46	0	-0.81	66kV Pling-Gomtu fdr	Black out at Pling ss		DSTN OPTD, 186&86		Tripped at our end	At 05:36hrs charged 66kV Pling-Gomtu feeder got tripped at our end. At 05:46hrs normalised the feeder after getting clearance from BPSO.
6			26.10.2022			idle	66kV Pling-Malbase fdr	66kV Pling-Malbase fdr					At 14:25hrs as per instruction from BPSO charged 66kV Pling-Malbase feeder which was under idle charged condition with charging code 1505. Opened CB of 66kV Pling-Malbase feeder at 14:30hrs with opening code 0136 as per instruction from BPSO and feeder was put back to idle charged condition.
(D) 66/33/11 kV Gedu Substation													
1	08.10.2022	0:21	08.10.2022	0:30	0	1.03	66kV chukha-pling fdr	Gedu Black Out					Due to lightning & thundering tripped both source
2	11.10.2022	0:51	11.10.2022	0:56	0	1.26	66kV chukha-pling fdr	Gedu Black Out					Due to lightning & thundering tripped both source
(E) 66/33/11 kV Gomtu Substation													
1	02.10.2022	23:23	07.10.2022	14:06	110	0.01	66/33 kV 5 MVA Transformer	Nil	Punctured 33kV Bus PT	Nil	Gomtu SS	Hand Tripped	66/33kV 5 MVA Transformer manually hand trip due to 33 kV Y Phase Bus PT was punctured. Charged the transformer after changing the 33kV bus PT.
2	8.10.2022	0:20	8.10.2022	0:22	0	-3.354	66kV Dhamdhum feeder	Gomtu ss	Tripped	General tripped	Line segment	Transient Fault	General Tripped. Charged as per BPSO instruction.
3	8.10.2022	0:29	8.10.2022	0:38	0	-3.354	66kV Dhamdhum feeder	Gomtu ss	Tripped	General tripped	Line segment	Transient Fault	General Tripped. Charged as per BPSO instruction.
4	12.10.2022	11:05	12.10.2022	14:12	3	0	66/33kV 5MVA Transformer	33kV Samtse line	Shutdown	Nil	Gomtu SS	Shutdown	Availed shutdown against work permit No. 128 by maintenance team for inspection 33kV samtse feeder breaker and transformer testing as Transformer is producing abnormal sound
5	23.10.2022	5:38	23.10.2022	5:55	0	-5.986	66kV Dhamdhum feeder	Gomtu ss	Grid failed	Nil	Line segment	Transient Fault	Grid failed. From both the source
(F) 220/66/33 kV Dhamdhum Substation													
1	07.10.2022	22:26	08.10.22	00:18	1	-6.01	220kV Sinngeygang Fdr.	-	Heavy rainfall, lightning & thunder	REL670	-	Transient fault	Tripped feeder due to Over current on Y0, Zone - I
2	08.10.2022	00:06	08.10.2022	01:32	1	-5.41	220kV Malabese Fdr.	Samtse Dzongkhag	Heavy rainfall, lightning & thunder	REL670	-	Transient fault	Supply tripped from Malabese end
3	09.10.2022	19:36	09.10.2022	20:00	0	-3.26	220kV Sinngeygang Fdr.	-	Heavy Raining	REL670	-	Transient fault	Feeder tripped due to Over Current on R0 (Zone I) 1) Fault Abs Dist. 6.95% 2) Fault Rel Dist. 17.37%
4	11.10.2022	22:04	11.10.2022	22:09	0	0.55	220kV Sinngeygang Fdr.	-	Heavy Raining	REL670	-	Transient fault	Feeder tripped due to Over Current on R0 (Zone I) General trip, value I1=FA 2189.52A, FM=76.69deg, I2=FA 87.44A, FM=-71.46deg, I3=FA 96.26A, FM=75.89deg
5	14.10.2022	11:08	14.10.2022	13:20	2	0.44	220kV Sinngeygang Fdr.	-	Shutdown	-	-	Shutdown	Shut down taken by Maintenance team Head (TMD) P/ling, Singgoyang. BPSO T/pdu opening code word issued. 099. Closing code No.1522



Transmission System Performance Report 2022

(C) 66/33kV Olakha Substation												
1	07-10-2022	2:04	07-10-2022	2:25	0	3.11	66/33kV 20MVA, Transformer I	All the 33kV was effected as the 33kV Incomer I & II was tripped	Over current and earth fault	Earth Fault Over Current Operated	Distribution line	Transient fault
2	07-10-2022	2:04	07-10-2022	2:25	0	3.1	66/33kV 20MVA, Transformer II	All the 33kV was effected as the 33kV Incomer I & II was tripped	Over current and earth fault	Earth Fault Over Current Operated	Distribution line	Transient fault
(F) 66/33/11kV Jemina Substation												
1	21.10.2022	18:41	21.10.2022	18:48	0	26.07 (Imp) Changedaphu & 22.53 (Exp) Chumdo	66 kV Line Changedaphu & Chumdo	Black out	Supply failed from Semtokha end due to failure of the Bus coupler on OC.	Nil	Semtokha Substation	-
2	24.10.2022	18:22	24.10.2022	18:25	0	27.45 (Imp) Changedaphu & 24.063 (Exp) Chumdo	66 kV Line Changedaphu & Chumdo	Black out	Supply failed from Semtokha end due to failure of the Bus coupler on OC.	Nil	Semtokha Substation	-
3	24.10.2022	18:46	24.10.2022	18:50	0	27.45 (Imp) Changedaphu & 24.063 (Exp) Chumdo	66 kV Line Changedaphu & Chumdo	Black out	Supply failed from Semtokha end due to failure of the Bus coupler on OC.	Nil	Semtokha Substation	-
4	26.10.2022	15:59	26.10.2022	16:20	0	-17.86	66 kV Line Changedaphu	Black out	Supply failed from Changedaphu end to upgrate the CTR of the line.	Nil	Changedaphu	-
5	26.10.2022	16:20	26.10.2022	16:34	0	-17.86	66 kV Line Changedaphu	Black out	SOTF operated	Nil	Changedaphu	-
6	26.10.2022	16:20	26.10.2022	16:37	0	15.48	66 kV Line Chumdo	Black out	SOTF operated	Nil	Changedaphu	-
(H) 66/11kV Haa Substation												
1	18.10.2022	18:12	18.10.2022	18:20	0	-2.81	66kV incomer	All	grid fail	O/C	Chumdo switching station	-
2	18.10.2022	18:29	18.10.2022	18:57	0	-2.81	66kV incomer	All	grid fail	O/C	Chumdo switching station	-
3	21.10.2022	18:41	21.10.2022	18:48	0	-3.04	66kV incomer	All	grid fail	O/C	Chumdo switching station	-
4	22.10.2022	14:35	22.10.2022	14:40	0	-1.83	66kV incomer	All	Emergency shutdown	Nil	Chumdo switching station	-
5	24.10.2022	18:22	24.10.2022	18:25	0	-2.83	66kV incomer	All	Buscoupler tripped	O/C	Changedaphu ss	-
6	24.10.2022	18:45	24.10.2022	18:48	0	-2.83	66kV incomer	All	Buscoupler tripped	O/C	Chukha power house	-
7	26.10.2022	15:58	26.10.2022	16:36	0	-1.7	66kV incomer	All	To upgrade CT ratio	Nil	Changedaphu ss	-
8	28.10.2022	13:09	28.10.2022	14:33	1	-1.94	66kV incomer	All	To upgrade CT ratio	Nil	Pangbesa	-
(I) 220kV Substation Semtokha												
1	07.10.2022	02:05hrs	07.10.2022	02:10hrs			66kV Semtokha-Dochula Line	Dochula s/s	Directional EF trip	Backup OC/EF relay optd, Y&Bph I> Trip..IA=615.8A,IB=520.1A,IC=297.2A		Trasient
2	01-10-2022	13:23 hrs	01-10-2022	14:01 hrs	0 hrs	4.42	66/11kV 20MVA-1 Transformer	Semtokha s/s	Grid Failed	Chukha black-out R-PH A-288.6A.Y-PHA-70.39A.B-PH-676.7A.		Trasient



Transmission System Performance Report 2022

66/33kV Changedaphu Substation											
18:22 hrs	24-10-2022	18:26 hrs	0 hrs	4 mins		66kV Cangidaphu substation	Over Current	OC/EF Relay optd., Over current trip		Trasient	
18:46 hrs	24-10-2022	18:50 hrs	0 hrs	4 mins		66kV Cangidaphu substation	Over Current	OC/EF Relay optd., Over current trip		Trasient	
18:14 hrs	25-10-2022	18:15 hrs	0 hrs	1mins		66kV Cangidaphu substation	Over Current	OC/EF Relay optd., Over current trip		Trasient	
18:38hrs	25-10-2022	18:39 hrs	0 hrs	1 mins		66kV Cangidaphu substation	Over Current	OC/EF Relay optd., Over current trip		Trasient	
18.45hrs	21-10-2022	18:48hrs	0	3mins		66kV Cangidaphu substation	Over Current	OC/EF Relay optd., Over current trip		Trasient	
18:22 hrs	24-10-2022	18:26	0 hrs	4 mins		66kV Cangidaphu substation	Over Current	OC/EF Relay optd., Over current trip		Trasient	
18:46 hrs	24-10-2022	18:51 hrs	0 hrs	5 mins		66kV Cangidaphu substation	Over Current	OC/EF Relay optd., Over current trip		Trasient	
18:14 hrs	25-10-2024	18:16hrs	0hrs	2mins		66kV Cangidaphu substation	Over Current	OC/EF Relay optd., Over current trip		Trasient	
18:38hrs	25-10-2024	18:40hrs	0hrs	2mins		66kV Cangidaphu substation	Over Current	OC/EF Relay optd., Over current trip		Trasient	
02:05 hrs	07-10-2022	02:25hrs	0	15mins		66kV Cangidaphu substation		Distance relay optd., Y&Bph Zone 2 trip		Trasient	
66/33kV Damji Substation											
5/11kV Dochula Substation											
07-10-2022	02:05	07-10-2022	02:13		-32.22	66kV Semtokha	Semtokha - Dochula	Transit fault	Under voltage and 86 relay	Semtokha	Temporary
07-10-2022	02:05	07-10-2022	02:13		-30.25	66kV Lobeyisa	Lobeyisa - Dochula	Transit fault	Under voltage and 86 relay	Lobeyisa	Temporary



Transmission System Performance Report 2022

November 2022

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
(F) 220/66/33 kV Dhamdum Substation													
1	19.11.2022	15:13	19.11.2022	15:17	0	1.46	5MVA TRF. I	Damdum	O/C	REF615 67TRIP		Transient fault	Trip along with Dorokha feeder.
(C) 66/33kV Olakha Substation													
1	25-11-2022	10:02	25-11-2022	10:08	0	11.45	66kV Olakha-Changidaphu	Only 66kV Olakha-Changidaphu was effected	Under Voltage	Distance protection operated	Transmission line	Transient fault	Tripped due to distance portn, under voltage and trip relay 86 indicated.
(H) 66/11kV Haa Substation													
1	29.11.2022	11:53	29.11.2022	13:55	2	1.18	5MVA Transformer - I	5MVA Transformer - I	Tan Delta testing	Nil	Haa substation	Shutdown availed by Mr. Ugyen Phuntsbo, SMD, Semtokha to carryout Tan Delta testion of 5mva transformer - I vide work permit no. 2282, dated 29.11.2022. The same was normalised after completing the work.	Supply tripped from the source
2	29.11.2022	14:01	29.11.2022	15:50	1	2.23	5MVA Transformer - II	5MVA Transformer -II	Tan Delta testing	Nil	Haa substation	Shutdown availed by Mr. Ugyen Phuntsbo, SMD, Semtokha to carryout Tan Delta testion of 5mva transformer - II vide work permit no. 2283, dated 29.11.2022. The same was normalised after completing the work.	Supply tripped from the source
3	29.11.2022	15:52	29.11.2022	16:47	0	2.44	5MVA Transformer - I	5MVA Transformer - I	Tan Delta testing	Nil	Haa substation	Shutdown availed by Mr. Ugyen Phuntsbo, SMD, Semtokha to carryout Tan Delta testion of 5mva transformer - I vide work permit no. 2284, dated 29.11.2022. The same was normalised after completing the work.	Supply tripped from the source
(I) 220kV Substation Semtokha													
1	24-11-2022	10:02hrs	24-11-2022	10:07hrs	0	50.54mw	66kv Semtokha-Dochula Line	Dochula s/s	Over Current	Backup OC/EF relay optd., Y&Bph I> Trip,A=295.8A IB=5.728kA IC=5.522kA IN=17.78A		Transient	
2	24-11-2022	10:02hrs	24-11-2022	10:26hrs	0	-57.01	220kV Semtokha-BHP Line	220kV Semtokha-BHP Line		Distance relay Main-2 Optd, RYBph trip			
3	30-11-2022	10:36hrs	30-11-2022	11:31hrs	0 hrs	-75.04	220kV Semtokha-CHP Line	Shutdown availed by CHP, DGPC, to attend spark on Bph CT at CHP end.		Backup OC/EF relay optd., Y&Bph I> Trip,IA=263.24,1 B=5.799KA,IC=5.605KA,IN=17.26A		Transient	
(M) 66/11kV Dochula Substation													
1	25-11-2022	10:02	25-11-2022	10:19		-32.22	66kV Semtokha	Semtokha - Dochula	Transit fault	Under voltage and 86 relay	Semtokha	Temporary	DHI
2	25-11-2022	10:02	25-11-2022	10:21		-30.25	66kV Lobeyssa	Lobeyssa - Dochula	Transit fault	Under voltage and 86 relay	Lobeyssa	Temporary	DHI



Transmission System Performance Report 2022

December 2022

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks	
66kV & Above														
(A) 400/220/66/11 kV Malbase Substation														
#	03-12-2022	10:14	03-12-2022	13:12	2	0.08	10MVA Transformer I	Malbase Ss	Tripped		substation		Transformer was kept under tripped condition since it indicates Dfferent tripped and inspection was carried out physically and relay setting checked & found normal	
(B)220/66/11 kV Singhgoan Substation														
1														
2														
(B)66/33/11 kV Phuntsholing Substation														
1	06.12.2022	12:00				-12.54	66kV Pling-Malbase fdr	66kV Pling-Malbase fdr					At 12:00hrs Opened CB of 66kV Pling-Malbase feeder with opening code D264 from BPSO and said feeder was kept under idle charged condition.	
2			06.12.2022	17:12		idle	66kV Pling-Malbase fdr	66kV Pling-Malbase fdr					At 17:12hrs charged 66kV pling-Malbase feeder with closing code 1694 which was under idle charged, since at 17:17hrs CB of 66kV Chukha Pling fdr was kept opened at chukha end inorder to avoid overloading at Chukha end. (ie because of increased DHI load at Gedu end)	
#	26.12.2022	23:18	26.12.2022	23:34	0	-8.64	66kV Pling-Gomtu fdr	66kV Pling-Gomtu fdr	Tripped	Dist Prot optd, 186 & 86	Line	Tripped on fault	At 23:25hrs test charged after getting clearance from BPSO but got tripped on same fault. Normalized the feeder after opening CB from Gomtu end.	
(D) 66/33/11 kV Gedu Substation														
1	07.12.2022	8:55	07.12.2022	9:37	0	.16	8MVA 66/33kV TR-II	33kV DHI feeder-III	OTI trip	OTI trip	Substation		Transformer tripped on OTI, charged after checking the OTI and WTI setting for transformer.	
2	09.12.2022	11:00	09.12.2022	17:41	6	15.1	8MVA 66/33kV TR-II	33kV DHI feeder-III	OTI trip	OTI trip	Substation		Work permit no. 42 issued to Mr. Parsu Ram JE, maintenance team for installation of radiator cooling fan.	
3	10.12.2022	12:05	10.12.2022	14:19	2	6.58	8MVA 66/33kV TR-I	33kV DHI feeder-III	OTI trip	OTI trip	Substation		Work permit no. 44 issued to Mr. Parsu Ram JE, maintenance team for installation of radiator cooling fan.	
4														
(E) 66/33/11 kV Gomtu Substation														
1	15.12.2022	13:03	15.12.2022	18:20	5	2.76	66/11kV 10MVA transformer	Gomtu ss	OLTC problem	Nil			Maintenance of OLTC	
2	26.12.2022	23:19	26.12.2022	23:30	0	-15.201	66kV Damdum feeder	Gomtu ss	Y Phase & B phase fault	General Tripped, Zone-4 Trip, Rph Trip, Yph Trip, Bph Trip	Gomtu SS	Transient fault	66 KV Damdum Tripped on distance Protn, Zone-4 Rph Fault Yph Fault Bph Fault	
3	26.12.2022	23:33	26.12.2022	23:36	0	10.69	66kV Phuentsholing feeder	Nil	Hand tripped	Nil	Gomtu SS		Breaker opened as per BPSO instruction, as P/Ling SS could not charge Line.	
(F) 220/66/33 kV Dhamdum Substation														
1	26.12.2022	23:24	26.12.2022	23:28	0	15.16	66kV Gomtu Feeder	Gomtu s/s	O/C	General trip Zone 3 trip RYB faulty		O/C	Tripped on O/C, General trip, Zone 3 trip, RY&B phase fault, IL1: Fault mag. 0.18A, Fault Ang. -141.99 IL2: Fault mag. 0.35A, Fault Ang. -77.27 IL3: Fault mag. 0.11A, Fault Ang. -21.50A	
Tripping Report for the month of DECEMBER 2022														
Sl. No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	Duration of Outages (Min)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
(I) 220kV Substation Sentsokha														
2	23.12.2022	09:55hrs	23.12.2022	10:12hrs	0	17		220kV Sentsokha-BHP Line	220kV Sentsokha-BHP Line	Direct Trip Received	No relay operation		Transient	

















