



ལྷན་སྐྱོད་དང་འཕེལ་རྒྱུ་ཉམས་ལེན་ དཔལ་འབྲས་སྐྱོལ་གཞིའུ་
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 05-Apr-2025(-ve:import, +ve:export)

Report Details		Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
		April 4, 2025	9:00 AM			25-Dec-24	18:38:16	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements		Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	50.00	400kV THP - Siliguri Line - I		0.00	Unit-IV under AMP. Unit III under Shutdown. Unit- II, & VI on Standby. 400kV THP-SIL Line I on Standby. 400kV THP-SIL Line IV under Shutdown.	
		Unit-II	0.00	400kV THP - Siliguri Line - II		-95.15		
		Unit-III	0.00	400kV THP - Siliguri Line- IV		0.00		
		Unit-IV	0.00	400kV THP - Malbase Line - III		170.18		
		Unit-V	26.00	400kV Malbase - Siliguri Line		-143.27		
		Unit-VI	0.00	-		-		
		Total	76.00	Auxiliary Consumption & Transformation Losses at Generator end		1.28%		
2	4 x 180MW MHP	Unit-I	0.00	400kV MHP - Jigmeling Line - I		22.82	Unit-II under AMP. Unit I on Standby 400kV MHP-JLG line-III on Standby. 400kV MHP-JLG line-IV under Shutdown. 132kV MHP_Yurmo Line- I not in Service.	
		Unit-II	0.00	400kV MHP - Jigmeling Line - II		22.72		
		Unit-III	45.53	400kV MHP - Jigmeling Line - III		0.00		
		Unit-IV	45.43	400kV MHP - Jigmeling Line - IV		0.00		
		-	-	132kV MHP - Yurmo Line - I		0.00		
		-	-	132kV MHP - Yurmo Line - II		63.00		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)		196.08		
		-	-	400kV Jigmeling - Alipurduar Line - I : <i>direct lines</i>		19.20		
		-	-	400kV Jigmeling - Alipurduar Line - II : <i>direct lines</i>		17.18		
		-	-	80MVA, 220/132kV ICT - I (HV)		-19.82		
		-	-	80MVA, 220/132kV ICT - II (HV)		-19.65		
		-	-	220kV Tsirang - Jigmeling Line		-104.46		
		-	-	132kV Gelephu - Salakati Line		-17.42		
		Total	90.96	Auxiliary Consumption & Transformation Losses at Generator end		0.35%		
		3	6 x 170MW PHP-II	Unit-I	19.46	400kV PHP II - Jigmeling -I		
Unit-II	0.00			400kV PHP II - Jigmeling -II		189.00		
Unit-III	169.87			400kV PHP II - Alipurduar -I		0.00		
Unit-IV	0.00			400kV PHP II - Alipurduar -II		0.00		
Unit-V	0.00			-		-		
Unit-VI	0.00			-		-		
Total	189.33			Auxiliary Consumption & Transformation Losses at Generator end		0.17%		
4	4 x 84MW CHP	Unit-I	21.07	220kV CHP - Birpara Line - I		-80.50	Unit-II & Unit-III under AMP.	
		Unit-II	0.00	220kV CHP - Birpara Line - II		-79.60		
		Unit-III	0.00	220kV CHP - Gedu		-28.90		
		Unit-IV	20.52	220kV CHP - Jamjee (old) - I		76.10		
		-	-	220kV CHP - Jamjee - II (new)		75.57		
		-	-	220kV CHP - Jamjee - III (new)		72.91		
		-	-	220kV Malbase - Birpara Line		-69.60		
		-	-	66kV CHP - Gedu Line		4.64		
		-	-	3x3MVA, 66/11kV TFR		1.27		
		Total	41.59	Auxiliary Consumption & Transformation Losses at Generator end		0.24%		
5	2 x 12MW BHP (U/S)	Unit-I	4.10	220kV BHP - Semtokha Line		118.74	U/S Unit-II & L/S Unit-II on Standby.	
		Unit-II	0.00	66kV BHP - Lobeysha Line		7.70		
		Total	4.10	220kV BHP - Tsirang Line		-114.59		
6	2 x 20MW BHP (L/S)	Unit-I	8.30	5MVA, 66/11kV TFR		0.38		
		Unit-II	0.00	30MVA ICT, 220/66kV (HV)		4.15		
		Total	8.30	Auxiliary Consumption & Transformation Losses at Generator end		1.37%		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line		14.56	Unit-I on Standby. 220kV DHP-Dagapela line on Standby.	
		Unit-II	14.77	220kV DHP - Dagapela Line		0.00		
		-	-	220kV Jigmeling - Dagapela Line		51.56		
		-	-	5MVA, 220/33kV TFR		0.20		
		Total	14.77	Auxiliary Consumption & Transformation Losses at Generator end		0.07%		
8	4 x 15MW KHP	Unit-I	16.50	132kV KHP - Nangkhor Line		31.25	Unit- III on Standby.	
		Unit-II	16.42	132kV KHP - Kilikhar Line		17.49		
		Unit-III	0.00	5MVA, 132/11kV TFR		0.27		
		Unit-IV	16.48	132kV Motanga - Rangia Line		7.28		
		Total	49.40	Auxiliary Consumption & Transformation Losses at Generator end		0.79%		
9	2 x 59MW NHP	Unit-I	18.02	132kV NHP-MHP-I		17.90	Unit-II under AMP. 132kV NHP-MHP line-II under AMP.	
		Unit-II	0.00	132kV NHP-MHP-II		0.00		
		Total	18.02	Auxiliary Consumption & Transformation Losses at Generator end		0.67%		
10	2 x 9MW SHP	Unit-I	0.00	66kV SHP-Damdhum (Samtse)		0.00	Interim measure: evacuation is through 33kV system	
		Unit-II	0.00	-		-		
		Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end		0.00%		

Note: Generation-Load Summary (MW) for 04-Apr-25 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	492.47	934.35	-441.88

Note: Generation-Load Summary (MW) for 04-Apr-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	420.97	882.41	-461.44

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 05-Apr-2025(-ve:import, +ve:export)							
Report	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
Details	April 4, 2025	18:00:00			25-Dec-2024	18:36	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	0.00	400kV THP - Siliguri Line - I	0.00	Unit-IV under AMP. Unit III Under Shutdown Unit- II & I on Standby. 400kV THP-SIL Line I on Standby. 400kV THP-SIL Line IV under Shutdown .	
		Unit-II	0.00	400kV THP - Siliguri Line - II	-73.40		
		Unit-III	0.00	400kV THP - Siliguri Line - IV	0.00		
		Unit-IV	0.00	400kV THP - Malbase Line - III	189.72		
		Unit-V	76.39	400kV Malbase - Siliguri Line	-122.29		
		Unit-VI	39.84	-	-		
		Total	116.23	Auxiliary Consumption & Transformation Losses at Generator end	-0.08%		
2	4 x 180MW MHP	Unit-I	0.00	400kV MHP - Jigmeling Line - I	0.00	Unit-I on Standby. Unit II under AMP. 400kV MHP-JLG Line I on Standby. 400kV MHP-JLG Line IV under Shutdown. 132kV MHP_Yurmoo Line- I not in Service.	
		Unit-II	0.00	400kV MHP - Jigmeling Line - II	31.29		
		Unit-III	36.33	400kV MHP - Jigmeling Line - III	31.30		
		Unit-IV	70.44	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	132kV MHP - Yurmoo Line - I	0.00		
		-	-	132kV MHP - Yurmoo Line - II	61.17		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	209.46		
		-	-	400kV Jigmeling - Alipurduar Line - I	75.11		
		-	-	400kV Jigmeling - Alipurduar Line - II	74.00		
		-	-	80MVA, 220/132kV ICT - I (HV)	0.07		
		-	-	80MVA, 220/132kV ICT - II (HV)	54.69		
		-	-	220kV Tsirang - Jigmeling Line	-110.81		
		-	-	132kV Gelephu - Salakati Line	-15.16		
		Total	106.77	Auxiliary Consumption & Transformation Losses at Generator end	0.81%		
		3	6 x 170MW PHP-II	Unit-I	140.33		
Unit-II	0.00			400kV PHP II - Jigmeling -II	310.00		
Unit-III	169.77			400kV PHP II - Alipurduar -I	0.00		
Unit-IV	0.00			400kV PHP II - Alipurduar -II	0.00		
Unit-V	0.00			-	-		
Unit-VI	0.00			-	-		
Total	310.10			Auxiliary Consumption & Transformation Losses at Generator end	0.03%		
4	4 x 84MW CHP	Unit-I	31.04	220kV CHP - Birpara Line - I	-74.68	Unit-II & Unit-III under AMP.	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-74.00		
		Unit-III	0.00	220kV CHP - Gedu	-21.48		
		Unit-IV	20.63	220kV CHP - Jamjee - I	73.62		
		-	-	220kV CHP - Jamjee - II	73.19		
		-	-	220kV CHP - Jamjee - III	70.63		
		-	-	220kV Malbase - Birpara Line	-63.86		
		-	-	66kV CHP - Gedu Line	4.92		
		-	-	3x3MVA, 66/11kV TFR	1.34		
		Total	51.67	Auxiliary Consumption & Transformation Losses at Generator end	-3.62%		
5	2 x 12MW BHP (U/S)	Unit-I	4.02	220kV BHP - Semtokha Line	125.60	U/S Unit-II & L/S Unit-II on Standby	
		Unit-II	0.00	66kV BHP - Lobeyssa Line	8.98		
		Total	4.02	220kV BHP - Tsirang Line	-122.61		
6	2 x 20MW BHP (L/S)	Unit-I	8.50	5MVA, 66/11kV TFR	0.44		
		Unit-II	0.00	30MVA ICT, 220/66kV (HV)	5.61		
		Total	8.50	Auxiliary Consumption & Transformation Losses at Generator end	0.88%		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	14.94	Unit-I on Standby. 220kV DHP-Dagapela line on Standby	
		Unit-II	15.17	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	51.56		
		-	-	5MVA, 220/33kV TFR	0.22		
		Total	15.17	Auxiliary Consumption & Transformation Losses at Generator end	0.07%		
8	4 x 15MW KHP	Unit-I	13.45	132kV KHP - Nangkhor Line	23.61	Unit- III on Standby.	
		Unit-II	13.45	132kV KHP - Kilikhar Line	16.14		
		Unit-III	0.00	5MVA, 132/11kV TFR	0.27		
		Unit-IV	13.49	132kV Motanga - Rangia Line	5.60		
		Total	40.39	Auxiliary Consumption & Transformation Losses at Generator end	0.92%		
9	2 x 59MW NHP	Unit-I	0.00	132kV NHP-MHP-I	17.85	Unit-I on Standby. 132kV NHP-MHP line-II under AMP.	
		Unit-II	17.98	132kV NHP-MHP-II	0.00		
		Total	17.98	Auxiliary Consumption & Transformation Losses at Generator end	0.72%		
10	2 x 9MW SHP	Unit-I	0.00	66kV SHP-Damdhum (Samtse)	0.00	Interim measure: evacuation is through 33kV system	
		Unit-II	0.00	-	-		
		Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%		

Note: Generation-Load Summary (MW) for 04-Apr-2025 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	670.83	939.51	-268.68

Note: Generation-Load Summary (MW) for 04-Apr-2024, at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	760.94	891.89	-130.95

Note: Daily Energy (MUs) and Power(MW) Statistics for 04-Apr-2025

Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross-border (MW)
1	18.57	21.82	3.72	0.47	-500.01

- The Instantaneous load balance,calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually.
 - The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.