



འཇམ་ལུང་དང་རང་བཞིན་རྒྱུ་རྩའི་ལྷན་ཁག་གི་འཕེལ་རྒྱུ་ལྷན་ཁག་གི་འཕེལ་རྒྱུ་ལྷན་ཁག་
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 08-Apr-2025(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	April 7, 2025	9:00 AM			25-Dec-24	18:38:16	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	0.00	400kV THP - Siliguri Line - I	0.00	Unit-IV under AMP. Unit III under Shutdown. Unit - II, & I on Standby. 400kV THP-SIL Line I on Standby. 400kV THP-SIL Line IV under Shutdown.	
		Unit-II	0.00	400kV THP - Siliguri Line - II	-114.95		
		Unit-III	0.00	400kV THP - Siliguri Line - IV	0.00		
		Unit-IV	0.00	400kV THP - Malbase Line - III	135.58		
		Unit-V	9.20	400kV Malbase - Siliguri Line	-157.00		
		Unit-VI	11.80	-	-		
		Total	21.00	Auxiliary Consumption & Transformation Losses at Generator end	1.76%		
2	4 x 180MW MHP	Unit-I	0.00	400kV MHP - Jigmeling Line - I	0.00	Unit-II under AMP. Unit I on Standby. 400kV MHP-JLG line-I on Standby. 400kV MHP-JLG line IV under Shutdown. 132kV MHP_Yurmoo Line - I not in Service.	
		Unit-II	0.00	400kV MHP - Jigmeling Line - II	9.72		
		Unit-III	30.38	400kV MHP - Jigmeling Line - III	9.68		
		Unit-IV	36.39	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	62.36		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	209.46		
		-	-	400kV Jigmeling - Alipurduar Line - I <i>direct lines</i>	1.20		
		-	-	400kV Jigmeling - Alipurduar Line - II <i>lines</i>	-0.45		
		-	-	80MVA, 220/132kV ICT - I (HV)	-20.62		
		-	-	80MVA, 220/132kV ICT - II (HV)	-20.45		
		-	-	220kV Tsirang - Jigmeling Line	-101.27		
		-	-	132kV Gelephu - Salakati Line	-20.31		
		Total	66.77	Auxiliary Consumption & Transformation Losses at Generator end	-0.13%		
		3	6 x 170MW PHP-II	Unit-I	20.57		
Unit-II	0.00			400kV PHP II - Jigmeling -II	175.01		
Unit-III	154.99			400kV PHP II - Alipurduar -I	0.00		
Unit-IV	0.00			400kV PHP II - Alipurduar -II	0.00		
Unit-V	0.00			-	-		
Unit-VI	0.00			-	-		
Total	175.56			Auxiliary Consumption & Transformation Losses at Generator end	0.31%		
4	4 x 84MW CHP	Unit-I	19.08	220kV CHP - Birpara Line - I	-83.55	Unit-II & Unit-III under AMP.	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-82.58		
		Unit-III	0.00	220kV CHP - Gedu	-30.38		
		Unit-IV	22.59	220kV CHP - Jamjee (old) - I	79.45		
		-	-	220kV CHP - Jamjee - II (new)	78.84		
		-	-	220kV CHP - Jamjee - III (new)	76.28		
		-	-	220kV Malbase - Birpara Line	-75.02		
		-	-	66kV CHP - Gedu Line	2.90		
		-	-	3x3MVA, 66/11kV TFR	1.39		
		Total	41.67	Auxiliary Consumption & Transformation Losses at Generator end	-1.63%		
5	2 x 12MW BHP (U/S)	Unit-I	4.06	220kV BHP - Semtokha Line	115.82	U/S Unit-II & L/S Unit-II on Standby.	
		Unit-II	0.00	66kV BHP - Lobeyasa Line	7.86		
		Total	4.06	220kV BHP - Tsirang Line	-112.02		
6	2 x 20MW BHP (L/S)	Unit-I	7.69	5MVA, 66/11kV TFR	0.32	U/S Unit-II & L/S Unit-II on Standby.	
		Unit-II	0.00	30MVA ICT, 220/66kV (HV)	4.26		
		Total	7.69	Auxiliary Consumption & Transformation Losses at Generator end	-1.96%		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	14.45	Unit-I on Standby. 220kV DHP-Dagapela line on Standby.	
		Unit-II	14.72	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	51.56		
		-	-	5MVA, 220/33kV TFR	0.26		
		Total	14.72	Auxiliary Consumption & Transformation Losses at Generator end	0.07%		
8	4 x 15MW KHP	Unit-I	0.00	132kV KHP - Nangkor Line	13.64	Unit- I and Unit III on Standby	
		Unit-II	12.66	132kV KHP - Kilikhar Line	11.17		
		Unit-III	0.00	5MVA, 132/11kV TFR	0.32		
		Unit-IV	12.70	132kV Motanga - Rangia Line	-3.88		
		Total	25.36	Auxiliary Consumption & Transformation Losses at Generator end	0.91%		
9	2 x 59MW NHP	Unit-I	0.00	132kV NHP-MHP-I	14.90	Unit-I on Standby. 132kV NHP-MHP line-II on Standby.	
		Unit-II	15.01	132kV NHP-MHP-II	0.00		
		Total	15.01	Auxiliary Consumption & Transformation Losses at Generator end	0.73%		
10	2 x 9MW SHP	Unit-I	3.02	66kV SHP-Damdhum (Samtse)	0.00	Interim measure: evacuation is through 33kV system. 3.02MW is an infirm power.	
		Unit-II	0.00	-	-		
		Total	3.02	Auxiliary Consumption & Transformation Losses at Generator end	100.00%		

Note: Generation-Load Summary (MW) for 07-Apr-25 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	374.86	911.40	-536.54

Note: Generation-Load Summary (MW) for 07-Apr-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	363.45	878.45	-515.00

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 08-Apr-2025(-ve:import,+ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	April 7, 2025	18:00:00			25-Dec-2024	18:36	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	10.19	400kV THP - Siliguri Line - I	0.00	Unit-IV under AMP. Unit III Under Shutdown Unit- II & I on Standby. 400kV THP-SIL Line I on Standby. 400kV THP-SIL Line IV under Shutdown .	
		Unit-II	0.00	400kV THP - Siliguri Line - II	-123.00		
		Unit-III	0.00	400kV THP - Siliguri Line - IV	0.00		
		Unit-IV	0.00	400kV THP - Malbase Line - III	144.04		
		Unit-V	11.56	400kV Malbase - Siliguri Line	-169.00		
		Unit-VI	0.00	-	-		
		Total	21.75	Auxiliary Consumption & Transformation Losses at Generator end	3.26%		
2	4 x 180MW MHP	Unit-I	0.00	400kV MHP - Jigmeling Line - I	0.00	Unit-I on Standby. Unit II under AMP. 400kV MHP-JLG Line I on Standby. 400kV MHP-JLG line IV under Shutdown. 132kV MHP_Yurmoo Line- I not in Service.	
		Unit-II	0.00	400kV MHP - Jigmeling Line - II	59.63		
		Unit-III	89.00	400kV MHP - Jigmeling Line - III	58.66		
		Unit-IV	78.00	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	61.85		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	225.73		
		-	-	400kV Jigmeling - Alipurduar Line - I	32.01		
		-	-	400kV Jigmeling - Alipurduar Line - II	30.49		
		-	-	80MVA, 220/132kV ICT - I (HV)	-28.28		
		-	-	80MVA, 220/132kV ICT - II (HV)	-27.93		
		-	-	220kV Tsirang - Jigmeling Line	-119.51		
		-	-	132kV Gelephu - Salakati Line	-17.93		
		Total	167.00	Auxiliary Consumption & Transformation Losses at Generator end	1.02%		
		3	6 x 170MW PHP-II	Unit-I	40.62		400kV PHP II - Jigmeling -I
Unit-II	0.00			400kV PHP II - Jigmeling -II	210.44		
Unit-III	169.43			400kV PHP II - Alipurduar -I	0.00		
Unit-IV	0.00			400kV PHP II - Alipurduar -II	0.00		
Unit-V	0.00			-	-		
Unit-VI	0.00			-	-		
Total	210.05			Auxiliary Consumption & Transformation Losses at Generator end	-0.19%		
4	4 x 84MW CHP	Unit-I	12.11	220kV CHP - Birpara Line - I	-82.76	Unit-II & Unit-III under AMP.	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-82.15		
		Unit-III	0.00	220kV CHP - Gedu	-28.40		
		Unit-IV	18.96	220kV CHP - Jamjee - I	74.43		
		-	-	220kV CHP - Jamjee - II	73.89		
		-	-	220kV CHP - Jamjee - III	71.24		
		-	-	220kV Malbase - Birpara Line	-69.00		
		-	-	66kV CHP - Gedu Line	4.02		
		-	-	3x3MVA, 66/11kV TFR	1.50		
		Total	31.07	Auxiliary Consumption & Transformation Losses at Generator end	-2.25%		
5	2 x 12MW BHP (U/S)	Unit-I	3.95	220kV BHP - Semtokha Line	116.97	U/S Unit-II & L/S Unit-II on Standby	
		Unit-II	0.00	66kV BHP - Lobeysa Line	23.79		
		Total	3.95	220kV BHP - Tsirang Line	-129.21		
6	2 x 20MW BHP (L/S)	Unit-I	7.90	5MVA, 66/11kV TFR	0.44		
		Unit-II	0.00	30MVA ICT, 220/66kV (HV)	20.59		
		Total	7.90	Auxiliary Consumption & Transformation Losses at Generator end	-1.18%		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	14.50	Unit-I on Standby. 220kV DHP-Dagapela line on Standby	
		Unit-II	14.73	220kV DHP - Dagapela Line	0.31		
		-	-	220kV Jigmeling - Dagapela Line	51.56		
		-	-	5MVA, 220/33kV TFR	-		
		Total	14.73	Auxiliary Consumption & Transformation Losses at Generator end	-0.54%		
8	4 x 15MW KHP	Unit-I	0.00	132kV KHP - Nangkhor Line	18.48	Unit-I & III on Standby.	
		Unit-II	16.47	132kV KHP - Kilikhar Line	14.11		
		Unit-III	0.00	5MVA, 132/11kV TFR	0.24		
		Unit-IV	16.53	132kV Motanga - Rangia Line	5.27		
		Total	33.00	Auxiliary Consumption & Transformation Losses at Generator end	0.52%		
9	2 x 59MW NHP	Unit-I	0.00	132kV NHP-MHP-I	14.85	Unit-I on Standby. 132kV NHP-MHP line-II on Standby.	
		Unit-II	14.98	132kV NHP-MHP-II	0.00		
		Total	14.98	Auxiliary Consumption & Transformation Losses at Generator end	0.87%		
10	2 x 9MW SHP	Unit-I	0.00	66kV SHP-Damdhum (Samtse)	0.00	Interim measure: evacuation is through 33kV system	
		Unit-II	0.00	-	-		
		Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%		

Note: Generation-Load Summary (MW) for 07-Apr-2025 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	504.43	980.50	-476.07

Note: Generation-Load Summary (MW) for 07-Apr-2024, at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	918.30	880.38	37.92

Note: Daily Energy (MUs) and Power(MW) Statistics for 07-Apr-2025

Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross-border (MW)
1	14.44	20.48	6.48	0.46	-652.92

- The Instantaneous load balance,calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually.
 - The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.