



ལྷན་ཁག་དང་འཛམ་གླིང་གི་ལྷན་ཁག་གི་སྐབས་ལྷན་ཁག་གི་འཕྲིན་ལུགས་འཕུལ་བའི་ལྷན་ཁག་  
 Ministry of Energy and Natural Resources  
 Royal Government of Bhutan  
 Office of the Bhutan Power System Operator  
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 14-Apr-2025(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	April 13, 2025	9:00 AM			25-Dec-24	18:38:16	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	10.15	400kV THP - Siliguri Line - I	0.00	Unit-IV under AMP. Unit III under Shutdown. Unit II on Standby. 400kV THP-SIL Line I on Standby. 400kV THP-SIL Line IV under Shutdown.	
		Unit-II	0.00	400kV THP - Siliguri Line - II	-100.60		
		Unit-III	0.00	400kV THP - Siliguri Line - IV	0.00		
		Unit-IV	0.00	400kV THP - Malbase Line - III	120.90		
		Unit-V	10.65	400kV Malbase - Siliguri Line	-140.36		
		Unit-VI	0.00	-	-		
		<b>Total</b>	<b>20.80</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>2.40%</b>		
2	4 x 180MW MHP	Unit-I	40.11	400kV MHP - Jigmeling Line - I	0.00	Unit-II AMP and Unit-III on Standby. 400kV MHP-JLG line-I & IV on Standby. 132kV MHP_Yurmo Line-I not in Service.	
		Unit-II	0.00	400kV MHP - Jigmeling Line - II	76.26		
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	76.85		
		Unit-IV	131.35	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	62.57		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	209.46		
		-	-	400kV Jigmeling - Alipurduar Line - I <i>direct lines</i>	154.00		
		-	-	400kV Jigmeling - Alipurduar Line - II <i>lines</i>	154.00		
		-	-	80MVA, 220/132kV ICT - I (HV)	16.00		
		-	-	80MVA, 220/132kV ICT - II (HV)	16.00		
		-	-	220kV Tsirang - Jigmeling Line	-123.88		
		-	-	132kV Gelephu - Salakati Line	-12.24		
		<b>Total</b>	<b>171.46</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.27%</b>		
		3	6 x 170MW PHP-II	Unit-I	186.35		
Unit-II	186.43			400kV PHP II - Jigmeling -II	372.70		
Unit-III	0.00			400kV PHP II - Alipurduar -I	0.00		
Unit-IV	0.00			400kV PHP II - Alipurduar -II	0.00		
Unit-V	0.00			-	-		
Unit-VI	0.00			-	-		
<b>Total</b>	<b>372.78</b>			<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.02%</b>		
4	4 x 84MW CHP	Unit-I	0.00	220kV CHP - Birpara Line - I	-86.23	Unit-I & Unit-II under AMP.	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-85.07		
		Unit-III	20.16	220kV CHP - Gedu	7.88		
		Unit-IV	21.32	220kV CHP - Jamjee (old) - I	67.03		
		-	-	220kV CHP - Jamjee - II (new)	66.30		
		-	-	220kV CHP - Jamjee - III (new)	64.25		
		-	-	220kV Malbase - Birpara Line	-104.40		
		-	-	66kV CHP - Gedu Line	6.41		
		-	-	3x3MVA, 66/11kV TFR	1.50		
		<b>Total</b>	<b>41.48</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>-1.42%</b>		
5	2 x 12MW BHP (U/S)	Unit-I	4.80	220kV BHP - Semtokha Line	128.72	U/S Unit-II & L/S Unit-II on Standby.	
		Unit-II	0.00	66kV BHP - Lobeyasa Line	25.41		
		<b>Total</b>	<b>4.80</b>	220kV BHP - Tsirang Line	-141.60		
6	2 x 20MW BHP (L/S)	Unit-I	8.40	5MVA, 66/11kV TFR	0.40		
		Unit-II	0.00	30MVA ICT, 220/66kV (HV)	21.28		
		<b>Total</b>	<b>8.40</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>2.05%</b>		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	18.03	Unit-I on Standby. 220kV DHP-Dagapela line on Standby.	
		Unit-II	18.26	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	51.56		
		-	-	5MVA, 220/33kV TFR	0.22		
<b>Total</b>	<b>18.26</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.05%</b>				
8	4 x 15MW KHP	Unit-I	0.00	132kV KHP - Nangkor Line	27.89	Unit-I on Standby	
		Unit-II	15.13	132kV KHP - Kilikhar Line	16.93		
		Unit-III	15.17	5MVA, 132/11kV TFR	0.32		
		Unit-IV	15.10	132kV Motanga - Rangia Line	2.73		
		<b>Total</b>	<b>45.40</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.57%</b>		
9	2 x 59MW NHP	Unit-I	0.00	132kV NHP-MHP-I	44.69	Unit-I on Standby. 132kV NHP-MHP line-II on Standby.	
		Unit-II	45.00	132kV NHP-MHP-II	0.00		
		<b>Total</b>	<b>45.00</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.69%</b>		
10	2 x 9MW SHP	Unit-I	0.00	66kV SHP-Damdhum (Samtse)	0.00	Interim measure: evacuation is through the 33kV system. Unit-I tripped	
		Unit-II	0.00	-	-		
		<b>Total</b>	<b>0.00</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.00%</b>		

Note: Generation-Load Summary (MW) for 13-Apr-25 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	728.38	946.55	-218.17

Note: Generation-Load Summary (MW) for 13-Apr-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	382.51	895.05	-512.54

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 14-Apr-2025(-ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	April 13, 2025	18:00:00			25-Dec-2024	18:36	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	114.42	400kV THP - Siliguri Line - I	0.00	Unit-IV under AMP. Unit III Under Shutdown Unit- II on Standby. 400kV THP-SIL Line I on Standby. 400kV THP-SIL Line IV under Shutdown .	
		Unit-II	0.00	400kV THP - Siliguri Line - II	5.50		
		Unit-III	0.00	400kV THP - Siliguri Line - IV	0.00		
		Unit-IV	0.00	400kV THP - Malbase Line - III	245.31		
		Unit-V	135.63	400kV Malbase - Siliguri Line	-46.54		
		Unit-VI	0.00	-	-		
		<b>Total</b>	<b>250.05</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>-0.30%</b>		
2	4 x 180MW MHP	Unit-I	164.78	400kV MHP - Jigmeling Line - I	0.00	Unit II under AMP. Unit III on Standby. 400kV MHP-JLG Line I & line IV on standby.132kV MHP-Yurmo Line- I not in Service.	
		Unit-II	0.00	400kV MHP - Jigmeling Line - II	115.05		
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	115.86		
		Unit-IV	102.09	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	63.40		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	209.46		
		-	-	400kV Jigmeling - Alipurduar Line - I	199.27		
		-	-	400kV Jigmeling - Alipurduar Line - II	197.52		
		-	-	80MVA, 220/132kV ICT - I (HV)	0.07		
		-	-	80MVA, 220/132kV ICT - II (HV)	54.69		
		-	-	220kV Tsirang - Jigmeling Line	-122.65		
		-	-	132kV Gelephu - Salakati Line	-10.48		
		<b>Total</b>	<b>266.87</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.13%</b>		
3	6 x 170MW PHP-II	Unit-I	174.80	400kV PHP II - Jigmeling -I	0.00	400kV PHP-II - Jigmeling Line-I on Standby.	
		Unit-II	51.10	400kV PHP II - Jigmeling -II	399.30		
		Unit-III	174.70	400kV PHP II - Alipurduar -I	0.00		
		Unit-IV	0.00	400kV PHP II - Alipurduar -II	0.00		
		Unit-V	0.00	-	-		
		Unit-VI	0.00	-	-		
		<b>Total</b>	<b>400.60</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.32%</b>		
4	4 x 84MW CHP	Unit-I	49.84	220kV CHP - Birpara Line - I	-60.93	Unit-II under AMP. Unit-III under Shutdown.	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-60.40		
		Unit-III	0.00	220kV CHP - Gedu	12.08		
		Unit-IV	55.51	220kV CHP - Jamjee - I	70.49		
		-	-	220kV CHP - Jamjee - II	70.00		
		-	-	220kV CHP - Jamjee - III	67.24		
		-	-	220kV Malbase - Birpara Line	-69.44		
		-	-	66kV CHP - Gedu Line	6.24		
		-	-	3x3MVA, 66/11kV TFR	1.45		
		<b>Total</b>	<b>105.35</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>-0.78%</b>		
5	2 x 12MW BHP (U/S)	Unit-I	4.56	220kV BHP - Semtokha Line	127.50	U/S Unit-II & L/S Unit-II on Standby	
		Unit-II	0.00	66kV BHP - Lobeyssa Line	25.17		
		<b>Total</b>	<b>4.56</b>	220kV BHP - Tsirang Line	-138.84		
6	2 x 20MW BHP (L/S)	Unit-I	9.79	5MVA, 66/11kV TFR	0.43		
		Unit-II	-0.05	30MVA ICT, 220/66kV (HV)	21.35		
		<b>Total</b>	<b>9.74</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.28%</b>		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	19.40	Unit-I on Standby. 220kV DHP-Dagapela line on Standby	
		Unit-II	19.84	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	51.56		
		-	-	5MVA, 220/33kV TFR	0.10		
		<b>Total</b>	<b>19.84</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>1.71%</b>		
8	4 x 15MW KHP	Unit-I	0.00	132kV KHP - Nangkhor Line	23.36	Unit- I on Standby.	
		Unit-II	13.45	132kV KHP - Kilikhar Line	16.34		
		Unit-III	13.50	5MVA, 132/11kV TFR	0.37		
		Unit-IV	13.42	132kV Motanga - Rangia Line	8.19		
		<b>Total</b>	<b>40.37</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.74%</b>		
9	2 x 59MW NHP	Unit-I	0.00	132kV NHP-MHP-I	27.79	Unit-I on Standby. 132kV NHP-MHP line-II on Standby.	
		Unit-II	27.99	132kV NHP-MHP-II	0.00		
		<b>Total</b>	<b>27.99</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.71%</b>		
10	2 x 9MW SHP	Unit-I	0.00	66kV SHP-Damdhum (Samtse)	0.00	Interim measure: evacuation is through the 33kV system. Unit I-Tripped at 16:51hrs	
		Unit-II	0.00	-	-		
		<b>Total</b>	<b>0.00</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.00%</b>		

Note: Generation-Load Summary (MW) for 13-Apr-2025 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	1,125.37	962.68	162.69

Note: Generation-Load Summary (MW) for 13-Apr-2024, at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	511.12	910.54	-399.42

Note: Daily Energy (MUs) and Power(MW) Statistics for 13-Apr-2025

Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross-border (MW)
1	22.89	22.02	0.53	1.40	-311.91

1. The instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:  
i) Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.  
2. This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.  
3. When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.