



འཇུག་ལྷན་པུས་ཀྱི་འཇུག་ལྷན་པུས་ལྷན་པུས་ལྷན་པུས་
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 15-Apr-2025(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	April 14, 2025	9:00 AM			25-Dec-24	18:38:16	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	35.16	400kV THP - Siliguri Line - I	0.00	Unit-IV under AMP. Unit III under Shutdown. Unit II & Unit-VI on Standby. 400kV THP-SIL Line I on Standby. 400kV THP-SIL Line IV under Shutdown.	
		Unit-II	0.00	400kV THP - Siliguri Line - II	-90.45		
		Unit-III	0.00	400kV THP - Siliguri Line - IV	0.00		
		Unit-IV	0.00	400kV THP - Malbase Line - III	146.00		
		Unit-V	20.56	400kV Malbase - Siliguri Line	-132.36		
		Unit-VI	0.00	-	-		
		Total	55.72	Auxiliary Consumption & Transformation Losses at Generator end	0.31%		
2	4 x 180MW MHP	Unit-I	51.18	400kV MHP - Jigmeling Line - I	0.00	Unit-II AMP and Unit-III on Standby. 400kV MHP-JLG line-I & IV on Standby. 132kV MHP_Yurmo Line-I not in Service.	
		Unit-II	0.00	400kV MHP - Jigmeling Line - II	28.75		
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	28.91		
		Unit-IV	51.39	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	62.25		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	44.25		
		-	-	400kV Jigmeling - Alipurduar Line - I <i>direct lines</i>	72.00		
		-	-	400kV Jigmeling - Alipurduar Line - II <i>lines</i>	71.27		
		-	-	80MVA, 220/132kV ICT - I (HV)	18.28		
		-	-	80MVA, 220/132kV ICT - II (HV)	18.12		
		-	-	220kV Tsirang - Jigmeling Line	-113.14		
		-	-	132kV Gelephu - Salakati Line	-16.90		
		Total	102.57	Auxiliary Consumption & Transformation Losses at Generator end	0.48%		
		3	6 x 170MW PHP-II	Unit-I	0.00		
Unit-II	140.00			400kV PHP II - Jigmeling -II	289.90		
Unit-III	150.00			400kV PHP II - Alipurduar -I	0.00		
Unit-IV	0.00			400kV PHP II - Alipurduar -II	0.00		
Unit-V	0.00			-	-		
Unit-VI	0.00			-	-		
Total	290.00			Auxiliary Consumption & Transformation Losses at Generator end	0.03%		
4	4 x 84MW CHP	Unit-I	24.98	220kV CHP - Birpara Line - I	-79.60	Unit-II under AMP & Unit III on Standby.	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-78.90		
		Unit-III	0.00	220kV CHP - Gedu	-5.03		
		Unit-IV	26.65	220kV CHP - Jamjee (old) - I	71.30		
		-	-	220kV CHP - Jamjee - II (new)	70.60		
		-	-	220kV CHP - Jamjee - III (new)	68.30		
		-	-	220kV Malbase - Birpara Line	-85.28		
		-	-	66kV CHP - Gedu Line	5.27		
		-	-	3x3MVA, 66/11kV TFR	1.32		
		Total	51.63	Auxiliary Consumption & Transformation Losses at Generator end	-3.16%		
5	2 x 12MW BHP (U/S)	Unit-I	4.55	220kV BHP - Semtokha Line	114.60	U/S Unit-II & L/S Unit-II on Standby.	
		Unit-II	0.00	66kV BHP - Lobeyasa Line	24.37		
		Total	4.55	220kV BHP - Tsirang Line	-125.22		
6	2 x 20MW BHP (L/S)	Unit-I	8.90	5MVA, 66/11kV TFR	0.40	U/S Unit-II & L/S Unit-II on Standby.	
		Unit-II	0.00	30MVA ICT, 220/66kV (HV)	20.57		
		Total	8.90	Auxiliary Consumption & Transformation Losses at Generator end	-5.20%		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	16.52	Unit-I on Standby. 220kV DHP-Dagapela line on Standby.	
		Unit-II	16.75	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	51.22		
		-	-	5MVA, 220/33kV TFR	0.22		
Total	16.75	Auxiliary Consumption & Transformation Losses at Generator end	0.06%				
8	4 x 15MW KHP	Unit-I	0.00	132kV KHP - Nangkor Line	20.89	Unit-I on Standby	
		Unit-II	11.78	132kV KHP - Kilikhar Line	13.94		
		Unit-III	11.79	5MVA, 132/11kV TFR	0.33		
		Unit-IV	11.81	132kV Motanga - Rangia Line	2.31		
		Total	35.38	Auxiliary Consumption & Transformation Losses at Generator end	0.62%		
9	2 x 59MW NHP	Unit-I	0.00	132kV NHP-MHP-I	17.83	Unit-I on Standby. 132kV NHP-MHP line-II on Standby.	
		Unit-II	17.95	132kV NHP-MHP-II	0.00		
		Total	17.95	Auxiliary Consumption & Transformation Losses at Generator end	0.67%		
10	2 x 9MW SHP	Unit-I	0.00	66kV SHP-Damdhum (Samtse)	0.00	Interim measure: evacuation is through the 33kV system. Unit-I tripped @ 22:03hrs on 13.04.2025 and troubleshooting is still being carried out.	
		Unit-II	3.27	-	-		
		Total	3.27	Auxiliary Consumption & Transformation Losses at Generator end	100.00%		

Note: Generation-Load Summary (MW) for 14-Apr-25 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	586.72	924.63	-337.91

Note: Generation-Load Summary (MW) for 14-Apr-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	330.38	894.45	-564.07

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 15-Apr-2025(-ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	April 14, 2025	18:00:00			25-Dec-2024	18:36	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	160.00	400kV THP - Siliguri Line - I	0.00	Unit-IV under AMP. Unit-III under Shutdown Unit - II & VI on Standby. 400kV THP-SIL Line I on Standby. 400kV THP-SIL Line IV under Shutdown .	
		Unit-II	0.00	400kV THP - Siliguri Line - II	35.10		
		Unit-III	0.00	400kV THP - Siliguri Line - IV	0.00		
		Unit-IV	0.00	400kV THP - Malbase Line - III	294.90		
		Unit-V	172.00	400kV Malbase - Siliguri Line	-17.00		
		Unit-VI	0.00	-	-		
		Total	332.00	Auxiliary Consumption & Transformation Losses at Generator end	0.60%		
2	4 x 180MW MHP	Unit-I	84.88	400kV MHP - Jigmeling Line - I	0.00	Unit II under AMP. Unit III on Standby. 400kV MHP-JLG Line I & line IV on standby. 132kV MHP-Yurmoo Line- I not in Service.	
		Unit-II	0.00	400kV MHP - Jigmeling Line - II	92.61		
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	93.11		
		Unit-IV	146.43	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	62.60		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	203.64		
		-	-	400kV Jigmeling - Alipurduar Line - I	99.00		
		-	-	400kV Jigmeling - Alipurduar Line - II	97.00		
		-	-	80MVA, 220/132kV ICT - I (HV)	-24.83		
		-	-	80MVA, 220/132kV ICT - II (HV)	-24.42		
		-	-	220kV Tsirang - Jigmeling Line	-103.83		
		-	-	132kV Gelephu - Salakati Line	-11.30		
		Total	231.31	Auxiliary Consumption & Transformation Losses at Generator end	0.48%		
		3	6 x 170MW PHP-II	Unit-I	0.00		
Unit-II	51.02			400kV PHP II - Jigmeling -II	221.00		
Unit-III	170.74			400kV PHP II - Alipurduar -I	0.00		
Unit-IV	0.00			400kV PHP II - Alipurduar -II	0.00		
Unit-V	0.00			-	-		
Unit-VI	0.00			-	-		
Total	221.76			Auxiliary Consumption & Transformation Losses at Generator end	0.34%		
4	4 x 84MW CHP	Unit-I	61.00	220kV CHP - Birpara Line - I	-56.41	Unit-II under AMP. Unit-III under Shutdown.	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-55.74		
		Unit-III	0.00	220kV CHP - Gedu	-5.72		
		Unit-IV	60.00	220kV CHP - Jamjee - I	78.57		
		-	-	220kV CHP - Jamjee - II	77.86		
		-	-	220kV CHP - Jamjee - III	75.28		
		-	-	220kV Malbase - Birpara Line	-48.16		
		-	-	66kV CHP - Gedu Line	5.30		
		-	-	3x3MVA, 66/11kV TFR	0.95		
		Total	121.00	Auxiliary Consumption & Transformation Losses at Generator end	0.75%		
5	2 x 12MW BHP (U/S)	Unit-I	4.40	220kV BHP - Semtokha Line	103.94	U/S Unit-II & L/S Unit-II on Standby	
		Unit-II	0.00	66kV BHP - Lobeysa Line	24.87		
		Total	4.40	220kV BHP - Tsirang Line	-116.22		
6	2 x 20MW BHP (L/S)	Unit-I	8.90	5MVA, 66/11kV TFR	0.44		
		Unit-II	0.00	30MVA ICT, 220/66kV (HV)	21.18		
		Total	8.90	Auxiliary Consumption & Transformation Losses at Generator end	2.03%		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	16.23	Unit-I on Standby. 220kV DHP-Dagapela line on Standby	
		Unit-II	16.43	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	50.78		
		-	-	5MVA, 220/33kV TFR	0.19		
		Total	16.43	Auxiliary Consumption & Transformation Losses at Generator end	0.06%		
8	4 x 15MW KHP	Unit-I	0.00	132kV KHP - Nangkhor Line	16.16	Unit - I & III on Standby.	
		Unit-II	15.18	132kV KHP - Kilikhar Line	13.69		
		Unit-III	0.00	5MVA, 132/11kV TFR	0.29		
		Unit-IV	15.19	132kV Motanga - Rangia Line	-2.05		
		Total	30.37	Auxiliary Consumption & Transformation Losses at Generator end	0.74%		
9	2 x 59MW NHP	Unit-I	0.00	132kV NHP-MHP-I	18.11	Unit-I on Standby. 132kV NHP-MHP line-II on Standby.	
		Unit-II	18.03	132kV NHP-MHP-II	0.00		
		Total	18.03	Auxiliary Consumption & Transformation Losses at Generator end	-0.44%		
10	2 x 9MW SHP	Unit-I	0.00	66kV SHP-Damdhum (Samtse)	0.00	Interim measure: evacuation is through the 33kV system. Unit-I under Breakdown.	
		Unit-II	3.35	-	-		
		Total	3.35	Auxiliary Consumption & Transformation Losses at Generator end	100.00%		

Note: Generation-Load Summary (MW) for 14-Apr-2025 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	987.55	947.11	40.44

Note: Generation-Load Summary (MW) for 14-Apr-2024, at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	402.81	905.39	-502.58

Note: Daily Energy (MUs) and Power(MW) Statistics for 14-Apr-2025

Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross-border (MW)
1	19.10	22.03	3.45	0.51	-379.90

- The Instantaneous load balance,calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually.
 - The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.