



| THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 05-Jun-2025(-ve:import, +ve:export) |                    |           |                                      |                                                                |             |                                                                               |
|--------------------------------------------------------------------------------------------------------------------------------------|--------------------|-----------|--------------------------------------|----------------------------------------------------------------|-------------|-------------------------------------------------------------------------------|
| Report                                                                                                                               | Date               | Time      | National Coincidental Peak Load (MW) |                                                                | Date        | Time                                                                          |
| Details                                                                                                                              | June 4, 2025       | 19:00:00  |                                      |                                                                | 25-Dec-2024 | 18:36                                                                         |
|                                                                                                                                      |                    |           |                                      |                                                                |             | 1026.44                                                                       |
| Sl. No.                                                                                                                              | Hydropower Plant   | Unit      | MW                                   | Transmission Lines and Elements                                | Load (MW)   | Remarks                                                                       |
| 1                                                                                                                                    | 6 x 170MW THP      | Unit- I   | 124.28                               | 400kV THP - Siliguri Line - I                                  | 0.00        | Unit-III & IV on Standby.<br>400kV THP-Siliguri Line -I under Shutdown.       |
|                                                                                                                                      |                    | Unit- II  | 94.97                                | 400kV THP - Siliguri Line - II                                 | 83.39       |                                                                               |
|                                                                                                                                      |                    | Unit- III | 0.00                                 | 400kV THP - Siliguri Line - IV                                 | 76.81       |                                                                               |
|                                                                                                                                      |                    | Unit- IV  | 0.00                                 | 400kV THP - Malbase Line - III                                 | 312.40      |                                                                               |
|                                                                                                                                      |                    | Unit- V   | 140.60                               | 400kV Malbase - Siliguri Line                                  | 29.04       |                                                                               |
|                                                                                                                                      |                    | Unit- VI  | 109.43                               | -                                                              | -           |                                                                               |
|                                                                                                                                      |                    | Total     | 469.28                               | Auxiliary Consumption & Transformation Losses at Generator end | -0.71%      |                                                                               |
| 2                                                                                                                                    | 4 x 180MW MHP      | Unit-I    | 140.19                               | 400kV MHP - Jigmeling Line - I                                 | 172.84      | 400kV MHP-JLG line-II on Standby.<br>132kV MHP_Yurmoo Line- I not in Service. |
|                                                                                                                                      |                    | Unit-II   | 142.29                               | 400kV MHP - Jigmeling Line - II                                | 0.00        |                                                                               |
|                                                                                                                                      |                    | Unit-III  | 80.25                                | 400kV MHP - Jigmeling Line - III                               | 179.50      |                                                                               |
|                                                                                                                                      |                    | Unit-IV   | 161.50                               | 400kV MHP - Jigmeling Line - IV                                | 179.20      |                                                                               |
|                                                                                                                                      |                    | -         | -                                    | 132kV MHP - Yurmo Line - I                                     | 0.00        |                                                                               |
|                                                                                                                                      |                    | -         | -                                    | 132kV MHP - Yurmo Line - II                                    | 62.00       |                                                                               |
|                                                                                                                                      |                    | -         | -                                    | 500MVA, 400/220kV ICT at Jigmeling (HV)                        | -7.32       |                                                                               |
|                                                                                                                                      |                    | -         | -                                    | 400kV Jigmeling - Alipurduar Line - I                          | 475.64      |                                                                               |
|                                                                                                                                      |                    | -         | -                                    | 400kV Jigmeling - Alipurduar Line - II                         | 474.91      |                                                                               |
|                                                                                                                                      |                    | -         | -                                    | 80MVA, 220/132kV ICT - I (HV)                                  | -43.82      |                                                                               |
|                                                                                                                                      |                    | -         | -                                    | 80MVA, 220/132kV ICT - II (HV)                                 | -44.49      |                                                                               |
|                                                                                                                                      |                    | -         | -                                    | 220kV Tsirang - Jigmeling Line                                 | -102.61     |                                                                               |
|                                                                                                                                      |                    | -         | -                                    | 132kV Gelephu - Salakati Line                                  | 32.68       |                                                                               |
|                                                                                                                                      |                    | Total     | 524.23                               | Auxiliary Consumption & Transformation Losses at Generator end | 0.04%       |                                                                               |
| 3                                                                                                                                    | 6 x 170MW PHP-II   | Unit- I   | 164.42                               | 400kV PHP II - Jigmeling -I                                    | 334.55      | erstwhile interim lines                                                       |
|                                                                                                                                      |                    | Unit- II  | 169.26                               | 400kV PHP II - Jigmeling -II                                   | 333.82      |                                                                               |
|                                                                                                                                      |                    | Unit- III | 170.28                               | 400kV PHP II - Alipurduar -I                                   | 0.00        |                                                                               |
|                                                                                                                                      |                    | Unit- IV  | 169.40                               | 400kV PHP II - Alipurduar -II                                  | 0.00        |                                                                               |
|                                                                                                                                      |                    | Unit- V   | 0.00                                 | -                                                              | -           |                                                                               |
|                                                                                                                                      |                    | Unit- VI  | 0.00                                 | -                                                              | -           |                                                                               |
|                                                                                                                                      |                    | Total     | 673.36                               | Auxiliary Consumption & Transformation Losses at Generator end | 0.74%       |                                                                               |
| 4                                                                                                                                    | 4 x 84MW CHP       | Unit- I   | 57.72                                | 220kV CHP - Birpara Line - I                                   | -13.97      |                                                                               |
|                                                                                                                                      |                    | Unit- II  | 57.56                                | 220kV CHP - Birpara Line - II                                  | -13.64      |                                                                               |
|                                                                                                                                      |                    | Unit- III | 56.89                                | 220kV CHP - Gedu                                               | 60.53       |                                                                               |
|                                                                                                                                      |                    | Unit- IV  | 58.08                                | 220kV CHP - Jamjee - I                                         | 63.74       |                                                                               |
|                                                                                                                                      |                    | -         | -                                    | 220kV CHP - Jamjee - II                                        | 63.32       |                                                                               |
|                                                                                                                                      |                    | -         | -                                    | 220kV CHP - Jamjee - III                                       | 60.90       |                                                                               |
|                                                                                                                                      |                    | -         | -                                    | 220kV Malbase - Birpara Line                                   | -26.65      |                                                                               |
|                                                                                                                                      |                    | -         | -                                    | 66kV CHP - Gedu Line                                           | 7.60        |                                                                               |
|                                                                                                                                      |                    | -         | -                                    | 3x3MVA, 66/11kV TFR                                            | 1.50        |                                                                               |
|                                                                                                                                      |                    | Total     | 230.25                               | Auxiliary Consumption & Transformation Losses at Generator end | 0.12%       |                                                                               |
| 5                                                                                                                                    | 2 x 12MW BHP (U/S) | Unit- I   | 7.63                                 | 220kV BHP - Semtokha Line                                      | 134.76      |                                                                               |
|                                                                                                                                      |                    | Unit- II  | 0.00                                 | 66kV BHP - Lobeysa Line                                        | 26.68       |                                                                               |
|                                                                                                                                      |                    | Total     | 7.63                                 | 220kV BHP - Tsirang Line                                       | -140.01     |                                                                               |
|                                                                                                                                      |                    | Unit- I   | 7.17                                 | 5MVA, 66/11kV TFR                                              | 0.62        |                                                                               |
| 6                                                                                                                                    | 2 x 20MW BHP (L/S) | Unit- II  | 6.65                                 | 30MVA ICT, 220/66kV (HV)                                       | 20.09       |                                                                               |
|                                                                                                                                      |                    | Total     | 13.82                                | Auxiliary Consumption & Transformation Losses at Generator end | -2.80%      |                                                                               |
|                                                                                                                                      |                    | Unit-I    | 40.56                                | 220kV DHP - Tsirang Line                                       | 0.00        |                                                                               |
|                                                                                                                                      |                    | Unit-II   | 0.00                                 | 220kV DHP - Dagapela Line                                      | 40.16       |                                                                               |
| 7                                                                                                                                    | 2 x 63MW DHP       | -         | -                                    | 220kV Jigmeling - Dagapela Line                                | 9.34        | Unit II on Standby.<br>132kV DHP_Tsirang Line on Standby                      |
|                                                                                                                                      |                    | -         | -                                    | 5MVA, 220/33kV TFR                                             | 0.41        |                                                                               |
|                                                                                                                                      |                    | Total     | 40.56                                | Auxiliary Consumption & Transformation Losses at Generator end | -0.02%      |                                                                               |
|                                                                                                                                      |                    | Unit- I   | 16.50                                | 132kV KHP - Nangkhon Line                                      | 41.68       |                                                                               |
| 8                                                                                                                                    | 4 x 15MW KHP       | Unit-II   | 16.60                                | 132kV KHP - Kilikhar Line                                      | 23.66       |                                                                               |
|                                                                                                                                      |                    | Unit- III | 16.48                                | 5MVA, 132/11kV TFR                                             | 0.35        |                                                                               |
|                                                                                                                                      |                    | Unit- IV  | 16.54                                | 132kV Motanga - Rangia Line                                    | 37.55       |                                                                               |
|                                                                                                                                      |                    | Total     | 66.12                                | Auxiliary Consumption & Transformation Losses at Generator end | 0.65%       |                                                                               |
| 9                                                                                                                                    | 2 x 59MW NHP       | Unit-I    | 50.04                                | 132kV NHP-MHP-I                                                | 19.83       |                                                                               |
|                                                                                                                                      |                    | Unit-II   | 20.02                                | 132kV NHP-MHP-II                                               | 49.69       |                                                                               |
|                                                                                                                                      |                    | Total     | 70.06                                | Auxiliary Consumption & Transformation Losses at Generator end | 0.77%       |                                                                               |
| 10                                                                                                                                   | 2 x 9MW SHP        | Unit- I   | 5.02                                 | 66kV SHP-Damdhum (Samtse)                                      | 0.00        | Interim measure: evacuation is through 33kV system.                           |
|                                                                                                                                      |                    | Unit- II  | 4.99                                 | -                                                              | -           |                                                                               |
|                                                                                                                                      |                    | Total     | 10.01                                | Auxiliary Consumption & Transformation Losses at Generator end | 100.00%     |                                                                               |

Note: Generation-Load Summary (MW) for 04-Jun-2025 at 19:00 hrs

| Sl. No. | Region                                   | Total Generation | Total Domestic Load<br>(Total Generation - Total Export) | Total Export(+ve)/<br>Import(-ve) |
|---------|------------------------------------------|------------------|----------------------------------------------------------|-----------------------------------|
| 1       | Both Eastern & Western<br>(Whole Bhutan) | 2,105.32         | 949.56                                                   | 1,155.76                          |

Note: Generation-Load Summary (MW) for 04-Jun-2024, at 19:00 hrs

| Sl. No. | Region                                   | Total Generation | Total Domestic Load<br>(Total Generation - Total Export) | Total Export(+ve)/<br>Import(-ve) |
|---------|------------------------------------------|------------------|----------------------------------------------------------|-----------------------------------|
| 1       | Both Eastern & Western<br>(Whole Bhutan) | 973.44           | 867.76                                                   | 105.68                            |

Note: Daily Energy (MUs) and Power(MW) Statistics for 04-Jun-2025

| Sl. No. | Total Energy<br>Generation | Daily Energy Met | Net Energy Import<br>(IEX and Solar) | Net Energy Export | Peak Cross-border (MW) |
|---------|----------------------------|------------------|--------------------------------------|-------------------|------------------------|
| 1       | 46.13                      | 22.13            | 0.00                                 | 28.17             | 1,274.58               |

- The Instantaneous load balance,calculated as (Total generation - (Total export-Import ) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
  - Not all the meters are digital and now are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.